



**WORKSHOP ON  
ENERGY MANAGEMENT IN INDUSTRIAL SECTOR**

Sponsored by  
**Department of Personnel and Training,**  
Government of India

Conducted by  
**Tata Energy Research Institute**

At  
Vigyan Bhavan, New Delhi)  
November 24-26, 1986

**Programme**

**November 24**

0930-1020	Inaugural Session
0930	Welcome Address - Dr. R.K. Pachauri, Director, Tata Energy Research Institute
0940	Inaugural Address - Mr. Lovraj Kumar, Consultant, Advisory Board on Energy
1005	Remarks on Training Programme - Mr. O.P. Gupta, Director, Department of Personnel and Training
1015	Vote of Thanks - Mr. V.S. Kothari, Fellow, Tata Energy Research Institute
1020-1045	Tea/Coffee Break
1045-1100	Introduction to Programme
1100-1210	Energy Use Patterns in the Industrial Sector and Policy Implications Dr. R.K. Pachauri
1210-1320	Energy Conservation Concepts Mr. V.S. Kothari
1320-1410	Lunch Break
1410-1520	Plant-Level Energy Management Mr. S. Padmanabhan
1520-1540	Tea/Coffee Break
1540-1700	Group Discussion - Energy Management in Industry : Personal Experiences
1830-2000	Reception by Director, Tata Energy Research Institute at 7, Jor Bagh, New Delhi





## **November 25**

- 0930-1040      Energy Conservation in Petroleum Refining Industry :  
Opportunities and Achievements  
Mr. M.K. Joshi and Mr. V. Baskaran
- 1040-1100      Tea/Coffee Break
- 1100-1210      Energy Conservation in Paper Industry  
Mr. H.H. Jethanandani
- 1210-1320      Energy Conservation in Steel Industry  
Dr. S.M. Aeron
- 1320-1410      Lunch Break
- 1410-1520      Case Studies in Energy Conservation  
Mr. Sudhir Mohan
- 1520-1540      Tea/Coffee Break
- 1540-1700      Group Discussion - Technical, Economic and Policy  
Issues and Barriers to Energy Conservation in  
Industry

## **November 26**

- 0930-1040      Industrial Cogeneration  
Mr. V.S. Kothari
- 1040-1100      Tea/Coffee Break
- 1100-1210      Industrial Sector Energy Use Models  
Ms. L. Srivastava
- 1210-1320      Policy Measures for Energy Conservation  
Mrs. S. Chandra
- 1320-1410      Lunch Break
- 1410-1530      Panel Discussion - Formulation and Implementation  
of Policies to Accelerate Energy Conservation in  
Industry
- Panelists :   Mrs. S. Chandra  
                 Mr. M.K. Sridhar  
                 Mr. P. Sengupta  
                 Mr. J. Ramesh
- 1530-1540      Tea/Coffee Break
- 1540-1630      Feedback and Programme Evaluation



**WORKSHOP ON  
ENERGY MANAGEMENT IN INDUSTRIAL SECTOR**

**Sponsored by  
Department of Personnel and Training  
Government of India**

**Conducted by  
Tata Energy Research Institute  
New Delhi**

**at  
Vigyan Bhavan, New Delhi  
November 24-26, 1986**

**LIST OF FACULTY**

**Dr. S.M. Aeron  
Project Coordinator (Thermal Engineering)  
Steel Authority of India Limited  
Research & Development Centre for Iron and Steel  
P.O. Hinoo  
Ranchi 834 002**

**Mr. V. Baskaran  
Deputy Manager (HMTD)  
Engineers India Limited  
Hindustan Times House, 5th Floor  
18-20 Kasturba Gandhi Marg  
New Delhi 110 001**

**Mrs. Shailaja Chandra  
Joint Secretary, Department of Power  
Ministry of Energy  
Shram Shakti Bhavan  
Rafi Marg  
New Delhi 110 001**

**Mr. H.H. Jethanandani  
Vice President  
Ballarpur Industries Limited  
Thapar House  
124, Janpath  
New Delhi 110 001**

**Mr. M.K. Joshi  
Manager(Process)  
Engineers India Limited  
Hindustan Times House, 4th Floor  
18-20, Kasturba Gandhi Marg  
New Delhi 110 001**



Mr. Virendra S. Kothari  
Fellow  
Tata Energy Research Institute  
7 Jor Bagh  
New Delhi 110 003

Mr. Sudhir Mohan  
Product Manager, Heat Recovery Division  
Thermax Private Limited  
Chinchwad  
Pune 411 019

Dr. R.K. Pachauri  
Director  
Tata Energy Research Institute  
7 Jor Bagh  
New Delhi 110 003

Mr. S. Padmanabhan  
Energy Specialist  
Office of Technology Development and Enterprise  
United States Agency for International Development  
American Embassy  
New Delhi 110 021

Mr. Jairam Ramesh  
Officer on Special Duty, I&M Division  
Planning Commission  
Yojana Bhavan  
Parliament Street  
New Delhi 110 001

Mr. Prabir Sengupta  
Joint Secretary  
Advisory Board on Energy  
Sardar Patel Bhavan  
New Delhi 110 001

Mr. M.K. Sridhar  
Director (Technical)  
Bharat Heavy Electricals Limited  
Hindustan Times House  
18-20, Kasturba Gandhi Marg  
New Delhi 110 001

Mrs. Leena Srivastava  
Research Associate  
Tata Energy Research Institute  
7 Jor Bagh  
New Delhi 110 003



**WORKSHOP ON  
ENERGY MANAGEMENT IN INDUSTRIAL SECTOR**

**Sponsored by  
Department of Personnel and Training  
Government of India**

**Conducted by  
Tata Energy Research Institute  
New Delhi**

**at  
Vigyan Bhavan, New Delhi  
November 24-26, 1986**

**List of Participants**

1. Shri B.P. Agarwal  
Assistant Technical Manager (E)  
Central Electronics Limited  
4, Industrial Area  
Sahibabad 201 010  
Uttar Pradesh
2. Shri H.S. Ajwani  
Officer on Special Duty  
Northern Railway  
Ambala (Haryana)
3. Shri Shauquat Alam  
Senior Electrical Inspector  
Government of Assam  
Guwahati
4. Shri Azizullah  
Deputy Manager  
Scooters India Limited  
Post Bag No. 1  
Sarojini Nagar  
Lucknow 226 008
5. Shri G.K. Bajaj  
Manager  
Bharat Pumps & Compressors Limited  
Naini  
Allahabad 211 010





Shri S. Barooa  
Senior Electrical Inspector  
Government of Assam  
Guwahati

Shri V. Baskaran  
Deputy Manager (Heat and Mass Transfer Division)  
Engineers India Limited  
Hindustan Times House, 5th Floor  
18-20, Kasturba Gandhi Marg  
New Delhi 110 001

Shri Gurmel Bhatwa  
Superintending Engineer  
Punjab P.W.D. (B&R)  
Ludhiana

Shri R. Chanda  
Manager (Plant)  
Burn Standard Company Limited  
10-C, Hungerford Street  
Calcutta 700 017

Shri D.P. Chattopadhyay  
Deputy Manager (Management Services Department)  
Burn Standard Company Limited  
10-C, Hungerford Street  
Calcutta 700 017

Shri K.L. Chopra  
Director, Energy Conservation  
Punjab State Electricity Board  
The Mall  
Patiala  
Punjab

Shri B.K. Das  
Secretary to Govt. II, Commerce & Industries Dept.  
Government of Karnataka  
M.S. Building  
Dr. Ambedkar Veedhi  
Bangalore

Dr. S.K. Gangopadhyay  
Industrial Advisor (Energy Audit)  
Bureau of Industrial Costs and Prices  
7th floor, Lok Nayak Bhavan  
New Delhi 110 003



14. Shri A.K. Ghosh  
Plant Engineer  
Fertiliser Corporation of India  
Sindri
15. Shri Bedobrata Goswamy  
Chief Engineer (Distribution)  
Assam State Electricity Board  
Narangi  
Guwahati 26
16. Shri R.K. Gupta  
Technical Manager (ETP)  
Central Electronics Limited  
4, Industrial Area  
Sahibabad 201 010  
Uttar Pradesh
17. Shri P.K. Kapil  
Chief Technical Services Manager  
Indian Oil Corporation Limited  
Indian Oil Bhavan  
Janpath  
New Delhi 110 001
18. Shri B. Lakshminarayan  
Chief Technical Services Manager  
Indian Oil Corporation Limited  
Marketing Division, Northern Region  
World Trade Centre  
Barakhamba Road  
New Delhi 110 001
19. Shri B.K. Mohapatra  
Executive Engineer  
Orissa State Electricity Board  
Bhubhaneshwar  
Orissa
20. Shri K.S. Mukherjee  
Senior Manager (Process)  
Engineers India Limited  
Hindustan Times House, 4th Floor  
18-20, Kasturba Gandhi Marg  
New Delhi 110 001



Shri B.K. Nag  
Manager (Technical)  
Burn Standard Company Limited  
10-C, Hungerford Street  
Calcutta 700 017

Dr. P.J. Nayak  
Managing Director  
Karnataka Agro Industries Corporation Limited  
Hebbal  
Bangalore

Shri S.L. Paliwal  
Chief Engineer (Planning)  
Hindustan Zinc Limited  
6, New Fatehpura  
Udaipur 313 001

Shri J.U. Pereira  
Chief Electrical Engineer  
Government of Goa, Daman and Diu  
Secretariat  
Vidyut Bhavan  
Panaji 403 001  
Goa

Shri D. Prasad  
Senior Design Engineer (Energy Section)  
Metallurgical and Engg. Consultants (India) Ltd.  
Ranchi 834 002  
Bihar

Shri G. Raghavendra  
Works Manager  
Tungabhadra Steel Products Limited  
Tungabhadra Dam 583 225  
Karnataka

Shri K.K. Rai  
Chief Technical Services Manager  
Indian Oil Corporation Limited  
Marketing Division, Western Region  
Keshav Rao Khade Marg  
Mahalaxmi  
Bombay 400 034



28. Dr. L.P. Rai  
Scientist  
NISTADS  
Hillside Road  
New Delhi 110 012
29. Shri K.S. Rangan  
Electrical Engineering Superintendent  
The National Newsprint and Paper Mills Limited  
Nepanagar 450 221  
Madhya Pradesh
30. Shri M.P. Sastry  
Senior Manager, Electrical Maintenance  
Mishra Dhatu Nigam Limited  
Midhani  
P.O. Kanchan Bhagh  
Hyderabad 500 258
31. Shri S.R. Sen  
Chief Manager (Planning)  
Burn Standard Company Limited  
10-C, Hungerford Street  
Calcutta 700 017
32. Shri Gurcharan Singh  
Director  
Department of Coal  
Ministry of Energy  
Shastri Bhavan  
New Delhi 110 001
33. Shri Y. Singh  
Director(TI)  
Research Design and Standards Organisation  
Ministry of Railways  
Lucknow
34. Shri Manoj Yadav  
Assistant Industrial Engineer (Trg)  
Central Electronics Limited  
4, Industrial Area  
Sahibabad 201 010  
Uttar Pradesh





**ENERGY USE PATTERNS IN THE INDUSTRIAL SECTOR AND  
POLICY IMPLICATIONS**

by

**R.K.Pachauri**

**Director,**

**The Tata Energy Research Institute  
7, Jor Bagh, New Delhi 110 003**



## BACKGROUND

Since the first oil price shock in 1973-74 and the second one subsequently in 1979-80, a world-wide effort has been launched to develop more efficient methods for energy use and conversion processes. Several outstanding examples can be quoted of achievements in improving energy efficiency in several countries of the world, but most of these examples remain confined to the developed countries. In the case of the EEC countries for instance during the period between 1973-1983 economic growth has taken place to the extent of 23% with an actual decline of energy consumption of 6%. In the case of Japan, achievements have been of an even higher order, with growth rates averaging close to 5% since the first oil price shock, and this has been accompanied by an actual decline in energy consumption. In the developing world in general and India in particular, however, while the potential for improved management of energy and attainment of higher energy efficiency remains very high it remains virtually untapped. Given the growth in capital intensity of the energy supply industry, it is imperative that a serious effort be launched nationwide for conservation of energy and attainment of higher efficiency in energy use. The prime candidate for efforts in this direction is the industrial sector of the country, since the immediate potential for savings in energy use with so called "housekeeping" measures is of the order of 15%. Further savings are possible with moderate levels of investment, but the rate of return from these investments is attractively high.

## INTERNATIONAL COMPARISONS

In order to assess the overall nature of India's pattern of energy consumption we present in Table 1, shares of oil in total commercial energy demand for 1973-1983 for selected Asian countries. Given India's endowment of coal resources, the share of oil appears somewhat high, and in particular the decline in this share between 1973-1983 is not appreciable. Table 2 shows energy and oil per capita for the same group of countries, and here it would be seen that India has increased its energy consumption per capita somewhat faster than oil consumption per capita. Accordingly, the slow increase in oil consumption does show the effects of conservation and the results of a policy of reducing dependence on oil in the Indian economy. Further, Table 3 shows energy and oil demand as a ratio of GDP.

As against the above aggregate figures, Table 4 shows energy and oil intensity in the industrial sector. These figures stand out in contrast with aggregate figures for per capita consumption and for the economy as a whole. The Indian industrial sector is only second to China in energy intensity, and what is more serious, shows an increase which averages 3.7% during the period 1978-83, a period when conservation efforts should have been bearing fruit, particularly in response to the second oil price shock. Undoubtedly, India's indus-



Table 1 Shares of Oil in Total Commercial Energy Demand (percent)

	1978	1988
Bangladesh	52*	40
China	19	19
India	33	30
Indonesia	87	76
Korea	64	59
Malaysia	94	89
Pakistan	47	35
Philippines	96	82
Taiwan	69	59
Thailand	91	78

\* 1977

Table 2 Energy and Oil Demand per Capita (TOE per 1000 persons)

	ENERGY			OIL		
	1978	1988	AAGR	1978	1988	AAGR
Bangladesh	-	39	-	-	15	-
China	304	446	3.8%	57	83	3.8%
India	130	180	3.3%	43	54	2.3%
Indonesia	86	184	7.6%	75	139	6.2%
Korea	644	1185	6.1%	413	699	5.3%
Malaysia	439	741	5.2%	412	661	4.7%
Pakistan	90	179	6.9%	42	63	3.9%
Philippines	272	261	-0.4%	260	213	-2.0%
Taiwan	910	1625	5.8%	627	966	4.3%
Thailand	216	289	2.9%	197	226	1.4%
Average	231	338	3.8%	73	104	3.5%

Table 3 Energy and Oil Demand and GDP (TOE per 1980 US \$)

	ENERGY			OIL		
	1978	1988	AAGR	1978	1988	AAGR
Bangladesh	-	258	-	-	102	-
China	1607	1480	-0.8%	302	276	-0.9%
India	677	778	1.4%	222	232	0.4%
Indonesia	246	349	3.5%	215	264	2.0%
Korea	608	629	0.3%	390	371	-0.5%
Malaysia	344	387	1.2%	323	345	0.7%
Pakistan	404	634	4.5%	191	222	1.5%
Philippines	467	354	-2.8%	416	290	-4.3%
Taiwan	605	649	0.7%	417	386	-0.8%
Thailand	415	367	-1.2%	379	288	-2.0%
Average	911	910	-	289	280	-0.3%



trial base is very different from several countries of the region excluding China, and therefore a direct comparison with say Indonesia or the Philippines would not be valid. But on the other hand a highly industrialised nation like the Republic of Korea, or for that matter Taiwan, shows much lower energy intensities despite the heavy industrial base in these two states. Even more notable is the reduction in energy intensity that took place between 1978-1983 in the case of the Philippines, Republic of Korea and Thailand. The major issues concerning energy use in the industrial sector that emerge from these figures and a deeper study of the reasons for existing disparities brought out in Table 5 can be listed as follows :

- 1) The entire structure of production in the country needs to be evaluated in terms of intensity of energy use and implied effects on demand for energy.
- 2) The choice of technologies to be adopted both in those industries which have a high intensity of energy use per unit of production and those industries which have a high volume of energy use on account of large scale output, needs to be driven by a concern for energy efficiency.
- 3) A programme for immediate implementation of housekeeping measures to improve energy efficiency and large scale retrofits, at least where capital expenditures are low, has to be taken in hand seriously.

## **PATTERNS OF ENERGY USE IN INDIA'S INDUSTRIAL SECTOR**

The problem of energy efficiency improvements is of course endemic throughout the developing world and several actions and measures can be identified to bring about a substantial improvement in the existing situation. The potential of some of these measures was studied by the World Bank and identified as shown in Table 6. It would be seen that retrofitting and technical improvements are expected to yield the largest savings in energy use.

To see the potential for some of these savings as applicable to India, we would now look at patterns of energy consumption and overall characteristics of energy use in India's industrial sector. These can be seen in terms of specific forms of energy consumed. Firstly, in the case of electricity, of which almost 60% is consumed by the industrial sector, the elasticity of electricity consumption has remained much higher than in several developed as well as developing countries. The figures for this variable computed as changes in consumption with respect to changes in value added in the industrial sector (including mining and manufacturing) at constant 1970-71 prices shows the following values :





Table 4 Industrial Energy and Oil Intensity  
(TOE per 1980 US \$ of Value Added)

	ENERGY			OIL		
	1978	1988	AAGR	1978	1988	AAGR
Bangladesh	402	326	-4.2%	161	91	-12%
China	2435*	2335	-1.4%	-	-	-
India	733	881	3.7%	120	124	0.7%
Indonesia	247	369	8.1%	192	237	4.2%
Korea	453	448	-0.2%	307	177	-11.1%
Malaysia	333	331	-0.1%	259	243	-1.3%
Pakistan	623	558	-2.2%	51	58	2.5%
Philippines	394	297	-5.7%	337	218	-8.7%
Taiwan	517	459	-2.4%	263	200	-5.5%
Thailand	282	228	-4.2%	216	138	-8.9%
Average	488	506	0.7	218	175	-4.3%

\* 1980

Table 5

Period

Elasticity Coefficient  
for Electricity Consumption

1959/60 - 1964/65	1.6825
1964/65 - 1969/70	2.8102
1969/70 - 1975/75	1.1659
1974/75 - 1979/80	1.3244
1979/80 - 1984/85	1.3959
1959/60 - 1984/85	1.6405



TABLE - 6

Potential savings in commercial energy consumption in developing countries, 1980  
(million of barrels per day of oil equivalents)

Savings from:						
	Projected consump- tion	Pricing policies	Taxes and regula- tions	Retrofitting and technical improve- means	Interfuel substitution	Total
Electric power *	7.3	0.1	-\$	0.6	0.1	0.8
Agriculture	1.7	-\$	-\$	0.1	-\$	0.1
Households	6.6	0.3	0.1	0.1	0.5	1.0
Transport	8.4	0.1	0.1	0.7	0.2	1.1
Industry	9.7	0.2	0.2	1.2	0.3	1.9
Other	0.6	0.1	-\$	-\$	-\$	0.1
Total	34.3	(0.8)	(0.4)	(2.7)	(1.1)	5.0

\* Includes energy consumed in generation, station use, losses in transmission, and distribution.

§ Less than 0.05



It would be observed that the largest increase in electricity intensity took place during the period 1964-65 to 1969-70. This was the period when a major shift took place in the heavy industries base of the industrial sector. If we were to project past levels of elasticity of electricity consumption with respect to industrial output, then with a 6.8% compound annual rate of growth in industrial output during the 7th Five Year Plan, we would arrive at demand for electricity of 124 billion Kwh. A simplistic assumption about constant electricity elasticity, however, would not be valid in making future predictions. For instance, if we were to consider the perspective plan brought out by the Planning Commission with the 7th Five Year Plan, the structure of the industrial sector in the year 1999-2000 is expected to be very different from the present. The manufacturing sector itself is likely to increase gross value added from 15% of total output in 1984-85 to 20% in 1999-2000. This increase will be attained largely by a rapid increase in the output of petrochemicals and plastics, fertiliser, aluminium, electronics, telecommunication equipment and components. In the case of the electronics industry alone, it is expected that output would increase 25 times by the year 2000 over the level attained in 1984-85. The demand for energy, therefore, would be highly sensitive to the kind of industrialisation strategies that the country adopts and pursues. If a high value added manufacturing strategy based on low energy consumption industries is pursued then a consequent decline in the electricity elasticity would be possible.

In the recent document indicating the perspective for 2004-2005 the Advisory Board on Energy has estimated electricity demand for the industrial sector at 280 billion Kwh and 367 billion Kwh for 1999-2000 and 2004-2005 respectively. If these estimates are to hold, then the demand for electricity in 1994-95 can be interpolated at around 185 billion Kwh, showing an increase of almost 50% during the 8th Five Year Plan period. Translated into additional generating capacity, this would amount to approximately 16,000 MW. If current estimates of cost per unit capacity are to be assumed, this growth of the industrial sector would imply a capital requirement of approximately Rs.20,000 crores by way of capacity additions in the power sector. It needs to be assessed whether efforts in conservation would result in a lower per unit cost for reductions in capacity required keeping output constant.

Coal use in the industrial sector is mainly in the form of coking coal for the steel industry and non-coking coal for the cement, paper and paper board, newsprint, vanaspati and brick industries. A large cluster of small industries generally accounts for around 20% of total coal consumption, but unfortunately disaggregated data on these is not available. Estimates for production in the iron and steel industry are set at approximately 28 million tonnes of hot metal in the year 2004-05. If there was to be no improvement in the efficiency of coking coal use in the industry, then the demand in the years 1989-90, 1994-95, 1999-2000 and 2004-2005 would be 41.1 million tonnes, 60 million tonnes, 75 million tonnes and 88 million tonnes respectively.



A minimum reduction of about 10% is possible in the consumption of these quantities even with existing technologies and much larger reductions are possible with improved processes in the future.

As regards consumption of non-coking coal, the biggest users are the cement, fertilisers, papers and paper board and brick industries. Almost all the capacity to be added in future in the cement industry would rely on the dry process. But energy savings would be possible if Pozzolana cement is to be produced instead of ordinary Portland cement. Also, by using substitutes like lime, lime-pozzolana or fly ash mixtures, energy requirements can be reduced even further. In the case of nitrogenous fertilisers, future plants are not likely to be coal based, and as such the share of coal use by the fertiliser industry is expected to go down. In the case of the paper industry efficient heat recovery and cogeneration systems can normally reduce total coal requirement by 25-35% per tonne of paper produced.

As far as petroleum products are concerned, the industrial sector uses oil products generally at a rate of 0.004 Kg per rupee of value added. If this norm was to continue unchanged then the demand in the year 2004-2005 would be 16.62 tonnes of petroleum products. Unfortunately data on use of petroleum products in the industrial sector (and most other sectors) is hardly adequate to make possible any analysis of consumption patterns and changes therein. A major effort in carrying out periodic surveys of consumption of oil products needs to be taken in hand on a regular basis.

On the basis of the above projections, we can predict the demand for coal and petroleum products as shown below in Table 7.

Table 7

Year	Requirement of Coal in the Industries Sector (Million Tonnes)
1989-90	89.2
1994-95	120.0
1999-00	150.0
2004-05	188.0
Year	Requirement of petroleum products in Industries as Fuel (in Million Tonnes)
1989/90	6.11
1994/95	8.53
1999/00	11.81





It is evident from the rapid rate of growth shown in these figures that demand for energy in the industrial sector may not be met, given the constraints not only in the coal and petroleum supply industry but also other attendant infrastructure such as transportation. Consequently energy conservation assumes an importance overriding other elements of a long term energy policy.



**ENERGY CONSERVATION CONCEPTS**

**VIRENDRA S. KOTHARI**  
**TATA ENERGY RESEARCH INSTITUTE**  
**NEW DELHI**

**WORKSHOP ON ENERGY MANAGEMENT IN INDUSTRIAL SECTOR**  
**NOVEMBER 24-26, 1986**



## **AREAS FOR ENERGY CONSERVATION**

- Combustion Equipment
- Steam System
- Electrical System
- Process Equipment
- Process Modifications
- Utilities and Off-Site Facilities
  - Compressed Air
  - Refrigeration
  - Cooling Water
  - Fuel Handling
- Services
  - Air Conditioning
  - Lighting

## HEAT LOSSES IN COMBUSTION


- Hydrogen in Fuel

- Moisture in Fuel and Air

- Dry Products of Combustion

- Excess Air

- Flue Gas Temperature



- Unburnt Combustibles

## HEAT LOSSES IN COMBUSTION EQUIPMENT

### ● Generic Losses

- Losses in Combustion
- Radiation
- Openings
- Air Infiltration

### ● Equipment or Equipment Design Specific Losses

- Product Support/Conveyor Losses
- Materials/By-Products e.g. blowdown (boiler), slag (blast furnace)
- Cycling Losses in Batch Operation



# IMPROVING EFFICIENCY OF COMBUSTION EQUIPMENT

- Operating Practices, e.g.

- Burner condition and performance
- Excess air
- Flame shape and heat distribution pattern
- Heat transfer surfaces
- Furnace temperature
- Furnace draft
- Loading

- Excess Air Control and Reduction

- Waste Heat Recovery

- Insulation Enhancement/Replacement


- Combustion System

- Low excess air burners
- High velocity burners
- Self-recuperative burners

## WASTE HEAT RECOVERY

- Equipment modifications/additions are required
- Three general methods
  - Preheat product, i.e. increase heat transfer to product within equipment, e.g. economiser on boiler, convection section on refinery heater, preheat zone on steel reheat furnace
  - Preheat combustion air
  - Heat another fluid or product stream, e.g. water, process liquids (steam can be raised by heating water in waste heat boiler)

**APPROXIMATE FUEL SAVINGS AS FUNCTION  
OF FURNACE EXIT TEMPERATURE  
AND AIR PREHEAT TEMPERATURE**



## WASTE HEAT RECOVERY EQUIPMENT



### ● Classifications can be based on

- Equipment type, e.g. recuperator, economiser
- Mode of heat transfer, e.g. radiation, convection
- Flow configuration, e.g. parallel flow, counter flow, cross flow
- Material, e.g. metallic, ceramic


### ● Equipment Types

- Regenerator
- Recuperator
- Heat Pipe
- Waste Heat Boiler
- Economiser
- Spray Recuperator


## WASTE HEAT RECOVERY EQUIPMENT




# WASTE HEAT RECOVERY EQUIPMENT



**COUNTER-FLOW RECUPERATOR AND TEMPERATURE DISTRIBUTION.**



**PARALLEL-FLOW RECUPERATOR AND TEMPERATURE DISTRIBUTION.**




**CROSS-FLOW RECUPERATOR AND TEMPERATURE DISTRIBUTION**

## TYPES OF FLOWS AND TEMPERATURE DISTRIBUTION


## STEAM SYSTEM

- Steam Leaks and Vents
- Steam Traps
- Insulation
- Condensate Recovery
- Flash Steam Recovery
- Boiler Blowdown
- Pressure Reducing Valves
- Proper Steam Utilisation
  - Maintaining steam quality (dryness)
  - Proper utilisation of directly injected steam
  - Proper air venting
  - Steam utilisation in process at lowest practical pressure

STEAM LEAK LOSSES-calculated heat losses through steam leaks or failed traps (1/32" dia. - 1/2" dia.) as a function of steam line pressure.



UNINSULATED PIPE HEAT LOSS-calculated heat losses per lineal foot from 1/2" through 12" pipe for a 100°F. - 500°F. pipe-room air temperature differential.





## **ELECTRICAL SYSTEM**

■ Greatest savings through proper management of electrical loads

■ Electrical distribution system - savings realisable through elements of proper system design, e.g.

- Selection of voltage levels
- Conductor sizing
- Load centre transformers

■ Electric Motors

- Largest users of electricity in industry
- Performance/Efficiency depends on
  - Motor characteristics, e.g. size, type, speed etc.
  - Application, e.g. actual operating load, duty cycle etc.
  - Service conditions, e.g. voltage variation, voltage unbalance
- Efficiency improvement measures
  - Proper load and application matching
  - Variable speed drives
  - Power factor correction
  - Replacement by more efficient motors (energy efficient motors)

## ● Lighting

- Reduction in illumination levels wherever possible
- Turning off lights when not needed
- Using efficient light sources, e.g. fluorescent lights, sodium vapour lamps

## ● Power Factor

- Poor power factor results in greater kilovolt-ampere (kV) load which limits permissible kilowatt (kW) load on utility distribution system
- Low lagging power factors improved by applying capacitances

## ● Electrical Load Management

- Knowledge of utility rate schedule
- Development of plant electric demand correlated with plant operation
- Identification of peaks and causes
- Peak demand reduction measures
  - Rescheduling operations to lower demand periods
  - Sequencing to spread effect over longer time, e.g. startups of equipment
  - Temporary curtailment of loads associated with 'reservoirs', e.g. air compressors, induction furnaces, air conditioning equipment etc.
- Overall load reduction
  - Replacement of oversized motors
  - Replacement of existing motors by energy efficient motors
  - Lighting efficiency and load

## PROCESS EQUIPMENT

- Proper selection, operation and maintenance affect efficiency of equipment such as heat exchangers, pumps, compressors, turbines, distillation columns, evaporators etc.
  
- Some examples
  - Monitoring heat exchanger surface fouling
  
  - Maintaining lowest possible condenser pressure to improve condensing turbine heat rate
  
  - Substituting multiple effect evaporator for single effect
  
  - Matching capacity and head characteristics of pump or compressor to requirement by reducing impeller diameter, driver speed or driver rating

## PROCESS MODIFICATIONS FOR ENERGY CONSERVATION

- Most of the energy consumed in a plant is transferred to meet a process requirement for work and/or heat

- Approach to Process Analysis

- How is energy utilised or generated within the process ?
- Are reductions in levels of energy use possible ?
- Can an alternative process or processing scheme be used ?
- What are the interactions of energy, environment, and economics associated with potential changes ?
- What effects would potential changes have on product quality and quantity ?

- Second Law Analysis

- Second Law of Thermodynamics - Conversion of energy from one form to another always results in a net loss of quality
- Actual conversion from heat into work is always less than the available work
- High temperature heat should not be degraded into low temperature heat without first extracting work

- Examples

- Heat integration of available energy sources and sinks
- Power recovery from pressurised streams

## UTILITIES AND OFF-SITE FACILITIES

### ● Compressed Air System

- Operating pressure(s)
- Types and sizes of compressors
- Capacity and load matching
- Leaks and vents
- Compressed air users/requirements

•

### ● Refrigeration Equipment

- Types of compressors and controls
- Operating temperature
- Chiller/Condenser performance
  - Operate at highest chiller pressure/temperature and lowest condenser pressure/temperature
- Condenser control

### ● Cooling Towers

- Operating conditions
- Fans operation and control
- Hot water distribution
- Tower performance
- Pumps operation and control

## MEASUREMENTS AND INSTRUMENTATION

Measurements are critical in any serious effort to conserve energy

### Purposes

- Quantify energy consumption within the plant
- Monitor equipment performance
- Check equipment condition

.

### Examples of Measurements and Instrument types

- Flow/Velocity : Orifice plate, Pitot tube, Venturi tube, Turbine meter, Vortex shedding flowmeter, Ultrasonic flowmeter
- Temperature : Thermometers - Bimetallic, Resistance etc., Thermocouple, Radiation pyrometer
- Pressure : Bourdon gauge, Diaphragm gauge, Manometers
- Stack Gas Analysis : Orsat apparatus, Oxygen analysers, Carbon dioxide analysers, Carbon monoxide analysers
- Heat Flow : Thermography equipment
- Electrical : Multimeter, Ammeter, Wattmeter, Power factor meter, Light meter
- Steam Trap Testing : Stethoscope, Ultrasonic detector

## **ENERGY CONSERVATION MEASURES**

### **SHORT-TERM : 6 MONTHS TO 1 YEAR**

- Good Housekeeping, e.g.
  - Prevention of obvious sources of leakage of oil, steam, compressed air, water etc.
  - Prevention of air infiltration into combustion equipment like boilers, furnaces etc.
  - Reduction in heat loss from steam pipes, bare hot surfaces, furnace walls etc. by better insulation practices
  - Better air-fuel ratio control
- Optimum loading of combustion equipment through proper production planning and control
- Recovery of process condensate
- Proper scheduling of electrical loads to limit maximum demand, achieve high load factor, and improve power factor
- Introduction of proper maintenance systems for boilers and furnaces
- Training of boiler and furnace operators

**ENERGY SAVINGS : 10-30 PERCENT DEPENDING ON  
EXISTING LEVEL OF EFFICIENCY**

**RECOVERY OF INVESTMENT : LESS THAN 6 MONTHS**

**AMOUNT OF INVESTMENT : NEGLIGIBLE**

## **ENERGY CONSERVATION MEASURES**

**MEDIUM-TERM : 2 TO 3 YEARS**

- Waste heat recovery devices like air preheater, economiser etc.
- Instrumentation systems on boilers, furnaces and processes, including automatic control
- Variable speed drives for electric motors, energy efficient motors, automatic electrical load management control system, capacitors to improve power factor etc.
- Low-temperature heat recovery devices for central air-conditioning systems, process dryers etc.
- Replacement of existing oil burners by low-excess air burners, firebricks by ceramic fibre etc.
- Minor process modifications for greater efficiency

**ENERGY SAVINGS : 10-20 PERCENT**

**RECOVERY OF INVESTMENT : 6 MONTHS TO 2 YEARS**

**AMOUNT OF INVESTMENT : MODERATE**



## ENERGY CONSERVATION MEASURES

LONG-TERM : 5 TO 10 YEARS

- Total energy systems
- Computers for process control and energy management on real-time basis
- First-order evaluation of technological developments in developed countries relevant to present practices leading to further techno-economic evaluation of attractive options
- Induction of latest technology based on these findings
- Total modernisation of management practices and technology of manufacture

ENERGY SAVINGS : 30-40 PERCENT

RECOVERY OF INVESTMENT : 3 TO 5 YEARS

AMOUNT OF INVESTMENT : SUBSTANTIAL (CAPITAL INTENSIVE)

Workshop on  
Energy Management in Industrial Sector

November 24-26, 1986

GROUP DISCUSSION

Group I : Technical Issues and Barriers in Energy Conservation in Industry

Group II: Economic Issues and Barriers in Energy Conservation in Industry

Group III: Policy Aspects and Incentives for Energy Conservation in Industry

GROUP I

Mr. B.P. Agarwal  
Mr. H.S. Ajwani  
Mr. V. Baskaran  
Mr. R. Chanda  
Mr. Bedobrata Goswamy  
Mr. P.K. Kapil \*  
Mr. D. Prasad  
Mr. G. Raghavendra  
Mr. K.S. Rangan  
Mr. Y. Singh  
Mr. Shauquat Alam  
Mr. A.K. Ghosh

GROUP II

Mr. G.K. Bajaj  
Mr. B.K. Das  
Mr. Azizullah  
Mr. B. Lakshminarayan  
Mr. B.K. Nag  
Mr. S.L. Palival  
Mr. S.R. Sen \*  
Mr. Gurcharan Singh  
Mr. Manoj Yadav  
Mr. Gurmeh Bhatwa  
Mr. B.K. Mohapatra

GROUP III

Mr. D.P. Chattopadhyay  
Mr. K.L. Chopra  
Dr. S.K. Gangopadhyay  
Mr. R.K. Gupta  
Mr. K.S. Mukherjee  
Dr. P.J. Nayak \*  
Mr. J.U. Pereira  
Mr. K.K. Rai  
Mr. M.P. Sastry  
Mr. S. Barooa  
Dr. L.P. Rai

\* Group Moderator



## PLANT - LEVEL ENERGY MANAGEMENT

### Introduction:

The rising cost of energy in India over the past one and a half decades and its poor availability represents, for the industrial sector in particular, a major factor affecting its profitability and competitiveness. Plant level energy management is therefore a sound and sensible approach to adopt by industry as a step to realising economies in the use of energy. This could, in most cases, translate itself to 15-20% energy savings in the short and medium terms itself. The advantages are not solely in the pecuniary gains achieved but also in the areas of improved quality of products and the environment. It also affords an opportunity for various departments to work in a multidisciplinary way that is quite different from the traditional manner that industrial production entails.

The primary use for energy is to provide process heat and cold, drive equipments and machinery, lighting and transport. These end users employ a myriad of processes and present several energy conservation opportunities through interventions of a management and technical kind. These 'interventions' represent decisions and actions that owe their origin to studies and analysis conducted at the plant.

### Types of plant energy studies:

Energy cannot be saved until it is known where and how it is being used. In most cases, the establishment of this baseline requires a comprehensive and detailed survey of energy uses and losses; this survey is referred to as the energy audit. Plant energy studies can be carried out in two sequential phases: the Preliminary Energy Audit (PEA) and the Detailed Energy Audit (DEA). Having conducted an energy audit does not, however, constitute in itself an energy

---

S. Padmanabhan, Energy Specialist, USAID

The views expressed are those of the author and not that necessarily of USAID.

conservation program. A number of other conditions must also be met. First, there must be a will to save energy. Second, viable project must be evaluated according to the company's financial guidelines. Third, financing must be available, and fourth, plant management and staff must be committed to continuing the energy rationalization effort well beyond project implementation, as the benefits of good projects can be lost as quickly as they are gained. Table 1 lists out some of the basic requirements for a successful Plant energy management program.

### Energy Audit Concepts:

It would be important to define the term energy audit at this stage. Although we have been using this term for the past few years, an acceptable definition is yet to emerge. While some consider it as a financial term or statement in respect of energy consumption, others use it as a diagnostic tool for evaluation of energy consumption and strategic planning for conservation. The term was first used in USA in 1977 in connection with the Supplemental State Energy Consumption Program (S.S.E.P.). This was basically for determining minimum eligibility requirement for financial assistance from the state to industry, hospitals, hotels, etc. In some countries like Japan, Taiwan and South Korea this has become a legal requirement like financial audit. The following definition can serve our purpose:

"The energy audit serves to identify all of the energy streams in a facility and quantifies energy use according to discrete functions. It serves the purpose of identifying where and why a facility uses energy and identifies energy conservation opportunities."

As mentioned earlier energy audit can be carried out in two sequential phases: the PEA and the DEA. The PEA is essentially a preliminary data gathering and analysis effort. It consists of two parts: the energy management audit through which the auditor becomes acquainted with investment decision criteria referencing energy conservation projects, and the technical energy audit. The technical part of the PEA uses only available data and is completed without sophisticated instrumentation. The PEA is conducted in a very short time frame and relies heavily on the auditors experience. It focusses on obvious areas of improvement in energy savings such as steam leaks, compressed air leaks, poor insulation, inoperative instrumentation, operational deficiencies of combustion equipment, idling machinery, and so forth. The typical output of a PEA is a set of recommendations on immediate low-cost actions that can be taken and, usually, a recommendation for a Detailed Energy Audit (DEA). Table (2) outlines the steps required for conducting a PEA.

The DEA which must be conducted after a PEA, is an instrumented survey followed by a detailed plant energy analysis. Sophisticated instruments are used to enable the energy auditor to compute energy efficiencies and energy balances during typical equipment operation. The instruments commonly used are flow meters, combustion gas analyzers, psychrometers, heat loss meters, etc. The actual tests performed depend on the type of facility under investigation and the objective, scope and level of funding of the energy management program. Hence a DEA could take as little as 1 man-week or as much as several man-years in a sophisticated refinery or fertilizer plants.

### Data Compilation

Typical forms can be designed to collect data on consumption and costs of energy. Some of these forms are shown in Exhibits 1 through 4. These forms obviously cannot be used for every industry. In addition, they do not show the interaction between energy-using systems (for example between the boiler, steam network and the steam consuming system).

In most of the energy audit programs maximum difficulty is experienced in data collection due to:

- Inadequate instrumentation (for example even where steam flow meter is available, pressure and temperature at the same point may not be available;
- Historical data not available;
- Poor accessibility to equipment; and
- Plant operational and design data unavailable.

### Energy efficiency determination

The efficiency of energy use has two different, although not separate, components - technical efficiency and economic energy efficiency.

The first component, technical efficiency, is often measured by the first law of thermodynamics, which provides a quantitative estimate of the ratio of useful heat output to energy input. The technical efficiency can also be evaluated by the second law of thermodynamics which considers quality of energy and is often preferred when value judgements in energy efficiency must be made. Efficiency under the second law is defined as the ratio of the least amount of energy necessary to achieve a particular objective to the amount of energy actually used to attain this objective. Because second law computation is a rather complex exercise, it is seldom required for the typical energy user and the technical efficiency according to

the first law is of more practical importance today. The second component, economic energy efficiency is not that well defined a concept in absolute terms. Rather, one refers to relative economic energy efficiency when an energy related decision such as fuel substitution in a furnace or cogeneration in a plant results in providing the same energy service at a lower cost.

**Actions to improve the technical energy efficiency would require:**

- i. Experimental investigations to draw up energy balances of equipments and processes.
- ii. Following (i), developing operational procedures in the following areas:
  - a. Improved design and construction
  - b. Maintenance

Let us take the example of a drier and examine briefly some of the areas that an energy auditor should address.

The thermal efficiency of a drier may be expressed as,  
$$\text{efficiency} = \frac{\text{Heat required to evaporate fluid from material}}{\text{Fuel input}}$$

In drying operation, heat must be supplied to:

- o Heat the incoming air
- o Warm the material being handled
- o Heat up the water in the incoming material and evaporate it
- o Make up for the heat losses by conduction, convection, and radiation

The drier efficiency is determined by completing an energy or heat balance of the drier. Conducting a drier heat balance involves measuring a number of items as well as knowing certain properties of the material being dried. Information required includes:

- a. Material moisture content before and after drier.
- b. Fresh air dry bulb/wet bulb temp.
- c. Exhaust air dry bulb/wet bulb temp.
- d. Heat (steam) supplied to heat fresh air
- e. Air flow rate
- f. Material specific heat
- g. Material through-put

Using the above information and psychometric charts it is possible to balance mass and energy flow through the drier. Checklists have also to be prepared in order that certain house-keeping and maintenance procedures are followed.

### **The Energy Management Structure**

The intensiveness of energy usage by industry is a useful indicator of the need and type of energy management structure that may be devised. Some of the major energy intensive industries are -

- (1) Steel plants (primary steel plants, mini-steel plants, integrated steel plants)
- (2) Metallurgical (foundry, forging, aluminium, copper, etc.,)
- (3) Chemicals (organic, inorganic, petrochemicals, chloralkali)
- (4) Others (cement, refractories, ceramic, glass textile, etc.)

All the forms of enterprises mentioned above can be associated with different levels of energy consumption from high energy consuming industries (e.g. steel, aluminium) to lower energy consuming industries (textile, tea). It is indisputable that energy management activities should be present in all of these enterprises with varying degrees of effort and concentration depending mainly upon the scope for energy productivity gains. The energy management activities for the most part would be common to all the enterprises in terms of the nature of the conservation actions initiated. Generally, the common measures, also known as horizontal approach to energy conservation account for almost 60 to 70% of the potential energy savings in a plant. Conservation measures peculiar to a particular industry and process known as the vertical approach towards energy management account for the remainder. Thus the Energy Management structure activities should be responsive to both these approaches.

As a consequence of what has been discussed above, industry should provide for an energy management structure. Fundamentally, this means that the personnel involved in energy management should be empowered with the necessary authority in order to pursue their fundamental tasks related to:

- (1) Planning
- (2) Execution, and
- (3) Control, in the management of energy.



They should be associated with the nodal points of the policy planning and production activities of the enterprises at all levels.

The Energy Management Structure may change depending upon the particular characteristics of the industry, its internal organization, its size and objective and even its geographical location. In a very large industrial plant which has several production plants, the energy management structure would necessarily have to be embodied in several departments and offices in one or more locations of its territory. In these circumstances, an Energy Manager at the top level will be the head of the department of Energy Management with its own staff and will coordinate the energy managers of the various plants the the lower levels. An Organization Structure illustrating this case is given in Exhibit 5.

Enterprises of intermediate size may require a full time Energy Manager at the top level with possibly a suitable staff of full time or part time energy management personnel. The staff could be drawn from various departments and top management could form a committee of production heads to oversee the activities related to energy management. The committee approach has several advantages in that it draws upon the inherent talents within the enterprise and allows for a more democratic manner of functioning. An organization structure illustrating this case is given in Exhibit 6.

In small enterprises, it may not be necessary to have an Energy Manager at all. Rather, the duty could be performed by a senior staff member with the assistance of a few junior engineers. An organization structure illustrating this case is given in Exhibit 7.

In all the above cases, it is extremely important that the functional head of the Energy Management group has access to the top management. Hiarchially each energy man (Personnel in the E.M. group) should be sub-ordinate to the energy manger of his plant, whereas the energy manager is autonomous within the organization, between those responsible for generation and distribution of energy and those responsible for its use. It is also important that the energy management group has within it a wide spectrum of exprience and knowledge ranging from financial competence to technical and maintenance knowhow. The options and suggestions of consultants or of consulting agencies might be of use to enterprises of all types. They can prove to be an important aid to the management of energy in an enterprise.

The energy management structure may vary in terms of its functions in existing industries as against in a projected new industry. Broadly speaking, in existing industry, energy management and conservation is achieved through:

- (1) Proper procedures in operation and maintenance
- (2) A continuous evaluation of energy conservation opportunities

In the above the 'control activity' is largely emphasised.

In a projected new industry, the energy management unit should provide the top management with its analysis of:

- (1) The equipments and processes to be installed
- (2) The input - output fluxes of energy forms
- (3) The scope for process integration, redesign and nature of production runs.

In the above case, largely the 'planning activity' is emphasised. The planning and control activities as separate components can be further understood by the following simple example in a existing plant:

**Example:** In an industry where boilers are installed to meet the process steam requirements, the average efficiency was around 70%. Although at that time when the project was developed 70% was a good figure, in the present stage of technology and higher energy costs, an increased efficiency is both desirable and obtainable.

The Energy Management Approach could involve two case alternatives:

Case 1: Where the residual amortization of equipment (boilers) is relatively higher than the fuel and maintenance costs

In the above case particular attention is to be paid to the achievement of targeted or design performances, even if they are not the best in terms of the present state of technology and high energy costs. Thus the 'control activity' is emphasised.

Case 2: Where the residual amortization of the boilers is relatively low compared to the maintenance and fuel costs

In this case, a new design of the total thermal generation and utilization areas has to be carried out. New high performance boilers may have an efficiency ranging around 90%. In addition, the possibility of co-generation could be examined. These opportunities should induce the energy management group to suggest the installation of new utilities. Here, the 'planning activity' is emphasised.

The control activities would be a routine job for the Energy Management group. An occasional activity would be the development

of norms, targets and goals of energy consumption through the application of energy audits. The specialized activity would be the planning intervention involving major energy project developments.

The activities hitherto explained are an inherent feature of the functions of the energy manager.

### **The Function of the Energy Manager:**

The functions of the energy manager can be broadly classified as:

- (1) The Technical Function
- (2) The Managerial Function

It may be mentioned that the above two components in actual practice cannot be isolated and the duties of the Energy Manager generally involves both of them. The technical function largely relates to the management of thermal energy equipments/processes and electrical energy equipments/processes. The energy management of thermal and electrical equipments are related to and depend upon the several kinds of energy using devices encountered in industrial energy management. Some of the are -

<u>Thermal equipments</u>	<u>Electrical equipments</u>
Burners	Motors
Boilers	Fans
Furnaces	Compressors
Driers	Pumps
etc.	etc.

The technical function of the energy manager is essentially to improve the technical efficiency of the thermal or electrical equipment. The concept of technical efficiency has been touched upon earlier.

The managerial functions of an energy manager may change with the size and the type of the organization. But, they should include some or all of the following:

- (a) To develop an Energy Accounting System
- (b) To coordinate the effort of energy users
- (c) To give technical advice on the energy saving equipments and procedures
- (d) To identify possible energy conservation opportunities
- (e) To train energy users and stimulate interest in energy conservation

- (f) To plan and participate in Energy Audits
- (g) To survey and review the literature on energy developments and properly disseminate this information
- (h) To make plans for energy emergency or cut-backs.

#### **Organizing for Energy Management Data Base:**

If the energy Manager is to fulfil these functions, an Energy Data Base is an essential prerequisite. Record keeping, energy accounting systems and surveys within the company in the fashion of an energy audit provide the data base for any Energy Management program. A corollary to this is that the energy manager must be given access to all information related to the energy flow in the industry. Development of an energy data base is a continuous task and the planning and conduct of energy audits is perhaps the initial step. It may not be necessary for the energy manager or his team to conduct the energy audits. Rather, the work could be left to a core-group of engineers within the plant or the assistance of a consultancy agency may be sought. It is to be mentioned that energy audits are merely an aid to optimising energy usage and not an end by itself. It is important to reiterate certain important guidelines regarding the procedure for energy audit as well as the means for identification of energy saving opportunities.

#### **Energy Accounting:**

Particular records related to energy consumption should be kept. They are:

- (1) The cost evaluation of different forms of energy
- (2) Energy consumptions strictly connected to the process (e.g. electricity in electric arc furnaces, steam consumption in a stenter, etc.)
- (3) Energy consumption related to utilities (e.g. electricity consumption for water pumps, air compressors, refrigeration compressors, etc.
- (4) Energy consumption related to general services such as for lighting.
- (5) Energy consumption related to comfort conditions i.e. electricity for HVAC systems, etc.

It is important to realize that energy accounting or record keeping are required not only as a consequence of energy audits during the initial stages of the planning phase but also after the energy saving strategies have been applied during the control phase.

The monitoring of energy consumption should be continuous and the records of accounting systems uniform and maintained in consistent units. Deviations in energy consumptions must be carefully analyzed and explanations sought. Careful monitoring over a period of time would help the energy manager to understand his equipments better.

#### **Identification of Energy Conservation Opportunities:**

Energy saving opportunities within an industry fall under the following three categories:

- (1) as a consequence of deterioration in equipment performance over time
- (2) As a consequence of up-gradation of technology
- (3) As a consequence of changed plans for the production of goods or services.

Where an energy conservation opportunity presents itself, it falls under either of the two categories:

- (1) As a result of house-keeping measures, which generally involves little or no capital investment. In this circumstance, the energy manager should promptly take necessary action.
- (2) In the second case, the conservation opportunity involves an investment in equipment redesign or retrofit. In the case the energy management structure in the enterprise must involve itself in a feasibility study based on the data base established through detailed energy audits.

Finally, a point may be made on the readability of the energy reports which an energy manager would have to issue from time to time. The energy report has to cope itself with different demands for readability. For instance, an engineer in a production department would be interested only in the energy consumption relevant to his product.

The Purchasing manager may be interested only in the evolution of the energy prices, whereas the the General Manager in the same factory would be interested both in energy consumption per unit of product as well as energy prices since he is responsible for overall costs and efficiency. Several times it has been noted in industry that energy reports have not been carefully compiled to meet the demands of various users in the plant.

#### **Conclusion:**

While the need for energy conservation has been well recognized in Indian industry, the Energy Manager has not yet been preceived to

play a distinct role in company affairs. It is observed that in industries where cost of energy has a crucial impact on the cost of production and profitability, their response to higher energy costs is often limited by the lack of an institutionalized energy management structure to apply the technical options that are available for reducing their energy costs. These technical options require planning and control interventions of a specialized nature.

It may not always be possible for the existing functional departments in industry to take upon itself the responsibility of management of energy.

The paper while discussing the objectives and features of energy auditing, focussed the need to develop an Energy Management structure in industry and outlined the expected functions of the energy manager. It is hoped that the views presented would provide industry with some guidelines in its task of establishing Plant Energy Management programs.

Note: The author would like to record his appreciation to Ms. Jasvinder Kaur for her assistance in typing and editing the manuscript.

Bibliography

1. Training modules for Energy Management in Enterprises, ILO, Turin Centre, Italy
- ii. Proceedings of Seminar on Energy efficiency and Conservation, Brookhaven National Laboratory, USA.
- iii. The Emerging Role of the Energy Manager - S. Padmanabhan, paper presented at National Energy Mgt. Conference, organized by PCRA, March 1985 at Madras.
- iv. Industrial Energy Auditing Manual - prepared for USAID by Hagler, <sup>B</sup>illy and Company, USA and Reliance Energy Services, USA.





Table 1

**Basic requirements for successful plant energy management program**

- o Commitment at Corporate Level to Energy Conservation**
  - Resources, personnel, funds
- o Optimum use of resources**
  - Intercompany information system
  - Centralized technical support
  - Facilities management training
- o Identification of opportunities**
  - Quick payback items
  - Capital intensive projects
  - Evaluation and relationship to production
- o Implementation of projects**
  - Self-financing
  - Capital project selection
  - Specification and bid
- o Establishment of operational criteria**
  - Optimum production/energy targets
  - Operations and maintenance procedures
- o Monitoring and Targets**
  - Evaluation
  - Re-evaluation

Table 2

**Steps in conducting a preliminary energy audit.**

- 1. Organize resources**
  - o Manpower/time frame
  - o Instrumentation
- 2. Identify data requirements**
  - o Data forms
- 3. Collect data**
  - o Conduct informal interviews
  - o Conduct plant walk-through
- 4. Analyze data**
- 5. Develop action plan**
  - o Immediate conservation actions
  - o Projects for further study
  - o Resources for detailing energy audit
  - o Refinement of energy management program.

# ENERGY CONSUMPTION FIGURES

TYPE OF ENERGY														
YEAR	FUEL						ELECTRICITY						Total Kcal	Total Cost
	FURNACE OIL						COAL							
	MT	Rs./ MT	Rs. Kcal	% of Total	% of Total	% of Total	MT	Rs./ MT	Rs. Kcal	% of Total	% of Total	% of Total		
										</				

## Exhibit 1

# PRODUCTION FIGURES

Year	Production, Tonnes	Total Energy consumed, Kcal	Specific Energy consumption of finished product, Kcal/Tonne
1978			
1979			
1980			
1981			
1982			
1983			

FACTORY : ..... Dpt .....

PRESENT STATE

BUDGET

LAST YEAR STATE


PREVISIONS

SPECIFIC CONSUMPTION

UNITS

ENERGY USE PER UNIT OF PRODUCTION

UNIT OF PRODUCTION



PRESENT STATE																				
BUDGET																				
LAST YEAR STATE																				
VAR. CUM.																				

MONTHS	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
--------	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----	-----

## CONSUMING ELECTRICAL ENERGY

TYPE OF ENERGY USED: ELECTRICITY

DEPARTMENT: \_\_\_\_\_


DATE: \_\_\_\_\_

**Total annual  
Energy cost**

**column 1 = h x i**


# ORGANISATION CHART OF A LARGE ENTERPRISE WITH TWO PRODUCTION PLANTS

(Arrows indicate as to whom the Energy Manager could report to)



**Exhibit 5**

ORGANISATIONAL CHART OF A MEDIUM SIZE INDUSTRY



**Exhibit 6**



ORGANISATION CHART OF A SMALL INDUSTRY




Exhibit 7

**ENERGY CONSERVATION IN  
PETROLEUM REFINING INDUSTRY  
OPPORTUNITIES AND ACHIEVEMENTS**



# ENERGY UTILIZATION PROFILE

(INPUT IN EQUIVALENT FUEL TONNES/DAY)

	NEW UNIT	OLD UNIT	OLD UNIT WITH CONSERVATION
FUEL	224.2	352.5	328.7
STEAM	56.2	23.9	27.3
POWER	29.5	24.2	34.8
TOTAL	309.9	400.6	390.8
(% ON CRUDE)	1.78	2.33	2.21

FIGURES GIVEN ABOVE ARE FOR CRUDE/VACUUM UNIT.

TYPICAL PROFILE FOR OVERALL REFINERY		
	A	B
FUEL	60%.	56%.
POWER	12%.	5%.
STEAM	28%.	37%.
REACTION HEAT & OTHER FUELS		2%.

FUEL IS THE LARGEST CHUNK OF ENERGY INPUT

# ENERGY CONSERVATION OPTIONS INCLUDE:


- INCREASED CRUDE PREHEAT
- INTEGRATION & MAXIMISATION OF LOW LEVEL HEAT RECOVERY
- ADDITION & MODIFICATION OF EQUIPMENT
- CHANGES IN PROCESS PARAMETERS
- CHANGES IN TECHNOLOGY
- COGENERATION
- FLARE GAS RECOVERY
- GOOD HOUSEKEEPING




ENERGY CONSERVATION SCHEMES SHOULD  
AIM FOR

- MINIMISING FUEL CONSUMPTION
- MINIMISING HEAT LOSS TO COOLERS

TYPICAL BENEFITS

- EACH  $10^{\circ}\text{C}$  PREHEAT IN A 6MMT/YR REFINERY  
SAVES  $\sim 3500 - 4000$  MT/YR OF FUEL.
- PREHEATING 100 MT/HR OF BFW TO  $140^{\circ}\text{C}$   
SAVES  $\sim 10000$  T/YR OF FUEL.






~~DEF. PASSENGER TRAIN~~



## MODIFICATION ADDITION OF EQUIPMENT FOR IMPROVED THERMAL EFFICIENCY,


- ADDITION OF AIR PREHEATERS.
- USE OF PREFLASH DRUM
- USE OF VACUUM PUMPS
- USE OF EFFICIENT TOWER INTERNALS



BUDGETARY COST OF PUMP & MOTOR	\$ 60,000
III STAGE EJECTOR	\$ 19,000
OPERATING COST OF VACUUM PUMP.	\$ 55,648 / YEAR
IV STAGE EJECTOR	\$ 28,6918 / YEAR

USE OF VACUUM PUMP IN PLACE OF III STAGE EJECTOR

# USE OF A PREFLASH DRUM



	A	B
CRUDE PREHEAT TEMP °C	285	285
PREFLASH DRUM PRES. (KG/CM <sup>2</sup> A)	-	4.5
PREFLASH DRUM TEMP °C	-	190
% FEED FLASHED	-	7
HEATER OUTLET TEMP °C	382	386
HEATER DUTY KCALB/HR	79 × 10 <sup>6</sup>	72 × 10 <sup>6</sup>

A FLOW SCHEME WITHOUT FLASH DRUM

B FLOW SCHEME WITH FLASH DRUM.

FEED CONSIDERED 6000 T/A B.H. CRUDE

# IMPROVING INTERNALS OF VACUUM TOWERS

- Use of packings instead of trays in vacuum towers gives lesser pressure drop, thereby reducing FZ temperature. Lower FZ temperature reduces heater duty and results in energy savings.

- A Case Study

1.7 MMtpa FPU's in wet vacuum operation

Particulars	MRP	GRSP
Tower Internals		
Pressure Drop, mmWg		
FZ Temperature, °C		
Saving on Heater Duty		
MMkcal/hr		
Annual saving US \$		
	Trays	Packings
	70	28
	380	363
		2.25
		0.35 x10 <sup>6</sup>

- Additional Bonus

- Reduced tendency for cracking
- Increased capacity

## CHANGES IN TECHNOLOGY / PROCESS VARIABLES

- USE OF DRY VACUUM TECHNOLOGY IN PLACE OF WET VACUUM
- USE OF LOWER S/F RATIOS IN EXTRACTION PROCESSES.
- USE OF MULTIPLE EFFECT EVAPORATION

## USE OF DRY VACUUM IN VACUUM DISTILLATION

- Application

Vacuum units for non-lube use

- A Case Study

A 1.29 MMTPAFPU at Vizag

Particulars	GRSP	VREP
Capacity MMTPA	1.675	1.29
Operation	Wet vacuum	Dry vacuum
Pressure at FZ, mmHg. 'a'	112	24
Coil+stripping steam, t/hr	21	NIL
Ejector Motive steam, t/hr	3	11.7 (9)
Net saving of steam, t/hr	—	12.3
Annual savings US \$	—	2 x 10 <sup>6</sup>


# EFFECT OF REDUCTION IN S F RATIO, ( FURFURAL EXTRACTION )

## OPERATING CONDITIONS:


	<u>DESIGN</u>	<u>REVAMP (PROPOSED)</u>
UNIT T'PUT MT/HR	37.3	59.5
S/F (V/V)	2.98	2.1
RAFFINATE YIELD (VOL%)	65.7	68.0
EXTRACTOR TEMP °C	130/90	129/79

<u>UTILITY CONSUMPTION</u>	<u>AVG. DESIGN</u>	<u>AVG. REVAMP</u>
COOLING WATER M <sup>3</sup> /bb1	5.51	2.5
FUEL FIRED Kg/bbl	5.55	3.48
MP STEAM Kg/bbl	8.96	2.64
LP STEAM Kg/bbl	0.24	6.24
POWER Kwh/bbl	1.78	1.03
TOTAL ENERGY EQUIVALENT MM CAL/bbl	65.85	36.9

# CO-GENERATION




COMPARE : T.P. \_\_\_\_\_





# WHAT IS FGRU



## **FLARE GAS RECOVERY**

### **• Objectives**

- Energy Saving
- Pollution Control

### **• A Case Study**

A large Petrochemical complex in India

Flare Gas Losses, t/hr      2

Flare gas recovery system recovers all these losses as fuel gas to be used in the complex

Equivalent Fuel oil saved      t/hr      2.8

4.5 x 10<sup>6</sup>

Annual savings US \$

Less than one year

Payout Period

## FUTURE OPTIONS

- USE OF TEMPERED WATER LOOP TO PREHEAT BFW
- INTEGRATION OF PROCESS UNITS & TPS
- SWITCHOVER TO ELECTRIC TRACING
- USE OF LOW PRESSURE INST AIR SYSTEM
- HIGHER COOLING WATER TEMP. RISE.
- ANTIFOULANTS FOR IMPROVED HX PERFORMANCE
- ADVANCED COMPUTER CONTROL
- FLARE GAS RECOVERY
- RECOVERY OF VAPOURS FROM TANK VENTS/LOADING GANTRIES.

**ENERGY CONSERVATION IN**  
**REFINERIES**

**MAX POTENTIAL IN**

- HEAT EXCHANGER TRAIN OPTIMISATION**
- EFFICIENCY IMPROVEMENT OF FURNACES  
& BOILERS.**

## FEED PREHEAT & RECYCLE HEAT IN EFFLUENTS

<u>YEAR</u>	<u>CRUDE TO HEATER</u>	<u>PRODUCTS TO COOLERS</u>
1960's	180-200°C	150-170°C
1970s	225-250°C	100-150°C
1980s	250-275°C	60-100°C
Current	275-300°C	50- 90°C

In a 3MM tonnes per annum refinery

Each 10°C crude preheat:—2.2MM kcal/hr absorbed

—2.5MM kcal/hr fired

—2000 TPA fuel

At US dollars 150/tonne—0.3 million dollars/year

# **SPECIFICATIONS FOR HEAT EXCHANGERS**

- 1 OPTIMIZE FLOW CONFIGURATION.**
- 2 MINIMIZE HEAT LOSS TO AIR/WATER INCLUDING HEAT INTEGRATION BETWEEN PROCESS UNITS.**
- 3 OPTIMIZE CLEANING CYCLES.**
- 4 USE OF EXTENDED/POROUS SURFACES.**



**ENGINEERS  
INDIA**  
NEW DELHI



# **~~SPECIFIC CONSERVATION MEASUREMENT~~**

## **AIR COOLERS**

- 1 USE OF AUTOMATIC VARIABLE PITCH FANS.
- 2 BETTER INLET AIR DISTRIBUTION.
- 3 USE OF TUBES WHICH MAINTAIN FIN CONTINUITY /  
THERMAL CONTACT.
- 4 MINIMIZE AIR RECIRCULATION.



**ENGINEERS  
INDIA**  
NEW DELHI

# SP. ENGINEERS INDIA

## REDUCE WASTE

- THRU CUTTING DOWN AIR LEAKAGES
- BETTER INSULATION (CERAMIC FIBRE FACING)
- BOILER BLOWDOWN CONTROL.
- BY CLEANER SURFACES THRU EFFECTIVE SOOT - BLOWING

## IMPROVE COMBUSTION EFFICIENCY

- THRU MORE EFFICIENT LOW EXCESS AIR BURNERS
- COMBUSTION CONTROL INSTRUMENTATION

## RECOVER HEAT IN FUEL GASES


- THRU AIR PREHEATER
- ADDITIONAL CONVECTION AREA
- INSTALL WASTE HEAT BOILER




ENGINEERS  
INDIA  
NEW DELHI





# HEATER EFFICIENCY





# SLIP-STREAM AIR PREHEAT SYSTEM





## **AIR-PREHEAT EFFECT ON FURNACE OPERATION**

### **— Pressure Profile**

- FD Fan for Air Ducts, APH & Burner
- ID Fan for Convection Section, Duct, APH & Stack

### **— Temperature Profile**

- Increased Flame Temp (Coil Supports)
- Increased Radiant Flux (Sensitive Stocks)

### **— Excess Air Reduction**

- Increased Emissivity ( $H_2O$ ,  $CO_2$ )
- Decreased Convection Section Duty.

## **RETROFIT CONSTRAINTS**

- 1 Process Parameters**
  - Superheater Performance**
- 2 Space Restrictions**
  - Safety/Maintenance**
  - Best Solution Not Possible**
- 3 Use of Recovered Energy**
  - Steam User**
- 4 Down Time Allowed**

## **CASE STUDY**

**CLIENT : BHARAT PETROLEUM CORPORATION LIMITED**

**CAPACITY : 6 MTPA Bombay high crude (1984)**

### **ENERGY CONSUMPTION :**

Existing Design : 2.64% Wt . of crude  
With modifications : 2.21% Wt . of crude  
Savings/year : 25,800 tons of crude

<b><u>PROPOSED MODIFICATIONS :</u></b>	<b>CAPITAL INVESTMENT</b>	<b>Annual Savings</b>
	<b><u>In million Rupees</u></b>	
1. New heat exchangers	4.8	11.4
2. Air pre-heaters for C.D.U. heaters	21.0	41.6
3. Air pre-heaters for Boilers	6.0	2.1
4. Replacing FPU heater	30.0	21.9
5. <u>CO boiler x 1.2 MW turbine</u>	20.0	15.9

\* Includes basic equipment & components cost only.

**CASE STUDY**  
**HEAT EXCHANGERS**

**CLIENT : BHARAT PETROLEUM CORPORATION LIMITED, BOMBAY**

**ALTERNATIVES**

(Present Crude Pre-Heat Temp-188°C)

**1 IDEAL CASE-REDESIGN TRAIN**

Preheat temp. could be increased to 232°C  
however not practical due to space constraints

**2 REPLACING WITH LONG-TUBE EXCHANGERS**

Present exchangers have 4.8<sup>m</sup> long tubes.  
increasing length to 6<sup>m</sup> increases area by 25%  
and crude terminal temp. can be 204°C. Existing  
bundles when requiring replacement could be  
replaced with longer tube bundles since space is  
available

**3 OPTIMIZATION WITH ECONOMICAL CHANGES**

Relocating some of the existing heat exchangers,  
addition of 4 new exchangers with piping  
modifications can increase pre-heat to 200°C,  
recovering 4.75x10<sup>6</sup> kcal/hr. Studies also revealed  
that pressure drops in some heat exchangers  
could be reduced with slight modifications



## CASE STUDY

### C.D.U. HEATERS

CLIENT : BHARAT PETROLEUM CORP. LTD.

EXISTING		HEATER-B1	HEATER-B2
	Type	Box-Type	Forced Draft
	Duty-10 <sup>6</sup> kcal/hr	39.0	41.7
	Fuel	LSHS/S.R./GAS	
	Excess Air-%	45	45
	Efficiency- %	69.7	68.0
	Flue exit Temp. °C.	500	545
ADDITIONS	<u>AIR PREHEATER WITH</u>		
	<u>EXTERNAL CONVECTION SECTION</u>		
	Duty 10 <sup>6</sup> kcal/hr	4.83+1.0	5.16+2.1
	Flue Temp. in/out°C	500/204	545/204
	Air Temp. in/out°C	30/325	30/325
	F.D. Fan Power kW	70	85
NEW	I.D. Fan Power kW	120	140
	Excess Air %	10	10
	Efficiency %	89	89
<u>SAVINGS FUEL OIL TPA</u>		<u>9709</u>	<u>11574</u>

## CASE STUDY

### FPU HEATER B-I

CLIENT : BHARAT PETROLEUM CORPORATION LIMITED

**EXISTING**

Type	Box-type forced Draft
Duty	$19.4 \times 10^6$ kcal/hr.
Fuel	LSHS/S.R./Gas
Excess Air	150%
Efficiency	65.2%
Flue exit temp.	450°C

**NEW**

<u>Heater</u>	
Duty	$27.2 \times 10^6$ kcal/hr.
Excess Air	10%
Efficiency	90%
<u>Air-Preheater</u>	
Duty	$2.4 \times 10^6$ kcal/hr.
Flue temp. in/out	450/204°C
Air temp. in/out	30/325°C

**SAVINGS FUEL OIL 6559 TPA**

**CASE STUDY**  
**BOILER**  
**CLIENT : BHARAT PETROLEUM CORP. LTD.**

<b>EXISTING</b>	Duty	10 <sup>6</sup> kcal/hr.	16.7
	Fuel		L.S.H.S./S.R./Gas
	Excess Air	%	60
	Efficiency	%	80.4
	Flue exit temp.	C	310
<b>ADDITIONS</b>	<b><u>AIR PRE HEATER</u></b>		
	Duty	10 <sup>6</sup> kcal/hr	1.29
	Flue Temp. in/out	C	310/204
	Air Temp. in/out	C	30/153
	<b><u>F.D. FAN</u></b>	Power	kW
	<b><u>I.D. FAN</u></b>	Power	kW
<b>NEW</b>	Excess air	%	60
	Efficiency	%	85

**SAVINGS FUEL OIL TPA**

**1028**

## CASE STUDY

### CO BOILER + TG SET

CLIENT : BHARAT PETROLEUM CORPORATION LTD.

#### EXISTING BOILER

Steam	12.5 TPH
Pressure	21 BAR
Flue inlet temp.	620°C

#### CO BOILER

#### NEW SYSTEM

Steam	24.0 TPH
Pressure/Temp.	50 BAR/400°C
Flue temp. in/out	940/250°C
Fuel oil fired	160 kg/hr


#### TURBOGENERATOR

Power	1.2 MW
Back Pressure	16 BAR

#### SAVINGS

Additional steam	92000 TPA
Power	9.5x10 <sup>6</sup> kWh
Fuel oil Fired	(1280 TPA)

# CO. BOILER



- 1.0 Energy is basic to production and its efficient use to productivity. Its scarcity limits growth. Economic use of energy is vital for sustaining the very tempo of development.

Slide 1 shows price escalation index from RBI bulletin Jan. 86. This shows that Energy costs are rising much faster than prices of other goods/commodities and this pattern will continue in this country for atleast next twenty years. Power shortages and cuts will also continue. It has been estimated that while it costs Rs.1.25 crores per MW to create additional generation capacity, it costs Rs.30 to 40 lakhs to adopt Energy Conservation measures to save 1 MW power. Economically therefore Energy Conservation measures need more attention.

Slide 2 shows the increase in price index of selected essential commodities. Price index of coal and electricity is higher than other commodities.

- 2.0 Pulp and Paper Industry is one of the largest consumer of energy. Energy costs constitute nearly 20-24% of production cost in India against 12-14% in advanced countries.

Table 1 shows how energy costs at Ballarpur and Jagadhri have been rising:

TABLE 1 : Energy Costs/Ton of Paper

	<u>79-80</u>	<u>80-81</u>	<u>81-82</u>	<u>82-83</u>	<u>83-84</u>	<u>84-85</u>	<u>85-86</u>
Ballarpur	672	837	1218	1296	1623	1677	1683
Shree Gopal	1151	1272	1091	1357	1764	1931	2192

The increasing cost of energy should therefore become a concern of every body.

Table 2 below shows how the purchased energy at Ballarpur and Jagadhri have been controlled by various energy conservation measures. (These fig. include about 0.15 M K Cal/ton of Energy on effluent treatment).

TABLE 2 : Purchased Energy MKcal/Ton of Paper

	<u>1-82</u>	<u>82-83</u>	<u>83-84</u>	<u>84-85</u>	<u>85-86</u>	<u>Jul-Aug 86</u>
Ballarpur	13.7	12.8	13.45	12.7	10.82	10.60
Shree Gopal	-	12.72	13.22	12.46	12.75	12.34

3.0 All over the world Paper Industry has made outstanding achievements in Energy Productivity. Published figures of American Pulp & Paper Industry show following achievements.

TABLE 3 : Energy figures of American Industry

Purchased	1983 %	1972 %	Self Generated	1983 %	1972 %
Purchased electricity	6.4	4.4	Wood residues	9.8	2.0
Coal	13.9	10.6	Bark	5.5	4.5
Residual fuel oil	9.4	21.2	Spent pulping liquors	38.1	33.4
Distillate fuel oil	0.3	1.1	Hydro electricity	0.5	0.4
Gas	14.6	20.9			
Other	1.0	1.3	Other	0.5	0.5
TOTAL	45.6	59.5	TOTAL	54.4	40.5

This shows:

- Increased use of self generated and residue sources of energy from 40.5%, an increase of 34.6%.
- Reduced oil consumption by 55%.
- Reduced total consumption of fossil fuel and purchased energy by 23%.

4.0 We started off with a check list of American Pulp & Paper Institute and Canadian Pulp & Paper Institute. Annexure 'A' lists various energy conservation ideas.

5.0 Some of the case studies of Energy Conservation measures at Ballarpur Industries Limited are given below.

### 5.1 Energy Requirement in Digester

An energy balance was done on Voith Digester to check on the actual steam consumption versus theoretical steam consumption. The steam consumption was 2.6 MT/Ton of Pulp when this study had started. Table 5.1 shows that we require 2.40 MT per ton of pulp at a bath ratio of 3.8 and 2.22 MT per ton of pulp at a bath ratio of 3.5. These calculations further led to analysis of other areas where energy was not utilised efficiently.

These areas were:

- (a) Proper maintenance of air vent valves.
- (b) Avoiding use of superheated steam as it resulted in poor heat transfer coefficient.
- (c) Change of chip packing method to increase capacity per batch.
- (d) Improved insulation of digester, pipelines etc.

All these measures particularly increased chip packing reduced steam consumption to 2.0 T/ton of pulp resulting in saving of Rs.32.0 lakhs/annum.

### 5.2 Optimization of blow heat recovery and other operations in Pul- Mill

During the blow of digester, sudden decrease in the temperature releases steam which could be recovered and used for heating the water for brown stock washing.

Total weight of Black liquor = Black liquor from 1st stage  
+ black liquor in 2nd stage  
+ white liquor + Injected  
black liquor + chips water  
lignin

= 76.10 tonnes

Weight of Pulp

= 7.75 tonnes

Heat available from:

(a) Pulp = .15 MK Cal

(b) Black liquor = 4.0 MK Cal

(c) Digester Shell = .20 MK Cal

Latent heat of vapour at 100°C and 1 atm pressure

= .539 M Cal/tonne

∴ Steam available per blow =  $\frac{4.35}{.539}$

= 8.1 tonne steam



TABLE 5.1 : VOITH DIGESTER-STEAM/COOK

	Heat input/Cook in present operations	Heat input/Cook with reduced bath ratio and increased B/L & W/L Temp.
1. Bath Ratio	3.8	3.5
2. White liquor temp	82°C	85°C
3. Black liquor	75°C	78°C
4. Steam during blow	1000 kg	800 kg
	K.Cal	K.Cal
1. Chips Heating	7,36,032	7,36,032
2. Moisture	5,30,400	5,30,400
3. Black Liquor B/L 1st stage	19,26,925	18,21,820
4. Remaining B/L 1st Stage	3,60,360	3,60,360
5. White liquor 2nd stage	29,42,940	28,41,459
6. Black liquor 2nd stage	7,28,728	3,52,352
7. Digester shell	1,22,148	1,22,148
8. Insulation	10,000	10,000
9. Radiation Losses	1,10,363	1,10,363
10. Relief	5,00,000	5,00,000
11. Unaccounted for	2,20,750	2,20,750
12. Total	81,88,646	76,05,664
13. Steam/cook	16,884 kgs	15,633
14. Steam for blowing	1,000	800
15. Total steam/Cook	17,884 kgs	16,482
16. Steam/T Pulp	2.4 MT	2.22 MT

In addition to this 1 tonne of steam is used for blowing the cook.

Steps taken to improve blow heat:

- (a) Modification in blow tank to avoid carry over of fibres.
- (b) Regular cleaning of trays.
- (c) Maintaining circulating condensor water temperature.
- (d) Ensuring requisite capacity of circulating water pump.

Heat released during each blow = 5.46 MK Cal/Cook  
or 5.00 MK Cal/hr

Heat requirement for heating the water from 30°C to 65°C for brown stock washing plant.

Earlier only 2 MK Cal/hr was recovered. With the above stated steps we have been able to avoid the steam usage for brown stock washer.

This means a saving of Rs.320/- per hour, or a saving of Rs.25 lakh per annum.

### 5.3 Steam requirement on PM 6

The average production is based on 1.8 tonnes per hour.

% Moisture input to dryer = 62%  
% Moisture at Pope reel = 3%  
B.D. paper = 1.746 tonnes/hr.

Total quantity of water + fibre entering = 4.595 tonnes/hr.

Quantity of water entering = 2.849 tonnes/hr.

Quantity of water evaporated = 2.795 tonnes/hr.

(1) Heat with incoming paper

$$= 1746 \times .33 \times 35 + 2,849 \times 1 \times 35$$

$$= 133893 \text{ KCal/hr.}$$

(2) Heat with outgoing paper

$$= 1746 \times .33 \times 65 + 54 \times 1 \times 65$$

$$= 40962 \text{ K Cal/hr.}$$

(3) Heat required for evaporation

$$= 2795 \text{ kg/hr} \times 550$$

$$= 1537250 \text{ K Cal.}$$

(4) Heat with incoming air

$$= 3 \times 4200 \times 1.293 \times .242 \times 35$$

$$= 137992 \text{ K Cal/hr.}$$

(5) Heat with outgoing air

$$= 3 \times 4200 \times 1.293 \times .242 \times 70$$

$$= 275984 \text{ K Cal/hr.}$$

Heat Loss due to radiation and convection

There are 17 paper driers and 4 felt dryers on machine No.6. For a surface temperature of  $100^{\circ}\text{C}$ , it is estimated that:

$$\text{Radiation losses} = 505 \text{ KCal/M}^2/\text{hr}$$

$$\text{Convection losses} = 320 \text{ KCal/M}^2/\text{hr}$$

$$\therefore \text{Total losses} = 1,65,000 \text{ KCal/hr}$$

$$\text{Total heat required} = 1747311 \text{ KCal/hr}$$

$$\text{Steam required} = \frac{1747311}{521} = 3354 \text{ ton of steam}$$

If size press is working then approximately 0.30 ton of water is added per ton of paper which has to be evaporated.

$$\therefore \text{Total steam required} = 3894 \text{ ton of steam per hour.}$$

$$\text{Steam consumption per ton of paper} = 2.16 \text{ ton/ton of paper.}$$

In dandy we require approximately 0.5 ton/ton of paper on Machine No.6.

$$\therefore \text{Total theoretical steam consumption} = 2.66 \text{ ton/ton of paper.}$$

The moving average of steam consumption of Machine No.6 was 4.21 ton/ton of paper in the month of May 1985, which was reduced to a moving average of 3.15 ton of steam/ton of paper by taking various measures.

On Paper Machine No.6 there was a provision of using flash steam only in first 3 dryers. After closing the condensate vent valve the pressure in the tank was rising as high as  $0.6 \text{ kg/cm}^2$  gauge. There was a tendency of opening live and flash steam simultaneously in the same dryer as a result live steam was rushing into condensate tank. This resulted in flash and some live steam to get vented. Even after shutting live steam valve there was a residual pressure in condensate tank in the range of 0.2 to  $0.4 \text{ kg/cm}^2$ . Subsequently a flash steam connection was provided to additional dryer No.4. This gave full utilization of flash steam in the range of 280 to 300 kg/hr.

#### 5.4 Boiler Efficiency

Most of coal fired boilers in India are operating at low efficiencies and quite often no attempt is made by operating depth to determine as to where the losses are occurring. Provision of additional facilities like ultimate analysis of coal, Orsat apparatus, use of portable flue gas analyser, Bomb Calorimeter are absolutely essential. Insistence on periodic efficiency monitoring can bring about significant improvement.

Provision of O<sub>2</sub>/CO Online analysers can help efficiency improvement of 1-3%. Use of microprocessor combustion controls can further reduce losses by 1-1½%.

By scrapping old chain grate stoker/stationary grate boilers with spreader stoker boilers, we have improved coal to steam ratio considerably and achieved saving of Rs.42 lakhs annually but our boiler efficiency continues to be still low i.e. 66-70% as against our target of 72%.

An improvement of efficiency by 4% would give us saving of Rs.30 lakhs/yr at Ballarpur Unit. The measures in hand are:

1. Periodic efficiency testing.
2. Microprocessor controls on boilers.
3. Installation of oxygen analyser and use of portable flue gas analyser to determine air leakages.
4. Controlling air distribution to grate particularly at low loads.
5. Use of hydraulic cleaning of boiler tubes to improve heat transfer.
6. Reduce losses due to blow down etc.

#### 5.5 Pumps

The pumps alone consume about 40 to 50% of the total energy consumed per tonne of paper. In most cases it has been found that pumps are oversized and design characteristics do not match system characteristics. A review of pump sizing can lead to significant savings. As a first step one can instal pressure gauges and determine pump differential head (actual) v/s design. This can itself give lot of clues.

**Case Study:****(1) Mill water pumping from pump house**

In Pump House the main distribution header pressure was maintained at  $3.2 \text{ kg/cm}^2$  so that sufficient water is available to all section of mills including pulp mill having highest operating floor connected to this header. This was as per recommendation of M/s. Voith and accordingly pumps were selected to operate at duty point 'A' as shown in the curve.

Later on after some years a separate pump was installed having a total head of 40 M to cater to only Pulp Mill requirement and the header pressure was brought down from  $3.2 \text{ kg/cm}^2$  to  $1.8$  to  $2.0 \text{ kg/cm}^2$  so that sufficient water is available for all the balance sections.

A detailed study was conducted by Unit Technocrates and Energy Conservation Cell on Mill Pump House which revealed that the pumps were working a total head of 25 M only as shown in the curve "Point B" and in this region the pump efficiency and power consumption cannot be predicted.

The total water consumption at this pressure were calculated and accordingly a pump was installed in the Pump House having an efficiency of 84 to 86%. The results are as follows:

<u>No. of pumps running earlier</u>	<u>Running load</u>	<u>No. of pumps running now</u>	<u>Running load</u>
2 Nos. big pumps (10 UP 3)	210 Amp. each	1 No. Big Pump (16 UPHI)	270 Amp.
1 No. small pump (6/8" medivane)	60 Amp.		
	<u>480 Amp.</u>		<u>270 Amp.</u>

$$\text{Saving in power} = \frac{1.73 \times 210 \times 420 \times 0.85}{1000}$$

$$= 129.7 \text{ KWH}$$

$$\text{Or Saving in Rs. per annum} = \frac{129.7 \times 24 \times 330 \times 0.72}{100}$$


$$= 7,39,600$$

Say Rs.7.4 lakhs

# PERFORMANCE CURVES OF PUMP TYPE

Case

(1)



A - DESIGN OPERATING POINT.

B - ACTUAL OPERATING POINT

**(11) Pul. Mill and Machine House Pumps**

A survey was carried out to locate inefficient pump in the above plants. The capacity of the pumps were established after doing the mass balance of these specification and pressure were noted down. It was observed that there would be a saving of around 40 Unit/Ton of paper by replacing around 32 nos. pumps and motors in these sections i.e. against an investment of around Rs.20.0 lakhs. The saving will be around Rs.25 lakhs. Has a pay back period of less than a year.

**6.0 Constraints in Energy Conservation Efforts****6.1 Technological Developments:**

There are a number of untried but very promising technologies available for reducing energy consumption. Among the barriers to innovation in Energy Technology are:

- the risks associated with adoption of new techniques and new applications of existing technologies, particularly when they are not central to the production process.
- Lack of authentic information, reliability and economics of new equipment and processes.
- Weakness of Industry which manufactures and supplies conservation equipment and systems.

Aim of Energy Conservation Demonstration Scheme as operated in U.K. is to accelerate adoption of new or improved energy use technology by overcoming these barriers. The Scheme

- provides grants to offset risks associated with novel projects. In return, companies must allow their projects to be monitored or reported on by independent consultants.
- Disseminates independent technical and economical information about projects to other potential users.
- Provides marketing and technical back up to energy conservation equipment supply industry.

## **6.2 Modernization of Plants**

There are lot of equipments which have been used world over but are not yet available in India and also testing equipments which can lead to significant energy savings. Imposition of 30% import duties cannot but discourage use of such equipments. A typical list (but not exhaustive) is given below:

- Ultrasonic flow meters
- Portable flue gas analysers
- Oxygen/CO analyser
- Online drainage tester
- Moisture measurement
- Digestor weighing systems
- Online analysers
- Reliable steam flow meters, annubars etc.
- Pressure gauges for slurry, pulp etc.
- Conductivity analysers
- Ultrasonic trap survey instruments
- Smelt bed temp. measurement
- Instruments for paper formation studies
- High consistency pulp pumps
- Low pressure drop centricleaners
- Oscillating showers and shower nozzles
- Ceramic foils and covers
- Efficient vacuum pumps
- Falling film evaporators
- Felts and wires

## **6.3 Proper Energy Management Approach**

Another barrier in Energy Conservation efforts is lack of proper energy management approach. Following characteristics are required for effective energy managements approach:

- An awareness throughout all the ranks that Mill Manager cares about energy.
- Develop aggressive policies and programmes.
- Formation of an energy committee composed of right people.



- Conduct meetings regularly.
- Have a proper energy reporting system.
- Accountability at the lowest possible level with available measurement.

It is essential that each Unit has an Energy Manager (not connected with day to day operations) to co-ordinate all activities related to Energy.

#### 6.4 Government Incentives

At present Government does not have many incentives for energy conservation projects. The following forms of Govt. support are required at national level:

- Provision of taxes and other incentives as well as soft financing for energy efficient equipments.
- Reduction/exemption of import duties.
- Discourage energywise inefficient units.
- Advisory bodies to assist and guide the industry to adopt energy saving technologies.
- Ensure sustained and reliable power supply.
- Second-hand equipment imports to be encouraged only if they are energy efficient.
- Proper training in the field of energy conservation.

#### 6.5 Management Support

Management support is an essential requirements for energy conservation programme. The management must provide following for energy conservation:

- Enough funds for energy conservation projects.
- Manpower for Energy Conservation.
- Acceptance of new technologies.
- Develop Research and Development Department.

## CHECK LIST OF ENERGY SAVING IDEAS

### Woodroom, Woodyard, Hog Fuel Preparation

- Use waste process hot water in woodrooms to reduce steam requirements.
- Improve bark burning efficiency by improving pressing of wet bark prior to firing.
- Use chipped forest refuse (birch, aspen, etc.) and peat as fuel, reducing oil use.
- Maximize bark burning by changing operational routine of wood room.
- Recover wood and bark fines for fuel.
- Install bark dryer.
- Improve hog fuel handling to improve boiler efficiency and eliminate frequent downtime which requires fossil fuel make-up (ECO WHP 1).
- Replace pneumatic conveyors with belts.

9

### Mechanical Pulping and Bleaching

- Reduce fresh water consumption on showers in pulping and bleaching areas.
- Recover waste heat from grinders and refiner exhausts.
- Replace fresh water showers or dilution with white water.
- Automatic freeness control (ECO GW 2).

### Chemical Pulping, Washing and Screening

#### Digesters

- Optimize target KAPPA number.
- Raise sulphidity to reduce lime demand and hence kiln fuel (ECO KP 23).
- Insulation on Kaur digester (ECO KP 27).
- Install chip packers in batch digester.
- Use two level steaming in batch digester.
- Computer control to level steam loads and increase boiler efficiency (ECO KP12 & KP17 & KP25).

#### Brownstock Washing

- Improve recovery of waste liquor for firing in chemical recovery units.
- Reduce fresh water consumption on showers in bleaching, pulping, and paper making areas.
- Control wash water flow in accordance with production rate and evaporator load.
- Improve brown stock washing to reduce evaporation load.
- Replace steam doctors on washers with air doctors.
- Replace fresh water showers on knotters with liquor to reduce evaporator load (ECO Pulp 1).
- Select hottest feasible evaporator condensate for brownstock washing (ECO KP 1).
- Heat washer shower water by heat exchange with bleach caustic extract.
- Use waste warm water for unbleached decker seal tank make-up (ECO KP 8).

#### Screening

- Heat Brownstock decker water with waste heat to warm bleach plant input stock.
- Eliminate unnecessary screens (ECO KP 9).
- Shut down some screens when production is low.

#### Chemical Pulp Bleaching

- Recycle warm filtrates in bleach plant.
- Reduce fresh water consumption on showers in bleaching, pulping and paper making areas.
- Eliminate fresh water use in washer ring brackets (ECO KP 4).
- Replace fresh water with white water in bleach decker hydraulic doctor (ECO KP 5).
- Replace fresh water with waste warm water for caustic dilution (ECO KP 15).
- Replace trash removal screens with large diameter cleaner (ECO KP 16).
- Heat shower water by exchange with contaminated condensate (ECO CON 5).

#### Chemical Recovery and Evaporators

##### Evaporators

- Recover evaporator flash steam.
- Modify evaporator for better economy.
- Improve brown stock washing to reduce evaporation load.
- Install pre-evaporation unit on liquor evaporator system using waste heat.
- Use automatic density control to optimize evaporator operation.
- Install new ejectors or replace them with vacuum pump.
- Install stand-by liquor storage in earthen basin to retain temporary overloads of weak liquor (ECO Sulp 2).
- Transfer as much as possible of the evaporation load from concentrator to more efficient multiple effect evaporators by acid cleaning latter (ECO KP 22).

##### Recovery Boiler

- Improve soot blowing system on recovery boilers to minimize steam usage.
- Improve smelt tank heat recovery system.
- Use compressed air instead of steam for smelt shatter jet.
- Heat feed water make-up with recovery boiler scrubber effluent (ECO SP 19).
- Use speed control rather than damper control for fans.
- Improve recovery boiler operation to eliminate oil firing (ECO SP 1).

## LINE KILN

- Improve efficiency of lime kiln
- Insulation to be checked to minimise losses
- Possibility of recycling flue gases to utilise volatile from coal

## Paper Machine and Pulp Drying

### Wet End

- Replace suction presses with grooved presses and reduce vacuum requirements (ECO PM 8 & 20).
- Increase press loading on paper machines to reduce drying requirements (ECO PM 11).
- Lower felt moisture by additional vacuum (ECO PM 19).
- Reduce fresh water consumption on showers (ECO GEN 3).
- Close up paper machine white water systems with objective of eliminating wire pit steam (ECO PM 3, PM 5 & KP 14).
- Improve vacuum systems on paper machine couch rolls to reduce dryer loadings.
- Replace steam ejector by vacuum pump on deculator.
- Upgrade felt conditioning on paper machine.
- Eliminate felt conditioning (ECO PM 22).
- Eliminate felt dryers (ECO PM 4).
- Replace ventanip roll with stainless "C" roll (ECO PM 1).
- Replace heated fresh water with white water for cleaner reject sluicing (ECO KP 13).
- ✓ - Install steam shower to improve pressing (ECO PM 23).

### Dryer

- ✓ - Reduce pocket ventilation temperature (ECO PM 21).
- ✓ - Reduce pressure in paper dryers to increase steam flow through turbogenerator (ECO SP 17).
- Recover and reuse paper machine press water.
- ✓ - Reduce paper machine dryer drive loads by improving condensate removal.
- Install thermo-compressors on dryer steam systems (ECO PM 7 & CON 4).
- ✓ - Improve capability of paper machine moisture control systems.
- ✓ - Replace condensers with direct cooling by treated

boiler feed water make-up (ECO PM 15).

- ✓ - Install dual syphons in dryer cans to improve condensate removal (ECO PM 12).
- ✓ - Employ computer controls on paper machines for basis weight and dryer controls to minimise over-drying.

### Air System

- ✓ - Upgrade paper machine enclosed hoods.
- ✓ - Upgrade heat recovery capability of waste heat economisers on paper machine and pulp machine dryers.
- Reduce pressure differential across FLAKT dryer (ECO KP 19).
- ✓ - Limit air exhaust on open dryer hood in winter (ECO PM 9).

### Miscellaneous

- ✓ - Replace cold water intakes to warm water systems with used cooling water (ECO PM 16).
- ✓ - Seal hotwell overflow to reduce loss of flash steam (ECO SP 22).

## Steam Plant and Turbines (except recovery boiler)

### Boiler

- Install new bark fired boilers.
- ✓ - Install new boiler controls, gas analyzers, and other devices to improve boiler efficiency.
- ✓ - Install boiler blowdown heat recovery units.
- Convert oil fired power boilers to allow partial or full hog fuel firing.
- Burn waste oil as fuel.
- Improve oil burner operation and maintenance and design to increase efficiency.
- Upgrade atomizing steam or oil fired boiler.
- Reduce burner atomizing steam pressure (ECO SP 9).
- Replace defective tubes in combustion air heater (ECO SP 5 & 30).
- Improve gas/oil burners (ECO SP 6 & SP 24).
- Improve undergrate air distribution in hog fuel boiler (ECO SP 10).
- ✓ - Use warm air from top floor of building as supply for FD fan (ECO SP 11 & SP 20).
- Improve reliability of auxiliary fuel ignitors in hog fuel boiler to avoid the need to maintain one gun in operation to protect against loss of fire (ECO SP 14).
- Replace steam spreaders with mechanical spreaders in hog fuel boiler (ECO SP 15).

### Turbine

- ✓ - Install back pressure turbines for either electric generation or direct mechanical drives.
- ✓ - Transfer steam from low efficiency local turbine to central turbo-generator by replacing local turbine with electric motor (ECO SP 27 & 32).
- ✓ - Convert medium pressure steam consumers to lower pressure for increased electrical generation.

## CHECK LIST OF ENERGY SAVING IDEAS (con't)

### Feedwater

- Upgrade and rehabilitate boiler feed water heating systems.
- Install water softeners for boiler feed water to reduce blowdown.
- Preheat boiler feedwater with mill effluents.
- Heat boiler feedwater by using it as compressor cooling (ECO SP 31).
- Preheat boiler feedwater with flash steam from condensate collecting tank (ECO SP 23).
- Heat boiler feed water with flue gas and paper machine hood vent.
- Use warm water from the evaporator surface condenser to supply the boiler feedwater treatment system (ECO SP 3).
- Recover hot water from seal gland exhausters in turbines (ECO SP 6).
- Divert deaerator vent from atmosphere to feedwater heater (ECO SP 7).
- Install economisers to heat feedwater in a high temperature stack (ECO SP 13).
- Minimise recirculation at feedwater pumps (ECO SP 29).

### Miscellaneous

- ✓-Reduce service water pressure (ECO SP 2).
- ✓-Eliminate leakage from HP steam header to LP header (ECO SP 4).
- Insulate bunker C storage tank (ECO SP 21).
- ✓-Monitor and check condensate return rates to detect losses (ECO CON 1).

### Mill-Wide Process Heat

- ✓-Pressurise condensate recovery systems to avoid unnecessary cooling for pumping purposes (ECO CON 8).
- ✓-Scheduled maintenance of steam traps (ECO CON 3 & 6).
- ✓-Upgrade steam line and process equipment insulation systems (ECO GW1).
- Upgrade steam condensate recovery systems.
- ✓-Reclaim transformer cooling water.
- Reclaim compressor cooling water (ECO SP 25).
- ✓-Increase use of warm surplus white water for stock dilution system.
- Replace, upgrade or improve maintenance of heat exchanger units.
- ✓-Increase heat recovery from exhaust gaseous streams.
- Use waste process hot water in woodrooms to reduce steam requirements.
- Recover waste heat from grinder and refiner exhausts.
- Replace or repair leaking fresh water valves.
- ✓-Reduce direct steam heating.
- ✓-Install steam meters.
- Install water meters.
- Install mechanical seals on liquor pumps.
- ✓-Heat all stock and white water pump seal water with waste heat (some of it cools the process).

### Mill-Wide Heating and Ventilating

- Heat building make-up air with exhaust heat using glycol intermediary to avoid freezing in very cold weather (ECO PM 10).
- Reduce paper mill building ventilation exhaust heat losses, commensurate with humidity limitations, during colder weather.
- Use paper mill exhaust air to heat boiler room supply air.
- Reduce heating in storage areas not normally staffed.
- Change sheave sizes on exhaust fans, winter vs. summer conditions.
- Insulate buildings. This is almost always economically attractive unless building is heated by unrecoverable waste process heat. An example is described in ECO PM 14. Most mill buildings are inadequately insulated relative to to-day's energy costs.
- Use infra red viewer to locate heat losses (ECO GEN 1).
- Minimise make-up air (ECO PM 18).
- Energy audit of steam and condensate losses (ECO GEN 5).
- Minimise heat losses through building openings such as windows and doors.

### Mill-Wide Electrical

#### Lighting

- ✓-Replace incandescent lighting fixtures with more efficient fluorescent sodium or mercury vapour units and use skylights and windows where possible, especially in storage areas (ECO ELEC 5 & 7).
- Automate outside area lighting (ECO ELEC 1).

#### Power

- ✓-Shut down unnecessary agitators (ECO ELEC 3 & 4 and PM 17).
- Modify utilisation and selection practices of process equipment such as pumps, fans etc. to ensure optimum operating efficiency.
- ✓-Reduce compressed air use.
- Use variable speed drives to control pump discharge flow or pressure.
- Upgrade hydraulic turbines.
- Install automatic peak demand control on grinders.
- Review electric and gas contracts to optimize energy use.
- Study inter-relationship of cogeneration, steam and fuel to optimize energy consumption.
- Install peak load controllers (see ECO ELEC 6) for one application).
- ✓-Install capacitors for power factor correction.
- ✓-Modify electric motor selection standards to ensure operation at optimal efficiency.
- Convert continuously running pumps to automatically controlled intermittent operation where feasible (This is most commonly useful on cooling water pumps, examples are described in ECO PM 13 & GEN 4).



# INTRODUCTION

# STEEL INDUSTRY HIGHLY ENERGY INTENSIVE

- HIGH TEMPERATURE PROCESSES
- BATCH TYPE RATHER THAN CONTINUOUS

## SPECIFIC ENERGY CONSUMPTION

- INDIAN STEEL WORKS 9-16 G. cal/t steel
- ADVANCED COUNTRIES 4-7 G. cal / t steel  
LIKE JAPAN

# ENERGY INPUTS TO STEEL PLANTS

- COKING COALS
- STEAM COALS
- PETROLEUM FUELS
- PURCHASED ELECTRICITY

ABOUT 80-90% OF ENERGY INPUT  
THROUGH COKING COALS





FIG. 5

COMPARISON OF ENERGY DATA



# CONCLUSIONS FROM ENERGY DATA

- SPECIFIC LEVEL OF ENERGY CONSUMPTION IN INDIAN STEEL PLANTS HIGH ( NEARLY DOUBLE )
- CONSUMPTION OF ENERGY IN IRON ZONE NEARLY 70% FOR INDIAN AND FOREIGN PLANTS
- FUEL UTILISATION EFFICIENCY IN FURNACES POOR

# PRIORITY AREAS FOR ENERGY CONSERVATION

- REDUCTION OF COKE RATE
- EFFICIENT FUEL UTILISATION
- INTRODUCTION OF WASTE HEAT RECOVERY SYSTEMS

## IRON MAKING

PARAMETER	UNIT	INDIA	ABROAD
COKE RATE	kg/thm	750 – 1150	450 – 500
COKE ASH	%	25–29	8–10
M <sub>10</sub>		11–18	
% SINTER		0–65	80–95
RAW STONE	kg/thm	350–550	5–10
BLAST TEMPERATURE	°C	600–1000	1100–1350
TOP PRESSURE	Atmg	1.4–1.5 (ONLY BSL)	2.5–3.5
STABILITY OF OPERATION		UNSTABLE	STABLE




FIG 7

## IMPORTANT PARAMETERS IN BLAST FURNACES



# STEEL MAKING

- HIGH RATIO OF O.H. OXYGEN STEELMAKING – 55 %
- HIGH SPECIFIC FUEL CONSUMPTION
- CONVENTIONAL INGOT CASTING ROUTE

# ROLLING MILLS

- OBSOLETE COMBUSTION SYSTEMS IN FURNACES
- HIGH HEAT LOSSES THROUGH COOLING WATER (SKID)
- HIGH HEAT LOSSES THROUGH REFRACTORIES
- UNSTABLE MILL OPERATION
- HIGH TRACK TIME

# **ENERGY CONSERVATION MEASURES**

- OPERATIONAL IMPROVEMENTS**
- EQUIPMENT IMPROVEMENT**
- MODERNISATION MEASURES**

# OPERATIONAL IMPROVEMENT

- GOOD HOUSEKEEPING
- OPTIMUM NUMBER OF FURNACES
- HARDLY ANY CAPITAL INVESTMENT
- CONTINUOUS FOLLOW UP



# **EQUIPMENT IMPROVEMENT**

## **MARGINAL INVESTMENT GOOD RETURN**

- INSULATION OF COLD BLAST MAIN**
- MINIMISING LEAKAGE OF HOT  
BLAST**
- IMPROVED COMBUSTION SYSTEMS**
- CERAMIC FIBRE INSULATION**
- SKID MODIFICATION IN REHEATING  
FURNACES**

# MODERNISATION MEASURES

## CAPITAL INTENSIVE

- STAMP CHARGING
- SINTER PLANT MODERNISATION
- INTENSIFICATION OF BLAST FURNACES
- REPLACEMENT OF O. H.
- ADOPTION OF CONTINUOUS CASTING
- MODERNISATION OF MILLS
- WASTE HEAT RECOVERY SYSTEMS

# **ENERGY CONSERVATION EFFORTS** **OF SAIL**

- LIME DUST INJECTION**
- HIGH BASICITY SINTERING**
- EXTENDED HOOD IN SINTERING**
- COLD BONDED PELLETS**
- EXTERNAL DESILICONISATION AND DESULPHURISATION**
- OPTIMUM THERMAL AND OXYGEN LANCING REGIME IN O.H.**
- OXYGEN ENRICHMENT OF COMBUSTION AIR**
- CERAMIC FIBRE IN SOAKING PITS**
- MODIFIED COMBUSTION SYSTEM IN REHEATING FURNACES AT IISCO**

# Energy Scene—Constraints, Concept and Conservation

S.K. Gupta

Director

Research and Development Center for Iron and Steel

G. Mukherjee

Vice-Chairman (Technical) Steel Authority of India Limited

Round Table on Steel Industry for the Next Decade  
February 18-19, 1985, Vigyan Bhavan, New Delhi



## 1. Introduction

Steel industry being highly energy intensive is and will continue to be one of the major consumers of energy. This is mainly due to the fact that the various steelmaking processes are performed at high temperatures. Further, the steelmaking processes are of batch type rather than continuous type. This results in high level of wastage of input energy.

The specific energy consumption of Indian steel plants ranges between 9-16 Gcal/t of saleable steel, (average being 12 Gcal/t). In the advanced countries like Japan, it is of the order of 4-7 Gcal/t. the objective is to bring down the specific energy consumption in the Indian steel plants to a level of about 7-8 Gcal/t of saleable steel within the next 10 years.

## 2. Energy Inputs to Steel Plants

The major energy inputs to the steel plants are:

- i) Coking coals for production of coke used in hot metal production;
- ii) Non-coking coals used for the generation of steam and power in the captive power plants;
- iii) Purchased electricity to supplement in-plant generated power for running of electrical equipment;
- iv) Purchased petroleum fuels like fuel oil, naphtha, LSHS etc. to meet any shortfall in the availability of by-product fuels like coke oven gas, tar, B.F. gas,

About 80-90% of the energy input to the steel plants comes through coking coals. Purchased electricity accounts for only 2-3% of the total energy input to the steel plants.

## 3. Energy Input Data

Table-1 shows the energy input to the SAIL steel plants during the year 1983-84. It may be seen that for production of 4.74 million tonnes of saleable steel, the SAIL steel plants consumed about 11.24 million tonnes of coking coals, 2.26 million tonnes of steam coals, 0.23 million tonnes of petroleum fuels and  $2.38 \times 10^6$  MWH of purchased electricity. The trend in the energy consumption pattern during the last few years is shown in Figure 1. It may be seen that for a 60% of increase in the saleable steel production during the last 10 years, the increase in the energy consumption is about 90%. Further, the consumption of petroleum fuels during the same period has increased roughly by about 80%. During the period 1976-77 to 1983-84, the fuel bill has increased from a level of Rs. 240 crore to Rs. 860 crore even though the level of saleable steel production has somewhat decreased (see Figure 2). It may be mentioned here that in the developed countries there is a definite downward trend in the specific energy consumption levels whereas in the Indian steel plants there is hardly any discernable downward trend. This may be clearly seen from figures 3 and 4.

The reasons for high energy consumption in the Indian steel industry may be better understood by comparison of the energy consumed in different shops of an Indian steel plant with that of a developed country. Figure 5 shows the comparison between the energy usage in a typical Indian steel plant during 1981-82 with that in a steel plant in Japan during 1975-76. The following observations are made:

- (a) Specific energy consumption in the Indian steel plant

is about twice that of the Japanese steel plant.

- (b) In both cases about 72% of the energy consumed is upto the ironmaking stage.
- (c) The fuel utilisation efficiency in the steelmaking and reheat furnaces is poor in the Indian steel plants. Consequently, the specific energy consumption in these areas is roughly twice that in the Japanese steel plant.

#### 4. Main Reasons for the High Energy Consumption

An analysis of the operating parameters of the individual shops brings out the main reasons of the high energy consumption levels in the Indian steel plants. Further, such an analysis is useful in defining potential measures for energy conservation. This has been attempted below for major technological areas namely Coke ovens, Ironmaking, Steelmaking and Soaking pits.

##### Iron Zone

###### Coke Ovens

The major factors contributing to high energy consumption in the coke ovens area are:

(i) *Low coke oven gas yield*

The yield of coke oven gas varies in the Indian steel plants from 230 to 290 Nm<sup>3</sup>/t of coal charged. The low gas yields are due to coal with high ash content varying from 18-22%, low volatile matter varying from 22-25% (see Table 2) and leakage of gas. In the developed countries gas yields of 320 Nm<sup>3</sup>/t of coal charged while using a coal charge having an ash content of 8% and volatile matter of 27% have been reported.

(ii) *Bad condition of the ovens*

Bad condition of the ovens results in operational difficulties and high energy consumption.

(iii) *High waste Energy*

Table 3 shows the heat balance for coke ovens in one of the steel plants. It is seen that various heat losses like sensible heat of coke and coke oven gas are about  $1.3 \times 10^6$  Gcal/year for BSP. This is about 10% of the total input energy in the coke ovens.

###### Blast Furnaces

It is well known that the spectacular decrease in the coke rates in blast furnace operation in the advanced countries has greatly contributed to energy conservation. Figure 6 shows the trend of the coke rates in Japan and the main steps taken to lower coke rates to less than 450 kg/thm and increase productivity. In the Indian steel plants the following factors are mainly responsible for the high coke rates (730-1150 kg/thm).

###### High ash content of coke

Figure 7 shows the ash content of coke in the SAIL steel

plants from 1972-73 to 1983-84. It is seen that the ash content in the coke varies between 25 and 29%. In the developed countries the coke ash is as low as 8-10%. Higher ash in the coke contributes to increased slag volume in blast furnace operation and consequently higher coke rates and lower productivity.

###### Poor strength of coke

Strength of the coke used in the Indian blast furnaces is rather low. The values of  $M_{10}$ —an index of the abrasion resistance of coke are rather high compared to that of the coke used in the advanced countries. Table 4 gives the data on the coke strength ( $M_{10}$ ).

Lower strength of the coke results in the high generation of fines in the blast furnace operation. Consequently acceptance of blast is lower, productivity is lower and coke rates are higher.

###### Low Sinter in burden

The level of sinter usage in the Indian blast furnaces from 1972-73 to 1983-84 is shown in Figure 7. The use of sinter has a direct effect on the coke rates. Increase in the percentage of quality sinter in the burden decreases the coke rates considerably. In the advanced countries, sinter constitutes about 80-95% of the blast furnace burden.

###### High Raw Limestone & Dolomite in the burden

In the advanced countries the amount of raw limestone/dolomite added in the modern blast furnace burden is 5-10 kg/thm. In some of the SAIL steel plants (DSP, IISCO) raw limestone/dolomite addition is very high—about 350-550 kg/thm (see Table 4). This results in higher coke rates as the thermal decomposition is highly endothermic.

###### Low blast temperature

Figure 7 shows the data on blast temperature achieved during the period 1972-73 to 1983-84 in the Indian steel plants. The average value of the blast temperature in the Indian steel plants is around 720°C, which is very low as compared to the blast temperature levels of 1100-1350°C achieved in the advanced countries.

###### High top pressure

Super high top pressure in blast furnaces (2.5-3.5 atmospheres gage) is being practiced in the advanced countries for achieving increased productivity and lower coke rates. In India, only Bokaro steel plant is practicing moderate top pressure of about 1.4-1.5 atmosphere.

###### Unstable blast furnace operation

Unstable operation of blast furnaces is caused by:

- (a) Unstable thermal regime on account of inconsistency in the quality of input materials
- (b) Excessive fines in the iron ore and sinter and improper burden distribution
- (c) Problems in availability of input materials
- (d) Logistic problems related to tapping of hot metal

## 6. Steelmaking

The high energy consumption in the area of steelmaking can be mainly attributed to:

### (i) High Ratio of open hearth steelmaking to oxygen steelmaking

In the developed countries the steelmaking is mainly through oxygen steelmaking route, while in India over 50% of the steel is produced through the open hearth furnace route (Table 5). Open hearth steelmaking process is highly energy intensive as it is a slow process.

### (ii) High specific fuel consumption

The high specific fuel consumption in the open hearth furnaces is contributed by unstable operation of the furnaces, low productivity and improper combustion control.

### (iii) Conventional Ingot casting route

In SAIL steel plants almost 100% of the steel is cast through ingot casting route. In modern steel plants almost 100% of the steel is cast through the continuous casting route where the yield is high and one reheating operation is eliminated.

## 7. Rolling Mills

The following factors contribute to high energy consumption in the area of rolling mills:

### (i) Obsolete combustion systems in furnaces

The combustion systems in the furnaces of primary and finishing rolling mills e.g. soaking pits, reheating furnaces, etc. are quite old in the Indian steel plants. In oil firing burner systems poor atomization, chocking of burner tips and leakage of oil etc. are common leading to high energy consumption.

### (ii) High track time

Track time of ingots is one of the major factors contributing to very high energy consumption in the soaking pits. The average track time in the Indian steel plants varies between 2.5 hours to 4.5 hours. By reducing the track time through extensive use of modern communication facilities for close monitoring and control and modernising auxiliary facilities like charging, discharging etc., Japanese steel plants are able to achieve a specific fuel consumption of about 0.15 Gcal/t whereas in the Indian steel plants it varies from 0.25 to 0.5 Gcal/t.

### (iii) High heat losses through cooling water/refractories

The heat losses through the cooling water and furnace structure account for nearly 30-32% of the heat supplied. This is due to obsolete design of cooling water systems in reheating furnaces and use of poor quality of insulation material in the Indian steel plants.

### (iv) Unstable Mill operation

Unstable mill operation is mainly due to the prevailing obsolescence of equipment. This results in difficulties in synchronising the heating operations and the rolling operations.

## 8. Categories of Energy Conservation Measures

Systematic and sustained efforts are required to bring down the level of energy consumption in the steel plants. The energy conservation measures can be broadly categorised as:

- (a) Operational improvements
- (b) Equipment improvements
- (c) Modernisation measures

### (a) Operational Improvements

For evolving and implementing energy conservation plans in the steel plants, it is imperative to give due importance to the matters related to

- improvement in operations technology
- improvement in administrative measures

These steps need hardly any capital investment, but have to be followed on a continuous, routine basis. Some of the examples of improving operational aspects are:

- (i) To minimise leakage of oil, air, steam etc.
- (ii) To analyse the fuel gases regularly for maintaining appropriate air-fuel ratio
- (iii) To maintain proper quality and size of input raw material
- (iv) To rigidly follow thermal regimes of furnaces
- (v) To operate optimum number of furnaces

### (b) Equipment Improvements

The second category of the measures is equipment improvement. These require marginal investment and the return is quite high. Some examples are:

- (i) Insulation of cold blast main;
- (ii) Minimising leakages of hot blast;
- (iii) Improvement in combustion systems. This requires replacement of existing burners with those of modern design like ceramic burners in blast furnace stoves, high velocity burners in soaking pits, flat flame burners in reheating furnaces etc.;
- (iv) Use of ceramic fibre insulation in the furnaces: This would reduce the heat loss from the furnaces to an extent of 5-7%;
- (v) Modification of water-cooled skids in the reheating furnaces. This is one of the important measures to bring down the energy consumption in the furnaces as heat losses through an uninsulated skid system can account for as much as 30% of the heat supplied to the furnaces. In modern furnaces the trend is to use skid



system with evaporative water cooling and insulating blocks having an inner layer of ceramic fibre.

(vi) Introduction of economically justified waste heat recovery systems requiring moderate investments.

#### (c) Modernisation Measures

These are generally capital intensive in nature. These measures are vital for efficient plant operation and failure to modernise the plant at the right time results in steep deterioration in the plant output.

Some of the modernisation measures that may be adopted are:

- stamp charging of coal charge;
- partial briquetting of coal charge;
- modernisation of the existing sinter plants and installation of new sinter plants;
- intensification of blast furnaces;
- replacement of open hearth furnaces by oxygen steelmaking converters;
- large scale adoption of continuous casting;
- introduction of walking beam/walking bottom furnaces;
- modernisation of rolling mills;
- introduction of computer control systems in all the shops;
- introduction of waste energy recovery processes like coke dry quenching, heat-recovery systems in sinter plant, power generation using blast furnace top gas pressure.

### 9. Energy Conservation Efforts of SAIL

In order to give a new impetus to the energy conservation efforts of SAIL, a report consisting of plant-wise energy conservation plans was prepared by SAIL in March, 1983. A brief list of the three categories of energy conservation measures included in the energy conservation plans of the SAIL steel plants is given in Annexure-I. The implementation of these measures has been taken up by the Task Force for Energy Conservation in individual shops of the steel plants. The progress of implementation of these measures is being monitored at the plant-level as well as at the Corporate level. Some of the short-term measures are being routinely followed. A number of medium-term measures are in progress. Long-term measures are planned to be introduced as part of the modernisation programmes.

Mention may be made of some of the technologies developed through R&D efforts in our plants contributing to energy conservation.

#### *Lime Dust Injection*

The technology of lime dust injection through tuyeres of blast furnace has been developed on the small scale at Kalinga Iron Works. Lime has been injected on continuous basis at the rate of 30 to 40 kg. per tonne of hot metal in blast furnace No. 3. The increase in productivity is in the

range of 11-15% and decrease in coke rate 6-11%. This technology is presently being upscaled at DSP where lime dust at the rate of 100 kg. per tonne of hot metal will be injected in blast furnace No. 1. The demonstration plant is under construction and is expected to be commissioned by the end of this year.

#### *Use of high basicity sinter*

It is a well established fact that if the raw lime stone charging in blast furnace is avoided by charging of the flux through sinter, substantial benefits can be achieved with respect to increase in productivity and decrease in coke rate in blast furnace. This objective in our steel plants can be achieved by charging either high percentage of the sinter burden of lower basicity or lower percentage of sinter in the burden of higher basicity. The trials at BSP have been carried out on both the above alternatives by eliminating 100 kg. per tonne of hot metal of lime stone through use of higher basic sinter. The increase in productivity was of the order of 5-6% and decrease in coke rate about 4-6%.

#### *Use of extended hood practice in the sintering*

The RDCIS design of extended hood has been implemented in sintering plant No. 2 in BSP. This modification will result in lower energy consumption and higher productivity of sintering machine.

#### *Use of Coal Bonded Pellets in Blast Furnaces*

The technology of coal bonded pellets eliminates use of fuel oil as required in conventional heat hardening pelletisation process. Trials with coal bonded pellets have been carried out at KIW using 25 to 30% pellets in blast furnace burden. The benefits with respect to increase in productivity and decrease in coke rate were of the order of 7-11%. The technology is now being upscaled for blast furnaces of IISCO.

#### *External Desiliconisation and Desulphurisation of hot metal*

The desiliconisation practice has been modified at DSP to achieve the higher degree of desiliconisation by increasing the lime stone consumption from 250 kg. to 1000 kg. per ladle. The drop in silicon content of hot metal was increased from 0.4 to 0.8%. The implementation of this technology will help in decrease in the lime consumption in open hearths and also an increase in productivity by reducing the duration of heat. RDCIS has also established the practice of desulphurisation of hot metal using the indigenously available cheaper reagent like lime and soda ash. The adaptation of this practice will help in running the blast furnaces on low slag basicity thus will help in increasing the productivity and decreasing the coke rate.

#### *Optimum thermal and lancing regime in the open hearth furnaces*

Implementation of this project at BSP has resulted in 15% saving in specific heat consumption. Similar benefits have also been achieved at DSP open hearth furnaces.

#### *Oxygen assisted melting in electric arc furnace*

Implementation of this project at ASP has resulted in reduction in melting time by about 20 minutes and reduction in power consumption by 80-100 KWH per tonne.

#### *Oxygen enrichment of combustion air in soaking pit*

This practice has been introduced in RSP and DSP and has resulted in saving of fuel consumption by about 10-12%.

#### *Use of ceramic fibre seal in soaking pits*

This project has been implemented on trial basis in the soaking pits at BSL. The ingot heating rate is faster and heat utilisation is better as indicated by the lower heat consumption.

#### *Modified combustion system in reheating furnace at IISCO*

The new combustion design system has given 16 to 20% reduction in specific heat consumption for structural mill and 21% reduction in light structural mill.

### 10. Discussion and Recommendations

Steel industry is highly energy intensive, since the various industrial operations have to be performed at high temperature conditions. It hardly needs to be emphasised that all other conditions remaining constant, the extent of energy conservation measures directly reflects on the profitability of a steel industry.

As the follow up of the last paper on upgradation of technology, this paper deals with more specifics in the area of energy scenario.

The most important observation is that the specific energy consumption in the Indian steel plants is about twice that of steel plants in other developed countries like Japan. The differential is of the same order even with other steel producing countries who are comparatively newcomers in the area like South Korea and Brazil.

It is observed that in our steel plants the rate of increase in saleable steel production between 1970-71 to 1983-84 is significantly lower than the rate of increase in total energy consumption. For 60% increase in saleable steel production during the last 10 years, increase in energy consumption is about 90%. In other words, specific energy consumption figures have been increasing. Even the consumption of the high value petroleum fuels during the same period has increased roughly by about 80%.

Various kinds and quality of energy inputs in different plants of SAIL and relative energy consumption figures in all the integrated steel plants inclusive of TISCO are given. The first apparent anomaly is needed to be highlighted. Consistently, the lowest energy consumption per tonne of finished steel has been in BSP, a fully open-hearth based steel plants till now, and not in the plants using oxygen process converter. While necessary correction due to differential product-mix as well as differential quality of raw materials can be made the fact remains that

the obvious advantage of oxygen steelmaking process over open-hearth in energy front has been upset by possibly better technology discipline and development and adaptation of more energy efficiency measures at BSP through inhouse R&D efforts particularly in iron and steelmaking zone.

It is also necessary to observe that during the period 1976-77 to 1983-84, fuel bill has increased in SAIL from a level of Rs. 240 crores to Rs. 860 crores even though the level of saleable steel production has somewhat decreased. It is worth mentioning that during the period, the rate of increase in steel price has been substantially lower.

Between 1950s and 1980s, all the other steel producing countries have reduced their specific energy consumption figures by around 50%. In fact in the 1950s and early 1960s, our energy consumption figures were equivalent to the same as in other steel plants abroad, which has, however, marginally increased during this period, while elsewhere the same has been halved.

After the said situation analysis, the causes of differential energy consumption have been highlighted. Since 80 to 90% of the total energy input to steel plants is through coal, primarily coking coal, the coal quality deterioration has the most significant effect on specific energy consumption. Ash content of coking coal has been steadily increasing from 17% to 22%. The effect of even marginal increase in ash content at such high level is disastrous in terms of exponential increase in coke rate and reduction in productivity in blast furnace and also deterioration in quality of hot metal thereby affecting sharply on steel making practice, the yield of products and increase in energy consumption in down stream areas with a multiplier effect. In this area, the steel plants are fighting a losing battle. While ash content of coking coal for economic production of iron has been decreasing from around 17% to 6 to 7% in Japan and elsewhere, with corresponding improvement in total energy efficiency, the ash content in Indian coking coal has been increasing and has now come to an alarming level. In fact, acceptable quality of coking coal for economic production of iron is no longer available in India, the resources can only be used for blended purposes with imported high caking index and low ash coking coal. Planners have to concentrate on this single largest constraint directly affecting techno-economic level of our steel industry.

While between 60 to 70% performance differentials can be attributed to the said inherent problems, the other major causes are also required to be highlighted. These are gradual deterioration of technology discipline, equipment hardware constraints, inadequate R&D inputs to consistently improve the state of art, and introduction of indigenous technologies and lack of systematic, planned in-time refurbishing and debottlenecking and technology modernisation efforts.

Improved technology discipline in our plants can share

reduce specific energy consumption. Introduction of decentralised shop floor/profit centre based reward and punishment schemes are required to be evolved and institutionalised. Both in the capitalist and socialist countries such decentralised, reward and punishment schemes have given best results in energy efficiency front. Incidentally in this area we are going back in time in terms of upward centralisation of authority through multiple, horizontal and vertical channels upto BPE.

Commercial adaptation of established R&D outputs is also an area needing more attention. R&D projects involving marginal or low investments with a potential to improve in state-of-art are established through controlled experiments in the plants with tangible results in improving energy efficiency. However, the same is often not commercialised in sustained manner due to extraneous and often human problems. R&D projects involving the total cycle from concept to commercialisation also get delayed

at the stage of introduction of commercial facilities both in investment decision making stage as well as project construction stage. Appropriate system and management decisions are called for.

For improvement of performance in energy front priority has to be given on introduction of imported software based technology packages through R&D and designs and engineering organisations for appropriate adaptation and further improvement of the imported technologies. As mentioned in the earlier paper, a National Standing Committee should identify targets of energy consumption in various technology areas which are to be made mandatory within specific timeframe.

Dr. S.K. Gupta is with Research & Development Centre for Iron & Steel, Steel Authority of India Limited, Ranchi.

Dr. G. Mukerjee is with Steel Authority of India Limited, New Delhi.

Table-1: Energy Inputs to Individual Steel Plants During 1983-84

Item	Unit	BSP	BSL	DSP	IISCO	RSP	Total SAIL Plants
Coking coal	X 10 <sup>6</sup> t	2.944	3.497	1.472	1.650	1.681	11.244
Steam coal	X 10 <sup>6</sup> t	0.516	0.743	0.260	0.495	0.241	2.255
Petroleum fuels	X 10 <sup>3</sup> t	9.990	6.020	98.50	22.60	94.470	231.61
Purchased electricity	X 10 <sup>6</sup> MWH	0.632	0.810	0.293	0.128	0.518	2.381
Total energy input	X 10 <sup>6</sup> Gcal	22.71	28.03	11.77	13.79	13.38	89.68
Steel production	X 10 <sup>6</sup> ingot	1.837	1.681	0.806	0.592	1.088	6.01
	X 10 <sup>6</sup> Saleable	1.538	1.288	0.602	0.444	0.862	4.730

Table-2: Ash Content and Volatile Matter in the Coal Blends of Indian Plants During 1976-77 to 1982-83

Sl. No.	Plant	Year							
		1976-77	1977-78	1978-79	1979-80	1980-81	1981-82	1982-83	
1.	BSP								
	Ash	%	18.99	19.84	20.20	19.60	20.10	19.70	18.70
	VM	%	24.00	24.90	24.70	24.40	23.60	23.70	23.10
2.	RSP								
	Ash	%	18.91	19.05	18.95	18.64	19.41	18.87	18.52
	VM	%	24.05	25.10	25.18	24.86	24.12	23.94	23.10
3.	DSP								
	Ash	%	20.22	20.44	21.12	22.69	21.96	22.13	21.78
	VM	%	23.63	23.53	23.46	22.57	22.90	21.94	21.92
4.	BSL								
	Ash	%	19.83	21.38	20.45	21.18	21.81	21.05	20.64
	VM	%	24.31	23.85	23.85	23.72	23.47	23.22	22.81
5.	IISCO								
	Ash	%	19.93	20.20	20.83	21.41	21.71	22.20	21.92
	VM	%	25.58	25.03	25.05	24.92	24.92	24.69	24.46

Table-3: Coke Ovens Heat Balance

Sl. No.	Item	Unit	Material input/ output value	Energy equivalent, 10 <sup>6</sup> Gcal/yr	%
1.0	Input				
1.1	Coking coal	X 10 <sup>6</sup> t	1.93	12.54	89.8
1.2	CO gas	X 10 <sup>9</sup> Nm <sup>3</sup>	0.07	0.26	1.9
1.3	BF gas	X 10 <sup>9</sup> Nm <sup>3</sup>	0.97	0.94	6.7
1.4	Air preheat	X 10 <sup>9</sup> Nm <sup>3</sup>	1.07	0.22	1.6
				13.96	100.0
2.0	Output				
2.1	Coke (potential)	X 10 <sup>6</sup> t	1.50	10.10	72.3
2.2	Benzol (potential)			0.04	0.3
2.3	Tar (Potential)	X 10 <sup>6</sup> t	0.05	0.47	3.4
2.4	CO gas (potential)	X 10 <sup>9</sup> Nm <sup>3</sup>	0.48	2.00	14.3
2.5	Losses			1.35	9.7
				13.96	100.0
	Break-up of losses				
2.5.1	Coke sensible heat			0.54	
2.5.2	Dry gas sensible heat			0.10	
2.5.3	Benzol & tar sensible heat			0.01	
2.5.4	Waste gas heat			0.30	
2.5.5	Others			0.40	

Table-4:  $M_{90}$  Value and Limestone Consumption in Blast Furnace During the Period 1972-73 to 1983-84

Item	Plant	72-73	73-74	74-75	75-76	76-77	77-78	78-79	79-80	80-81	81-82	82-83	83-84
$M_{90}$ Value	BSP							11	12	13	12	13	15
	RSP							10	10	11	10	10	11
	DSP	14.9	14.9	14.0	16.5	13.9	14.4	15	16	15	15	15	18
	BSL		9.9	8.8	9.9	9.9	10	-10	11	13	13	13	13
	IISCO							-17	17	17	18	18	17
Raw Limestone + Dolomite kg/1hm	BSP	222	206	179	179	171	190	185	168	116	110	42	60
	RSP	369	408	288	235	232	309	288	209	284	312	291	190
	DSP	368	363	456	400	394	351	359	347	343	386	302	380
	BSL	124	75	48	33	52	64	108	195	174	125	126	100
	IISCO	428	480	480	474	460	495	494	578	579	608	559	560
	TISCO	288	241	242	222	202	162	82	65	52	82		

Table-5: Steel Production Data Through Open Hearth Furnaces and LD Converters During the Period 1976-77 to 1982-83 in SAIL Steel Plants

Year	Steel through Open Hearth X $10^6$ tonnes	Steel through LD Converters X $10^6$ tonnes	% Open Hearth Steel
1976-77	4.361	2.158	66.90
1977-78	4.423	2.033	68.51
1978-79	4.070	2.217	64.73
1979-80	3.856	2.393	61.71
1980-81	3.659	1.820	66.78
1981-82	3.893	2.747	58.63
1982-83	3.927	2.752	56.91

**Category-I: Operational Improvement****(i) Coke Ovens**

- improvements in operating practices—full charging of ovens, proper sealing of oven doors to reduce door leakage and brazing
- to maintain thermal regime and control of heating
- regular cleaning of regenerators
- to maintain constant  $O_2$  in flue gas

**(ii) Sinter Plant**

- proper maintenance and cleaning of fuel line to maintain the required flow to all the strands
- proper de-dusting to be ensured to facilitate better working condition
- regular air-gas ratio control
- proper quality and sizing of input materials
- rectification of air leakage in the suction line of blower

**(iii) Blast Furnaces**

- better sizing and screening of input materials
- higher usage of sinter
- cleaning of the burners and chequers of the stove
- proper operational heating and control cycles of the stove
- minimising air loss by proper maintenance of cold and hot blast lines
- lower limestone in the burden either by increasing the sinter use or by using the higher basicity sinter.

**(iv) Steel Melting Shop**

- to work out optimal thermal regimes in open hearth furnaces taking into consideration the technological parameters and condition of the furnaces.
- to reduce constant heat losses through cooling water, walls, openings and flue, intensification of O.H. processes such as by oxygen lancing or higher heat load.
- regular flue gas analysis to be done for combustion control as well as to study air infiltration through regenerator and to take necessary corrective actions
- cleaning of regenerator channels periodically to maintain its higher efficiency
- operation, mechanical and electrical delays to be minimised.

**(v) Soaking Pits**

- to reduce heat losses from ingots to ambient by lowering track time, using optimum time of ingots inside and outside the mold before charging
- proper scheduling of charging and discharging of soaking pits to be done in order to ensure readiness of ingots
- to ensure air tight operation of the pits by proper sand sealing of covers, skirt plates etc.

**(vi) Reheating Furnaces**

- all discharge doors, charging doors and inspection doors to be kept functioning properly
- percentage oxygen in the flue gas is to be maintained around 1-2%
- all furnace pressure controls are to be in perfect working condition
- to use optimal thermal regimes for various sections rolled.

**(vii) Power Plant**

- to ensure availability of better quality coal in respect of ash content
- to ensure better wagon availability for removal of ash from boilers
- to plug all steam and air leakages to reduce steam consumption in turbo blowers
- to try the use of steam through wind box of boilers to avoid clinker formation
- to keep the coolers of turbo compressors in proper working condition
- to analyse the coal unburnt carbon in the cinder regularly.

**Category-II: Equipment Improvement****i) Iron-Making**

- insulation of cold blast line from turbo blower to the blast furnace stoves
- elimination of leakages of cold and hot blast
- modification of gas pipeline diameter to increase the fuel firing rate
- to increase blower capacity of combustion air in the sinter plant
- close circuit flux crushing to control lime fineness
- screening of sinter near skip pit

**ii) Steel Making****OH Furnace**

- modification in burners for improved firing of CTF
- Introduction of double oxygen lancing in OH Furnaces

**iii) Soaking Pits**

- burner modification
- replacement of blower to ensure required suction
- introduction of ceramic ceiling of the pit cover
- modification in burner design
- burner port modification
- flue arch modification

**iv) Reheating Furnaces**

- introduction of flat flame burners
- modification of skid insulation
- modification of burners

**v) Power Plant**

- modification in combustion air distribution for grate coal firing
- modification of BF gas burners

**Category-III: Modernisation**

**i) Iron Making**

- installation of sinter machine for augmenting sinter usage in the blast furnaces
- coal dust injection
- lime dust injection
- dry type top pressure recovery turbine
- introduction of ceramic burners in the stove
- preheating of combustion air of the stove
- coke dry quenching systems
- case heat recovery through sinter cooling

**ii) Steel Making**

- installation of LD converters

- installation of continuous casting equipment
- top and bottom blowing for BOF
- recovery of LD gas incorporating suppressed combustion system

**iii) Soaking Pits**

- automatic combustion control for soaking pit
- computerisation of operation

**iv) Reheating Furnaces**

- automatic combustion control
- computerisation of furnace control
- evaporative cooling of skids
- introduction of ceramic fibre blocks

**v) Utility Plants & Others**

- introduction of fluidized bed combustion in the power plant boiler
- firing of COM and/or CWM to reduce fuel oil consumption in the power plant
- introduction of energy supply demand system
- automatic control in oxygen plant




FIG. 1

# YEARWISE ENERGY CONSUMPTION DATA






FIG-2

INPUT ENERGY COST (SAIL)



RDCIS




FIG. 3

SPECIFIC ENERGY CONSUMPTION DATA  
(INDIA)






FIG. 4

SPECIFIC ENERGY CONSUMPTION  
— OTHER COUNTRIES.





FIG. 5 COMPARISON OF ENERGY DATA



- ① use of high self-fluxing sinter
- ② oxygen enrichment of blast
- ③ fuel injection and high temperature blast
- ④ high top pressure operation
- ⑤ use of imported pellet
- ⑥ spread of fuel injection
- ⑦ construction of high temperature stoves
- ⑧ super-high top pressure
- ⑨ increase of fuel injection
- ⑩ control of burden distribution
- ⑪ dehumidification

	1967	1977	Fuel rate, kg/t HM.
①	55.0%	75.7%	19
⑤	12.0%	10.7%	
⑦	990°C	1203°C	
⑪	25 g/Nm³	13 g/Nm³	8
slag ratio, kg/t HM	285	301	+5
coke ash, %	98	11.1	+13
low Si in hot metal			28
ore sizing			
better furnace control			
⑧	—	1530 kg/cm²	58
others			
fuel rate, kg/t HM	530	472	

Fig. 6 Trend of productivity, fuel rate, and coke rate of blast furnaces in Japan




FIG 7

IMPORTANT PARAMETERS IN BLAST FURNACES







CASE STUDIES  
IN  
ENERGY CONSERVATION

PREPARED  
FOR  
SEMINAR ON ENERGY CONSERVATION

BY  
HEAT RECOVERY DIVISION  
THERMAX PRIVATE LIMITED.





- Heat Recovery systems for thermic fluid heating, water heating and steam generation, could be tailor made so that performance of D.G. set is not affected in any way.
- Once a captive power source which was cheaper than grid power was installed, continuous operation of critical equipment could be ensured at all times, irrespective of power cuts, both scheduled as well as unscheduled.

Once these facts were brought forth, decision in favour of installing heat recovery system was straight forward. Heat was decided to be recovered in form of steam, by installing a custom-built, two drum, natural circulation water tube boiler and a finned economiser. The boiler was designed for recovering around 24 lac Kcal per hour, which is equivalent to around 3650 Kg/hr steam (F&A 100°C)

Now, when the system has been working successfully for 6 months, Management of Modipon considers their decision to adopt co-generation system, a wise one and have even decided to go-ahead with same configuration in 2nd phase of D.G. Set capacity expansion.

CASE - 1

INSTALLATION OF HEAT RECOVERY SYSTEM  
ON D.G. SET AT MODIPON, U.P.

Chronic power shortage has badly afflicted major industries in North India. Modipon Ltd., one such unit, was losing Rs. 2.5 crores per year on this account / it was forced to install a / till captive power generation system. Steam turbine based co-generation systems were not considered due to huge financial outlays, long gestations and unmatched power - steam requirements.

Simplest solution, therefore was installation of a D.G. set and that's how the project was launched. Resources were limited and hence initial instructions were to procure barest minimum of equipment.

The project department of Modipon however pointed out that a D.G. Set heat recovery system would cost only 7-10% extra and could save Rs. 30 lacs per year on operation cost.

More detailed analysis was asked for and figures which emerged revealed:

- By heat recovery system, cost of power from D.G. set could be reduced by 12-15%.
- Even with low grid power cost prevailing at that time continuous operation of D.G. Set with heat recovery, would save money for the company, rather than increase the cost of operations as was believed.
- Past trends indicated that the cost advantage for D.G. set with heat recovery, will become even more pronounced with passage of time.
- The company will burn 4000T less of coal, reducing procurement, storage, handling and ash disposal expenses.

SALIENT FEATURES OF D.G. SET HEAT RECOVERY  
SYSTEM INSTALLED AT MODIPON LTD.

APPLICATION:

D.G. Set capacity	- 5.4 M.W.
MAKE	- Wartsila
Exhaust gas temperature	- 370°C
Quantity	- 42624 Kg/hr
Steam pressure required in process	- 12.5 Kg/cm <sup>2</sup> g

SYSTEM DESIGN

Total Heat Recovered	- 2421000 Kcal/hr
Reduction in exhaust gas temp.	- from 370 to 225°C in boiler 225 to 175°C in economiser
Steam generation at full load	- 3655 Kg/hr f&A 100°C
Total pressure drop on gas side	- 150 mm wc in boiler 45 mm wc in economiser
Controls provided	- Level transmitter and controller. - pressure transmitter. - level control switches in F.W. tank - Automatic gas by-pass - feed control

SAVINGS

Cost of power from grid	- Rs. 1.08/kwh
Cost of power from DG Set without heat recovery	- Rs. 1.03/kwh
Cost of power from DG set with heat recovery	- Rs. 0.91P/kwh
Savings in power cost	- Rs. 0.12P/kwh
Likely yearly savings	- Rs. 30 lacs/year on 5000 hrs of operation.
Payback period on project cost	- Around 1 year

CASE-2                      INSTALLATION OF GILLED ECONOMISER  
ON 85 T/HR, 50 KG/CM<sup>2</sup> BOILER AT  
MADRAS REFINERY LIMITED.  
-----+-----

The refinery has a battery of 3 identical, John Thompson boilers, each capable of generating 85 T/hr of steam at 50 Kg/cm<sup>2</sup> and 430°C temp. All these boilers were originally installed without economiser/air preheater, as perhaps at that time heat recovery from flue gases was not considered economically viable. Air preheater was subsequently installed on one boiler and space was found to be insufficient for same on other two boilers.

It was then realised that a gilled tube economiser would be more compact and hence could be retrofitted in the space available. The installation would however be subject to certain special requirements like :

- Due to very high sulphur content (6.5%) in the fuel, precautions to prevent low temp. corrosion will be necessary.
- Due to reduction in quantity of fuel fired, steam temp. at the outlet of superheater could come down.
- Extra pressure drop on gas side may result in squeeze on ID Fan capacity.

These requirements were taken care of as follows:

- The economiser installed, comprises tubes of two configurations welded steel gill type for higher gas temp. section and cast Iron protected carbon steel type for sections prone to acid corrosion.
- An additional external superheater has been installed to raise the temp. of saturated steam before it goes to primary superheaters, to ensure against reduction in degree of super heat. This has been done for the first time in country for

power boilers.

- Proper pitch selection as well as 'in line' configuration of gills ensures against excessive pressure drop on gas side.

The design was overviewed by our collaborators, M/s. Senior Green of U.K. who have installed gilled economisers on boilers of upto 600 MW capacity. The order was received through global tenders, against competitions from world giants.

The project cost for both the boilers was around Rs. 90 lacs while savings are anticipated to be of the order of Rs. 2.3 crores/yr.

## SPECIFICATIONS OF MRL ECONOMISERS:

### A. SUPERHEATER

Duty	- $1009.8 \times 10^3$ Kcal/hr
Steam flow	- 85 T/hr
Rise in steam temp	- $12.3^\circ\text{C}$ .
Gas side pressure drop	- 5.9 mm wc
Tube details	- 64 Nos. welded steel gill type.

### B. ECONOMISER

Duty	- $6418.5 \times 10^3$ Kcal/hr
Feed water flow	- 85 T/hr
Rise in F.W. Temp.	- $73.7^\circ\text{C}$ (From $105^\circ\text{C}$ to $178.7^\circ\text{C}$ )
Drop in <u>flue</u> gas temp.	- $201.2^\circ\text{C}$ (from $366.6^\circ\text{C}$ to $165.4^\circ\text{C}$ )
Gas side pressure drop	- 45.5 mm wc
Tube details	- 64 No. welded steel gill 304 No. C.I. protected carbon steel.

CASE - 3

INSTALLATION OF VAPOUR ABSORPTION  
CHILLERS BASED ON D.G. SET HEAT  
RECOVERY AT THOMSON PRESS.

-----

M/s. Thomson Press are a most modern printing house, having centrally air conditioned facilities. Air conditioning at the moment is being achieved with 3 Nos. conventional, reciprocating chillers of 40 TR capacity each. Due to expansion of facilities, the total A/C load is expected to go up to around 250 RT in immediate future.

Power situation in the area in which the company is located is quite bad and the company has to operate its D.G. Sets for more than 20 hrs every day. The company has 2 D.G. sets of 1015 KVA each, installed for this purpose. It was clear to the Management that at least in the near future, there would be no way out, but to operate D.G. Sets, which, anyway is costlier than grid power.

A proposal was therefore mooted regarding recovery of waste heat from D.G. Sets and using the same for operating the vapour absorption chillers. The overall energy cost could therefore, be brought down. In view of the contemplated expansion, the company wanted to have an installed capacity of around 400 RT, for which 1800 Kg of steam at a pressure of  $8 \text{ Kg/cm}^2$  would be required, through use of double effect chillers. On the other hand, an estimation of steam generation potential from D.G. sets showed that upto 800 Kg of steam could be generated from both the sets. It was therefore decided that a oil fired package boiler be installed to meet the balance of steam requirements.

The final system installed comprised of following components:

- 2 waste heat recovery boilers, one on each D.G. Set.



-2-

- 2 oil fired package boilers, one to be operated on continuous basis, while the other to be a standby for periods when D.G. sets do not work.
- A two stage, 400 RT nominal capacity, steam fired vapour absorption chiller, imported from Japan.
- All associated piping, low side equipments, water softner and gas bypass valve.

The additional investment on this project, over and above the money the company would be spending had they gone in for conventional chillers, is around Rs. 30 lacs, which is expected to be recovered in 1 1/2 years time, after taking into account financial benefits due to accelerated depreciation, etc. The project specs are enclosed.

However, apart from monetary savings, the company considers the main advantage of the project in reduction of dependence on grid supply, reduction in maintenance and operation skill requirements for chillers and a quiet operation.

THOMSON PRESS - AIR CONDITIONING WITH  
 VAPOUR ABSORPTION CHILLERS.  
 -----

CAPACITY OF D.G. SETS	- 2 Nos. PETBOW MAKE, 1015 KVA each.
EXHAUST TEMP.	- 450°C.
AVERAGE LOAD	- 75%
MINIMUM LOAD	- 500 KW
COST OF GRID POWER	- 0.8 KWH
COST OF POWER FROM D.G. SET	- Rs. 1.1 /Kwh
DESIGNED CAPACITY OF EXHAUST GAS BOILERS AT 75% LOAD	- 400 KG/Hr each.
CAPACITY AT 500 KW	- 300 KG/Hr each.
CHILLER CAPACITY	- 400 TR
STEAM REQUIRED AT FULL LOAD	- 1800 KG/HR
OIL FIRED BOILER CAPACITY	- 1000 KG/HR each.

## CASE 4

INSTALLATION OF CERAMIC RECUPERATOR  
ON BOX TYPE FORGING FURNACES.  
-----

The company is one of the largest forging companies in India. They have a number of large furnaces, all firing L.D.O. Temperatures, maintained are around  $1200^{\circ}\text{C}$ . The company has been on the look out for a reliable heat recovery system, for a long time, without much success. Due to high flue gas temperatures, metallic recuperators were not expected to be of great benefit. Ceramic Recuperators on the other hand, could handle these high temp. gases with ease and thus save substantial money for the company.

Two box type furnaces were therefore chosen in the initial phase for installation of Ceramic recuperators. Each of these consumes around 150 Kg/hr of L.D.O. 4 Nos. North American LAP burners have been installed on each furnace. Our experience has shown that this type of burners can handle preheated air upto around  $500^{\circ}\text{C}$ . Hence recuperators were designed for inlet flue gas temp. of around  $1100^{\circ}\text{C}$  and an outlet air temp. of around  $460^{\circ}\text{C}$  at 40% effectiveness. The eductors provided on the gas side, compensate the pressure drop across the recuperator. Separate blowers have been provided for eductor air in each of the furnaces. Separate blowers for atomising air already existed.

The post commissioning trials have shown a preheated air temperature of  $450^{\circ}\text{C}$  and pressure drops of 6 mm wc and 37.5 mm wc on gas and air sides respectively. No adverse effect has been observed on burner/furnace operation. Each of these installations is likely to save 15-20 litres of oil per hour, resulting in a simple payback of less than 3 months.

# SPECIFICATIONS OF CERAMIC RECUPERATORS ON BOX TYPE FORGING FURNACES. -----

Type of Recuperators	- single block, Ceramic matrix type.
Model No.	- TCR-150
Type of burners	- LAP
Make and model	- Wesman, North American No. 5425-6
Number of burners on each furnace	- 4
Pressure at burner	- 20" of water column
Flue gas outlet temp. as measured	- 1060 <sup>o</sup> C
Designed effectiveness of recuperator	- 40%
Designed press. drop gas side	- 15 mm wc
Designed press. air side	- 50 mm wc
Actual press. drop gas side	- 6 mm wc
Actual press. drop air side	- 37,5 mm wc
Oil consumption before installation of recuperator	- 150 Kg/hr
Oil consumption after installation of recuperator	- 130-135 Kg/hr



INDUSTRIAL COGENERATION

VIRENDRA S. KOTHARI  
TATA ENERGY RESEARCH INSTITUTE  
NEW DELHI


WORKSHOP ON ENERGY MANAGEMENT IN INDUSTRIAL SECTOR

NEW DELHI  
NOVEMBER 24-26, 1986




## COGENERATION

- o Cogeneration is the combined production of electrical or mechanical energy and thermal energy
- o Cogeneration is not a new concept




Since 1900, industrial on-site power generation in the United States has declined relative to total generation

- o Cogeneration vs. utility generation



- o Performance of cogeneration system



$$\begin{aligned}
 FCP &= \frac{(\text{fuel})_2 - (\text{fuel})_1}{\text{kW} - (\text{PH aux})_2 + (\text{PH aux})_1} \\
 &= \frac{\text{total fuel} - \text{process fuel credit}}{\text{kW} - \Delta \text{PH aux}}
 \end{aligned}$$

Fuel chargeable to power concept. (a) Noncogeneration system. (b) Cogeneration system.




## COGENERATION   TECHNOLOGIES


- o Cogeneration technologies generally based on two power cycles
  - Topping Cycle : Fuel used to produce electric or mechanical power. Waste heat from power production then used to provide useful thermal energy
  - Bottoming Cycle : Fuel used to provide heat for process. Waste heat from process then used for power production
- o Topping cycle has wider industrial applications
- o Topping cycle systems
  - Steam turbine systems
  - Gas turbine systems
  - Combined gas-steam turbine systems
  - Diesel engine systems
- o Bottoming cycle systems
  - Steam Rankine cycle systems
  - Organic Rankine cycle systems

## STEAM TURBINE SYSTEMS

- o Most common cogeneration system
- o Steam turbine types
  - Backpressure
  - Extraction
  - Extraction condensing




- o Unit size : 0.5 - 100 MW
- o Electric efficiency
  - Full load : 14-28%
  - 50% load : 12-25%
- o Heat rate
  - Total : 11,550-22,750 kJ/kWh
  - Net : 4,250- 5,700 kJ/kWh
- o Electricity to Steam ratio : 28-70 kWh/GJ
- o Availability : 90-95%



Usual throttle steam conditions vs. steam flows<sup>4</sup>

Courtesy: Power magazine.




Courtesy: Power magazine.

By-product power generation vs. initial steam conditions.<sup>4</sup>

<sup>4</sup>W. B. Wilson, "How to Use Steam Turbines in Refining, Petrochemical and Chemical Industries." *Power*, February, 1960, p. 78.


## GAS TURBINE SYSTEMS

- o System consists of gas turbine and waste heat recovery system
- o Waste heat in exhaust gases recovered for
  - Heating process fluids or generating steam in unfired or supplementary fired waste heat boiler
  - Direct process use
  - Use as preheated combustion air




	Saturn	Centaur	Mars
Stack Temperature °F	269	270	282
Steam Output lb/hr	6848	18 886	43,825
Exhaust Temperature °F	835	818	877
Fuel Input million Btu/hr	12.8	38.5	95.4
Electrical Output kW	800	2795	8513
Air Mass Flow thousand lb/hr	49.3	140.1	299.0
Net Fuel Rate Btu/kWh	4979	5075	5790

Turbine Exhaust Used to Produce 15 psi Steam  
with No Additional Fuel Burned



	Saturn	Centaur	Mars
Heat Credit millions Btu/hr	9.55	26.55	63.32
Exhaust Temperature °F	835	818	877
Fuel input million Btu/hr	12.8	38.5	95.4
Electrical Output kW	800	2795	8513
Air Mass Flow thousands lb/hr	49.3	140.1	299
Net Fuel Rate Btu/kWh	4063	4276	3768

Turbine Exhaust Used Directly as Hot Air Source



	Saturn	Centaur	Mars
Stack Temperature °F	250	250	250
Steam Output lb/hr	16 947	48 150	101,633
Additional Fuel to Burner million Btu/hr	11 67	33 76	65 7
Exhaust Temperature °F	835	818	877
Turbine Fuel Input million Btu/hr	12 8	38 5	95 4
Electrical Output kW	800	2795	8513
Air Mass Flow thousand lb/hr	49.2	140.1	299
Net Fuel Rate Btu/kW	3313	3673	3768

Turbine Exhaust with Duct Burner to Supplemental Fire Exhaust  
Temperature to 1700°F in 200 psig Boiler

- o Unit size : 0.1-120MW
- o Electric efficiency
  - Full load : 24-35%
  - 50% load : 19-29%
- o Heat rate
  - Total : 9,250-13,450 kJ/kWh
  - Net : 5,200- 6,150 kJ/kWh
- o Electricity to Steam ratio : 130-215 kWh/GJ
- o Availability : 90-95%



# Ruston TB5000 Gas Turbine Cogeneration Performance

## Gas Turbine Output

Power ..... 3460kW  
 Heat rate ..... 14,130Btu/kWh  
 Fuel flow ..... 2574lb/hr  
 Air flow ..... 45 9lb/sec  
 Exhaust gas ..... 918°F  
 Specific power ..... 75 4kW-sec/lb air

## Operating Conditions

Computer-derived steam curves are calculated for base load output of the gas turbine at 59°F sea level site conditions burning natural gas fuel, with 4-inch water inlet and 10-inch outlet losses, with the exhaust ducted into an unfired single-pressure level waste heat recovery boiler.





# General Electric PG5361 Gas Turbine Cogeneration Performance

## Gas Turbine Output


Power ..... 25,010 kW  
 Heat rate ..... 12,430 Btu/kWh  
 Fuel flow ..... 16,362 lb/hr  
 Air flow ..... 267 lb/sec  
 Exhaust gas ..... 922°F  
 Specific power ..... 93.7kW-sec/lb air

## Operating Conditions


Computer-derived steam curves are calculated for base load output of the gas turbine at 59°F sea level site conditions burning natural gas fuel, with 4-inch water inlet and 10-inch outlet losses, with the exhaust ducted into an unfired single-pressure level waste heat recovery boiler.



## COMBINED CYCLE SYSTEMS



Combined cycle for power generation.



Combined cycle for power and process heat generation.

- o Unit size : 4-120 MW
- o Electric efficiency
  - Full load : 34-40%
  - 50% load : 25-30%
- o Heat rate
  - Total : 7,600-9,500 kJ/kWh
  - Net : 4,750-5,700 kJ/kWh
- o Electricity to Steam ratio : 165-300 kWh/GJ
- o Availability : 80-85%



## DIESEL ENGINE SYSTEMS

### o Diesel engine types

Type	Speed (rpm)	Power (MW)	Cycle	Efficiency (%)
High speed	> 900	0.1-1	4 stroke	34
Medium speed	400-900	1-10	2/4 stroke	38
Low speed	< 200	5-30	2 stroke	40

o Unit size : 0.1 - 30 MW

### o Electric efficiency

- Full load : 33-40%
- 50% load ; 32-39%


### o Heat rate

- Total : 7,850-9,750 KJ/kWh
- Net : 5,700-7,100 KJ/kWh


o Electricity to steam ratio : 330-660 kWh/GJ


o Availability : 80-90%

# Hoffmann-La Roche Diesel Cogeneration System





# Energy Flow Diagram For Diesel Cogeneration System






**Bottoming Cycle Concept**




## FUTURE TECHNOLOGIES

- o Fluidised bed boiler - Steam turbine system
- o Pressurised fluidised bed boiler - Gas turbine system
- o Coal gasification combined cycle system
- o Fuel cells
- o Stirling engine systems



**Cogeneration Systems Total Installed Costs\***



Cogeneration Systems Operation and Maintenance Costs




## COGENERATION SYSTEM SELECTION AND DESIGN

### o Technical factors


- Electricity requirement
- Thermal energy requirement : temperature level, quantity
- Daily, monthly, seasonal variation in electricity and thermal energy demands
- Balance between electric and thermal demand
- Fuels availability
- Retrofit vs. new installation
- System reliability
- Operation and maintenance aspects

### o Economic factors

- Available capital
- Rate of return required
- Energy costs
- Buy-back rates



Match between process and energy-conversion system (ECS) when power-heat ratio of ECS is greater than required.



Match between process and ECS when power-heat ratio of ECS is less than required.

## INSTITUTIONAL AND REGULATORY ASPECTS

- o Legislation enacted in a number of countries, e.g., U.S.A., U.K., France etc. to encourage cogeneration
- o In the U.S., PURPA (Public Utility Regulatory Policy Act, 1978) requires utilities must buy power offered by cogenerator at its avoided cost at a negotiated rate
- o Major issues pertain to both utility and cogenerator concerns
  - Conditions for purchase of cogenerated power by utility
  - Purchase rates
    - Avoided cost concept
    - Time (peak, off-peak) or seasonal component
  - Interconnection
  - Wheeling
  - Banking
  - Effect of dispersed cogenerators on grid
  - Effect of grid perturbations on cogeneration system

### Co-Generation Potential

Industry	No. of Units Surveyed	Total power demand MW	Co-gene- ration potential* MW
Pulp & Paper	3	37.5	56.0
Refineries	4	37.3	40.0
Rayon	3	17.1	28.0
Chemicals	9	33.0	47.0
Fertilisers	9	193.0	250.0

\* The co-generation potential has been determined, on a site by site basis, with regard to suitably tailored power-steam cycles.

### Co-Generation Investments

Type of Unit	Captive genera- tion possible (MW)	Incremen- tal Investment (Rs. lakhs)	Incremental Investment (Rs./KW)
Pulp & Power (200 tonnes/day)	28	576	2057
Rayon (4000 tonnes/annum)	14	342	2630
Chemicals (Polymer —30,000 tonnes/ annum)	17.5	384	2194
Fertiliser (Urea— 350,000 tonnes/ annum)	18	400	2222



# **Background Material On Energy Models - Objectives Techniques and Applications**

By .  
**Leena Srivastava**

Prepared for presentation at the Vigyan Bhawan, New  
Delhi for the "Workshop on Energy Management in  
Industrial Sector", November 24-28, 1986.



## What are models

Models are a set of mathematical equations representing the behaviour of any system that has been modeled and modelling is the use of these general mathematical and statistical techniques in either an economic engineering or systems approach.

## What modelling can contribute

Modelling allows us to make systematic use of fragmented pieces of knowledge and expert opinions. One way of looking at modelling is that it permits us to carry out rigorously a weighting scheme that may involve estimating and applying differential weights to hundreds of factors -- be they assumptions or pieces of scientifically derived data. In the case of energy modeling, we deal with science, technology, and human behaviour. In oil refining, for example, we know the physical properties of crude oil and of refined petroleum products. How much of each product is actually to be produced is a decision made by managers and is the result of their analysis of the market, availability of future supply, near-term demand, interest rates, and many other factors.

Through modeling, we can enforce consistent and explicit accounting of energy resources as they move through the production, transportation, transformation, inventory, and consumption phases of their life cycle. Multicriteria analysis allows us to analyze future-



oriented scenarios under different assumptions and competing objectives. Since modeling can be viewed as putting together current knowledge of the real world and the best assumptions and conjectures from experts, the rigors of modeling can identify and help analyze apparently counter-intuitive relationships. Without a model, these would be more difficult or impossible to uncover.

Another contribution of modeling is that it allows simultaneous examinations of various interrelated parts of the energy and economy systems. While energy modeling in itself is a valuable input to government and business decisionmakers, carrying out such modeling without explicit consideration of the overall economic environment leads almost surely to incomplete and potentially misleading results.

While acknowledging the potential value of modeling to the consideration of energy issues, we may not really be able to measure the specific contributions of energy modeling. What tests of success should we use? Consider an example from the private business sector. A simulation model of an oil refining process may be used to manage the production slate of an oil refinery. If the model does not correctly calculate outputs of various products, then it can be fine-tuned until it meets design specifications. On the other hand,

in a public agency responsible for energy information, the goal is to support decision-makers dealing with less well-defined problems. Models can assist a policymaker by:

- . helping him think through a set of options systematically;
- . identifying critical points or decision points for possible policy action;
- . identifying robust aspects of policies or energy/economy systems with respect to key uncertainties; and
- . providing fairly specific projected outcomes that would result from alternative decisions.

Prior to trying to assess the value of a model to a policymaker, we should have answers to questions such as the following:

- . What are the costs of not having projections or a comparative analysis of more than one option?
- . How much of a policy decision was based on the output of a model? How much did each of several models contribute?
- . Did the models help the policy-makers to organize their thoughts--to clarify or focus any decisions?

Without answers to these questions, we are simply left with: "Is the policymaker better off with the model solution or not?" Another way to think of that is, "What are the costs of not knowing?"

While energy models may allow us to make systematic, differentially weighted use of knowledge and assumptions, the extent of which they do this thoroughly and well is the key to giving the policymaker the benefits of assimilation of a mass of input and reduction of complexity.

### Policy Models And Engineering Models

The models being used in the energy field can be divided into two kinds, policy models and engineering models. The latter are concerned with design of systems, with technical questions about how to construct things, with physical inter-relationships, etc. The former are concerned with decision making, with the social, economic, and environmental interfaces of the energy problem, with strategies and policies for meeting desired energy goals, and so on. It is fairly easy to assess the value of an engineering model. Policy models are not so easy to assess. For, these models are usually used to make policies with a relatively long time horizon. Also, it is hard to assess the relative role played by a model in a policy decision. The final decision is based on many inputs, not just that from the

model, and even where the decision is heavily influenced by a model, the final implementation might be somewhat different than that recommended by the model.

The model builder needs to define the policy question in order to decide what kind of detail to build into the model to make it useful. The policy maker must know what kind of policy question he has to answer in order to determine what type of model would be suitable for answering it. As there is no model appropriate for all purposes. Therefore an articulation of the policy question to be answered is mandatory. Accordingly, a model can be evaluated only in terms of its usefulness for responding to a particular type of policy question. Also relevant for this evaluation is the time frame in which the policy question applies - some models are clearly appropriate for short-run analysis and others are applicable only in the long-run.

### Criteria For Model Choice

Once the policy question and a time frame have been established, the criteria for choosing a model come into play. From both the user's and the model builder's point of view, the following considerations should be taken into account:

- 1) a theoretical structure that incorporates functional demand, that is, demand for a particular service, and not for a particular tupe of energy

- 2) the effect of price
- 3) the effect of technological change
- 4) fuel substitution possibilities
- 5) a scheme for data disaggregation that can conveniently be aggregated to summarize results
- 6) the constraints of the natural resource base
- 7) the treatment of environmental effects
- 8) accuracy
- 9) level of aggregation
- 10) time horizon
- 11) cost.

For regression models a more specific list of characteristics are:

- 1) disaggregation by sector, region, and fuel type
- 2) the inclusion of price effects
- 3) attention to the theoretical structure of demand
- 4) a distinction between the capital stock of energy using equipment and the energy usage pattern.

### Conditions for Effective Model Utilization in Policy Decision-Making

#### 1., Technical Quality

The models and analysis should be technically sound.

## 2. Focus

The models and the analysis should quantify answers to specific policy questions, and estimate the impact of alternative ways of answering those questions.

## 3. Timing

The timing of the analytical or modeling effort should be right.

## 4. Credibility of Output

## 5. Communication of Results

Either the decision-maker is trained in the skills of quantitative analysis and modeling or, more commonly, someone like a "translator" is involved.

## Techniques for Energy Modelling

The three most commonly used approaches to Energy Modelling in the current day are econometric modelling, process modelling and systems dynamics modelling. Econometric modelling has its underpinnings in economic theory. A regression equation is not necessarily an econometric model. Equation estimates such as Energy-GDP elasticities are basically correlation analyses of one variable with another. A well-known example of econometrically based energy economy model is the Hudson and Jorgenson Model (1974) in which the factor and production market models are in

an input-output framework but are econometrically estimated.

The engineering or process group of models have their distinguishing features is their planning and their management nature. Programming models in particular provide optimum allocation rule for a particular objective function and set of inequality constraints.

Systems dynamics has emerged as an offspring of the development of computer systems and software. This has provided an extremely flexible tool for modelling complex phenomena from a number of different dimensions (time, space, etc.), enabling hierarchical levels of entry into the model by the model user, the linking of many sub-models.

Some distinguishing aspects of the above approaches are described in the following summary remarks:

- a. Econometric modelling is primarily deductive in nature; it is also behavioural in that underlying optimization behaviour is assumed for producers and consumers. Alternative economic models may be descriptive, analytical, or predictive. Most analysis is conducted at relatively aggregated levels using estimates of "summary" statistics (or analytical measures) such as demand elasticities, elasticities of substitution, and multiplier

estimates. An important feature of econometric modelling is its linkage to economic general equilibrium theory and economic welfare theory which provides the basis for economics (and econometric modelling) as a policy science.

b. Engineering, programming, and other systems of modelling tools are primarily empirical and descriptive in nature. Many programming techniques are used within economic analysis and an overlapping sub-discipline of "engineering economics" uses these techniques in performing cost accounting and cost-benefit analysis of engineering projects. This is a type of analysis distinct from economic modelling since cost analysis is only one aspect of economic analysis. The latter, in principle, would include market and general equilibrium effects, for example, on labour and capital markets (this also applies to pay-back and profitability analysis).

c. Systems dynamics modelling is relatively inductive and sometimes attempts to be "behaviourally realistic" (i.e. depicting actual real world activity in modelling a particular energy-economic system). Simulation analysis, rather than forecasting, is the primary use of these models. The systems dynamics approach is extremely flexible in terms of dealing with complex phenomena and can use a number of modelling methods within any single over-all systems



(e.g. programming for one sub-model, etc.). One inherent limitation of behaviourally realistic system dynamic models occurs in explaining the reasons for a specific simulation result: the reasons within the model for a particular outcome may be as complicated and unclear as they are in the real world.

### Causal forecasting/econometric models

Once estimates of the parameters of an economic model are available, the model can be employed to forecast the dependent variable if the associated values of the independent variables are given. It is this forecasting method, relying on the causal interpretation of the economic model in question, that is usually meant by the terminology 'econometric forecast'. The model used can range in sophistication from a single equation with one or two explanatory variables to a large simultaneous-equation model with scores of variables.

While application of the econometric approach can give a general indication of how energy demand will evolve in response to fuel prices, it should be noted that this response cannot be stated in terms of specific technological changes, even though it is recognized that for a change in energy demand to occur, some change or modification to production technology must take place. Indeed, proponents of the econometric approach would argue that this is one of the advantages of the

approach, in that the effect of technologies yet to be developed can be taken into account (without actually defining them). Of course, for this to be valid, one must suppose that the type of technological response induced by the price changes in the historical period that is subject to the econometric estimation will continue into the future.

### Process Models

An alternative to the econometric approach is that of so-called process model, in which the slate of technological alternatives is explicitly stated, and for which the model then selects the optimum capital expansion path for that industry under some given fuel price trajectory. Obviously, technologies that have yet to be discovered cannot be captured by the model, which is not too serious for short planning horizons, given the very long gestation periods between discovery of a process, and its ultimate commercialization.

A process model can be viewed as a tool to derive energy demand curves for specific industries. That is, for some given level of production, (say  $P$  tons of finished steel per year), and for a given set of energy and non-energy prices, what quantity of energy will be demanded to sustain that level of output. Clearly that will depend on the specific technologies used in the production process, and in particular on the degree to

which capital can substitute for energy.

Consider, as an illustrative example, a very simple model of the steel industry (Figure 7.2). Assume that there are  $J$  steelmaking processes (open hearth, electric arc, etc.), and let the amount of steel produced by each technology be denoted  $x_j$ . Then if the total production level for domestic steel is  $x$ , we require first that

$$\sum_j x_j \geq x$$

Next, let the existing capacity of each type be  $C_j$ . Then it follows that production each process cannot exceed the capacity of existing plus new mills of that type, i.e.,

$$x_j \leq C_j + \bar{C}_j(N)$$

where  $\bar{C}_j(N)$  is the capacity to be added over the planning horizon. In constraint form, in which all endogenous variables appear on the left hand side, (7.2) is written

$$x_j - \bar{C}_j(N) < C_j$$

Suppose there are K energy inputs (different fuels) and L non-energy inputs (labor, iron ore, etc.) and suppose that

$e_{jk}$  represents the unit requirement of energy of type k for process j

$k$  cost per unit of k

$f_{jl}$  represents the unit requirement for the non-energy factor of production l for process j.

l cost per unit of l

then the total industry wide consumption of fuel k is given by

$$\sum_j x_j \cdot e_{jk} = E_k$$

and the industry wide input of factor l is given by

$$\sum_j x_j \cdot f_{jl} = F_l$$

Hence the cost to be minimized is

$$C = \sum_k \lambda_k \cdot E_k + \sum_l \pi_l \cdot F_l + \sum_j C_j(N) \cdot W_j \cdot CRF(i,n)$$

where

$W_j$  is the capital cost for additions of type j.

$CRF(i,n)$  is the capital recovery factor at discount rate i and planning horizon n.

It should be noted that each technological modification of some basis process (such as oxygen landing in open hearth steelmaking) would be represented in the model by a separate  $x_j$ , since sometimes even minor process and conservation modifications will result in drastic changes in the mix of factor (and thus also energy) inputs.

This simple Linear program, then, enables one to predict the future energy consumption in the iron and steel industry as a function of energy and non-energy factor prices, and as a function of the capital costs for different technologies. This is, to be sure, a highly simplified description of the industry. The objective function can be more complex, too, reflecting industry decision criteria that take into account such items as taxes and depreciation allowances, and may be framed in terms of a minimization of net present value rather than minimization of an equivalent annual cost. A dynamic version may also be necessary to be more precise in estimating the capacity expansion path of the industry.

Simulation models differ quite fundamentally to optimization models. An optimization model can be represented by

$$\text{Max (or Min) } f(x);$$

$$\text{-subject to } g(x) = 0$$

that is, some function of  $x$  is optimized subject to a set of constraints on  $x$ ; if the objective function and the constraint set are linear equations in  $x$ , and  $x > 0$ , we then have so-called linear programming model, many applications of which we have already discussed. In contrast, a simulation model can be represented simply by

$$h(x) = 0.$$

As an example, consider the following set of equations that link price, investment and consumption of some energy form:

$$Q = \alpha \lambda^\beta \quad (10.1)$$

$$I = Y(Q - Q_0) \quad (10.2)$$

$$= \frac{I}{Q} + \quad (10.3)$$

where

$\lambda$  = price

$Q$  = consumption (demand)

$I$  = investment

and where  $\alpha$ ,  $\beta$ ,  $Y$ ,  $Q_0$ , and  $\lambda$  are constants.

We thus have three simultaneous equations in three unknowns: because they are non-linear (for example, equation (10.3) involves a term that includes both  $I$  and  $Q$ ), this cannot be solved by a standard elimination procedure (as one could in the case of a set of linear simultaneous equations). However, there are a number of iterative methods that can be used.

A major advantage of such simulation models is that we are not limited to linear functions: thus price-investment relationships can be captured with a greater degree of realism -- recall, for example, the difficulties of treating scale economies and fixed charges in the linear programming formulation. Indeed, in the simulation framework the functional relationships

can be quite arbitrary -- although convergence properties may not be quite as well behaved as in the above hypothetical example. The major disadvantage of a simulation model, however, is that single run of the model rarely provides much in the way of policy guidance: alternative policies must each be simulated in turn, and the optimal policy evaluated on the basis of comparison of each run. Obviously, such a procedure only guarantees a local optimum: that is, we can identify the best choice from among the finite number of policy simulation runs. This contrasts with, say, the linear programming model, whose solution can be shown to be the global optimum (i.e., the optimum from among the almost infinite number of feasible solutions) -- always assuming we meet all of the necessary conditions of linearity and convexity.

### The Perils of Policy Modeling

Modeling for policy use is always difficult, and energy/economy modeling is especially difficult. First we must acknowledge that each time we choose a particular formulation concerning the functioning of markets, the general structure of a national economy, or a relationship between the energy component and the economy as a whole, we expose our modeling efforts to the problems and pitfalls of the underlying theory behind the structure we adopt.

The most obvious limitations of energy models or for that matter any model is their incompleteness. Any representation of reality cannot be true in every detail: at best one abstracts from reality those elements that are important and suppresses unessential details. Particularly interesting from this point of view is the trade-off between time and energy. This trade-off between energy and time is so fundamental that it often goes unnoticed in discussions of energy policy.

The other important limitations of models is concerned with uncertainty. There are two sources of uncertainty - in parameters and intrinsic indeterminacy, because of the mathematical structure of the system, because of the underlying intractability of the world that is to be modeled. Most models depend on parameters often derived from historical time series. The question that arises here is on the accuracy of any forecasts/analysis based on these parameters (for ex. price elasticities) which are based on historical time series data ranging probably over a wide span.

### Conclusions :

Energy problems are so large and so complex that existing technical tools and capabilities are overwhelmed by them. New and more powerful mathematical or computational tools must be developed and obviously one way to improve the performance of modeling is to



make such new tools widely available to model builders.

It should be emphasized, however, that the development of new technical tools will not be enough to bridge the gap between the complexity of energy problems and the lack of power of existing tools. Energy problems are sufficiently complex that it is likely that any policy model used to study them will be required to make rather strong simplifying assumptions in order to be mathematically and computationally tractable. What is required, then, is a new attitude about the role of models, which is different from the traditional engineering attitude. Models in policy analysis have a different role to play, as one of a number of devices to gain intuition and understanding about complicated systems, when it is hopeless to gain the same level of understanding as one can about a machine or a plant. One of the reasons that many decision makers are disappointed in the assistance provided by models is that they are used to the very definitive, "right or wrong" kinds of answers attainable from engineering models, and expect too much of policy models. Hence, one of the methods for improving the performance of models is not so much improving their performance per se, but changing expectations about this performance. In sum, models used to make policy should be thought of as learning and communication devices, used to identify and assess alternatives, make precise otherwise hard to


specify ideas, and used to assist in thinking carefully about complicated interconnections, relationships, etc. If one emphasizes the learning aspects of modeling, and de-emphasizes the role of the model as the final source of a decision, a big step has been taken in putting models in their proper place.

Now if one accepts the idea that a model is a learning device, it follows that the user must participate in the modeling exercise as much as possible so as to benefit from the educational experience. There is one other point that goes along with this last one. A decision maker should not ask a model to provide a single number for an answer. Nor should the decision maker make too much of any numbers which are produced. He should be more concerned with the pattern or general direction of effect predicted.



1

Storage, handling  
and preservation  
of fuel oil





# Introduction

In many industries, little attention is often paid to oil storage, handling and preparation facilities. The result? Puddles of oil near the pump house and storage tanks—an indication of leaky joints, flanges and pipelines. Clogged filters, which impose an additional duty on the pumps. And poor combustion, manifested by smoky or spluttering flames leading to high fuel consumption.

Spilt oil is an easily avoidable waste, and renders the ground slippery and dangerous. For efficient burning, foreign matter such as dust, water, coke and sludge particles in fuel oil should be removed by adequate filtration. It is also necessary to examine several aspects, such as pumpability of oil during winter months, the type and capacity of the pump, the length of the pipelines, and the sizing of pipes. Correct preheating of fuel oil prior to combustion is also important for fuel efficiency. We shall cover some of these aspects, which have a significant effect on the fuel consumption in your plant.




Fig. 1—GENERAL LAYOUT OF STORAGE, HANDLING AND PREPARATION OF FURNACE OIL

## Stop that leak

Spilt oil is irretrievable. A little care when oil is decanted from the tanker to the storage tanks could lead to less spillage. All leaks from joints, flanges and pipelines must be attended to at the earliest.



Fig. 2

Loss of even one drop every second can cost you over 4,000 litres a year.

## How to store furnace oil

It is wrong and wasteful, even dangerous, to store oil in barrels. Furnace oil is best stored in cylindrical tanks either above or below the ground. Generally, the main storage tank is erected above ground when the capacity exceeds 70,000 litres. For lower capacities, underground storage may be more economical. When erecting a storage tank above ground, remember to maintain safety distances from the surrounding structures, as prescribed by the Explosives Department.

Storage tanks are generally made from welded mild steel plates. The overhead tank should be mounted on concrete blocks, which provide a slight gradient of 1:50 towards the drain valve.




Fig. 3—DETAILS OF STORAGE TANK

Each of the following fittings has a definite role to play. Perhaps your tank does not have some of them.

**The outlet or draw-off pipe** should be located at the raised tank end, no less than 15 cms. from the bottom.

**The vent pipe**, of gooseneck type, should be located at the highest point of the tank to facilitate filling by venting air and oil vapour during the filling operation. It should be at least 5 cms. in diameter and provided with a strainer at the outlet.

**The fill-pipe** could be located either at the top or at the bottom of the tank. If located at the top, it must be ensured that the pipe descends almost to the bottom of the tank. When located near the bottom, it is important to position a non-return valve on the line to avoid furnace oil re-entry into the tank-truck on account of back pressure. To avoid leakage of oil during decanting, it is advisable to have a camlock coupling at the filling end so that it fits snugly on the delivery hose.

**The drain pipe**, which is fitted at the lower tank end bottom, is used to periodically remove the accumulated water. It is a difficult task to drain the water and sludge from underground storage tanks. The water and sludge which settle down at the bottom should, however, be removed by a handpump. It would be advantageous to have two suction pipes—one at a lower level and the other at a higher level—so that in case the sludge accumulation is up to the lower point and the suction line chokes up, the alternative line could be put into operation and adequate time would be available to decide upon a time schedule for cleaning the tank.

Furnace oil as delivered may contain dust, dirt, gummy matter and water. During storage for prolonged periods, these tend to form sludge which accumulates in the various 'dead spaces' of the tank, where the oil is not agitated during

normal operations of the tank. This results in unsteady flames and clogging of filters. To avoid this, some means of agitation of oil in the tank may be necessary.

Cleaning of storage tanks, about once a year, will remove the accumulated sludge. Besides cleaning, periodic inspection and maintenance of the storage tank and auxiliaries is important.

## The service tank

In addition to the main storage tank(s), industries may have one or a number of day service tanks located in proximity to the units consuming oil.




Fig. 4

The principles enumerated earlier for the maintenance of main storage tanks apply here too. The service tank may be sized for a shift's consumption or daily consumption—the choice depends on capacity required, ease of location of tank near the shop, pumping capacity, horse power, etc. Certain additional precautions may, however, be taken with respect to service tanks:

- Service tanks should not be located very near or above furnaces, hot air or process ducts, etc.
- They may be provided with overflow pipes which lead directly below to a sump. As a further refinement, limit switches could be provided to avoid the possibility of oil overflow.
- In gravity feed systems, the difference in height between the service tank and the burners should be at least 10 metres.

## Why pay more for receiving less?

Do you check how much oil you actually receive? Are you paying more for receiving less? It would be worth your while to check the quantity of oil decanted into the storage tank. Road tankers are provided with dipsticks. Readings of oil level in the various compartments should be taken before decantation. The following procedure may be adopted before assessing the quantity of oil in the road tankers :-

- Ensure that the tank lorry is parked on firm level ground.
- The dipstick should be checked to ensure that it is the one calibrated by the Weights and Measures Department for the compartment concerned.
- The dip readings of all the compartments should be checked, and shortfall, if any, can be determined by topping up of the compartments with measured quantities of furnace oil from the main storage tank.
- If the tank truck has been filled hot, the product in the compartment is likely to shrink to the extent of 0.7 litre/KL per degree centigrade fall in temperature. If the shortfall is higher, it may be due to pilferage.
- Your storage tanks should also be calibrated. Though dip readings in storage tanks are more or less reliable, a major deviation should be investigated. They may provide a clue to malpractices.

## Removal of contaminants

Furnace oil should be freed from possible contaminants such as dirt, sludge and water before it is finally fed to the combustion system.

Furnace oil arrives at the factory site either in tank lorries by road or by rail. Oil is then decanted into the main storage tank. To prevent the possibility of contaminants such as rags, cotton waste, loose nuts or bolts or screws from entering the system and damaging the pump, position a coarse strainer of 10 mesh size (not more than 3 holes per linear inch) on the entry pipe to the storage tanks. Progressively finer strainers should be provided at various points in the oil supply system to filter away finer contaminants such as external dust and dirt, sludge or free carbon. It is advisable to provide these filters in duplicate to enable one filter to be cleaned while oil supply is maintained through the other. Fig. 5 gives an illustration of the duplex system of arrangement of strainers.






Fig. 5—ARRANGEMENT OF STRAINERS IN A PIPE LINE

### Sizing of strainers

Location	Strainer Sizes	
	Mesh	Holes/Linear inch
Between rail/tank lorry decanting point and main storage tank	10	3
Between service tank and pre-heater	40	6
Between pre-heater and burner	100	10

## A sluggish problem

Our problem now is only partially over. Furnace oil increases in viscosity as temperature drops, which makes handling a little difficult, particularly in winter. At low ambient temperatures (below 25°C), furnace oil is not easily pumpable.

### Recommended preheat temperature for pumping

Oil grade	Preheating required for easy pumping
Diesel/LDO	No heating
80 Cs at 50°C (600 RW <sub>1</sub> at 100°F)	10°C
125 Cs at 50°C (1000 RW <sub>1</sub> at 100°F)	20°C
170 Cs at 50°C (1500 RW <sub>1</sub> at 100°F)	25°C
370 Cs at 50°C (3500 RW <sub>1</sub> at 100°F)	35°C
LSHS	70°C

The preheating of oil in the storage tank to render it pumpable can be accomplished in two ways. Either the entire tank can be maintained at the pumping temperature (bulk heating) or an outflow heater may be fitted to heat the oil as it flows out. Bulk heating, which uses steam coils (Fig. 6) positioned at the floor of the tank, requires additional heat to compensate for the heat losses from the tank surface. To

reduce steam requirements, it is advisable to insulate where bulk heating is used.

In the case of outflow heating, only the oil which leaves tank is heated to the pumping temperature.




Fig 6—BULK HEATING

While the outflow heater is the preferred choice, bulk heating may be necessary where flow rates are so high that outflow heaters of adequate capacity cannot be easily installed, or when using special fuels such as low sulphur heavy stock (LSHS).

The outflow heater is essentially a heat exchanger, with steam or electricity as the heating medium. The heater protrudes from the suction connection into the oil space. (Fig.7)

### Important

Thermostatic temperature control of the oil is necessary to prevent overheating, especially when oil flow is reduced or stopped. This is particularly important for electric heaters.

since oil may get carbonised when there is no flow and the heater is on.

Thermostats should be provided at a region where the oil flows freely into the suction pipe.




Fig 7—OUTFLOW HEATING

## Preparation of furnace oil for combustion

The preheating of furnace oil in the storage tanks renders it pumpable. However, furnace oil generally has to be heated further so that its viscosity is appreciably lowered to suit the burner. This operation is extremely vital if we are to ensure that furnace oil is properly atomised by the burner—an essential condition for efficient combustion. A thermometer should, therefore, be provided on the oil line.

A temperature viscosity chart could be used to obtain the correct preheat temperature. (Fig. 8) For example, manufacturers of low air pressure burners generally specify a viscosity 100 Redwood seconds No. 1 at the burner tip. With the furnace oil generally marketed now (1500 Redwood seconds No. 1 at 38°C), this would need preheating around 100°C.

The oil can be preheated by either electricity or steam. The capacity of the preheater depends on the oil flow rate and the required rise in temperature.

## Oil preheater capacities for 100°C rise in temperature

Oil Flow rate (litres/hr.)	Preheater capacity (kw)	Steam requirements (kg/hr.)
5	0.5	1
10	1.0	2
15	1.5	3
20	1.5	4
25	2.0	5
50	3.5	10
Every additional 50 litres/hr.	Additional 3.5 kw is necessary.	Additional 10 kg/hr. capacity is necessary.

It is essential that preheaters are provided with a thermostatic control to prevent oil carbonisation when flow is stopped. It would be a good practice to insulate the preheater as well as the oil delivery line from the preheater right up to the burners. During start-ups, cold oil may be present in the oil lines upstream of the preheater. It should be drained by providing suitable drain cocks on the line.

## Pump capacity

It is advisable to use a positive displacement pump such as a gear pump, for pumping furnace oil. Sometimes no oil gets transferred through the pipes because of excessive pressure drop and cavitation at the pump. A centrifugal pump is therefore, not recommended, as the oil viscosity increases, the efficiency of the pump drops sharply and the horse power required increases.

It is also necessary to size the pipelines properly so that there is no excessive pressure drop and the required oil flow rates are obtained. On expansion of facilities, the adequacy of pipe sizes for transporting larger quantities of oil should be reviewed. It is preferable to lay the oil pipelines over ground as any oil leaks would then be visible and could be quickly attended to.

Fuel oil has to be pumped from the main storage tank to the day service tank. Depending upon the desired quantity of oil to be pumped, and the distance between the storage tank and the service tanks, adequate pumping capacity will have to be provided.




Fig. 8— VISCOSITY—TEMPERATURE RELATIONSHIP OF FURNACE OIL

The following is a step-by-step procedure to help you in estimating the horse power requirements of your pump.

### 1) Determination of equivalent length (L)

$$L = L_1 + L_2$$

where:

$L_1$  = Actual length of pipeline in meters.

$L_2$  = Equivalent length of fittings in meters.

The table below gives values of equivalent length of fittings ( $L_2$ ) for different diameters of pipes. Equivalent length of a 90-degree standard elbow on 100 mm diameter pipeline =  $30 \times 100 = 3000$  mm  
= 3 metres

### 2. Determination of friction loss in pipes

This may be estimated by using the following formula:

$$h_f = \frac{\mu L Q \times 10^3}{D^4}$$

where:

$h_f$  = Friction loss in pipes in metres.

$Q$  = Oil flow rate in KL/hr.

$D$  = Diameter of pipe in mm.

$\mu$  = Viscosity of oil in centistokes.

$L$  = Equivalent length of pipeline.

### 3. Determination of total head (H)

The total head to be overcome by the pump ( $H$ ) =  $h_1 + h_2$

where:  $h_1$  = Friction loss in pipelines in metres.

$h_2$  = Height in metres through which oil has to be lifted (difference in height between the levels of oil in the service tank and storage tank).

### 4. Determination of pump horse power

This may be arrived at by using the following formula:

$$\text{Pump HP} = \frac{Q \times H}{270 \times \eta} \quad (\text{Approximately})$$

where:  $Q$  = Fuel oil flow rate in KL/hr.

$H$  = Total head in metres.

$\eta$  = Efficiency of pump (around 0.6 for gear pumps).

### EQUIVALENT LENGTHS

#### FITTINGS/VALVES

#### EQUIVALENT LENGTH (L) IN PIPE DIAMETERS (D)



90° DEGREE  
STANDARD ELBOW

30



45° ELBOW

16




90°  
LONG SWEEP ELBOW

20



STANDARD TEE

20



STANDARD TEE  
THROUGH SIDE OUTLET

60



GATE VALVE

— 3/4 CLOSED  
— 1/2 CLOSED  
— 1/4 CLOSED  
— FULLY OPEN

35

160

900

13



GLOBE VALVE, OPEN

350



CHECK VALVE

(CONVENTIONAL SWING  
FULLY OPEN)  
CHECK VALVE  
(GLOBE LIFT)

135

350

# A check list

## Daily checks

- 1) Oil temperature at the burner.
- 2) Oil/steam leakages.

## Weekly tasks

- 1) Cleaning of all filters.
- 2) Draining of water from all tanks.

## Yearly jobs

- 1) Cleaning of all tanks.

## Remember

- \* **Spilt oil is irretrievable. Plug all leakages.**
- \* **Impurities in furnace oil affect combustion. Filter oil in stages.**
- \* **Oil has to be preheated to obtain the right viscosity to the burner. Provide adequate preheater capacity.**

# Trouble shooting hints

<b>Oil not pumpable</b>	Viscosity too high Blocked lines and filters Sludge in oil Leak in oil suction Vent pipe choked
<b>Blocking of strainers</b>	Sludge or wax in oil Heavy precipitated compounds in oil Rust or scale in tank Carbonisation of oil due to excessive heating
<b>Excessive water in oil</b>	Water delivered alongwith oil Leaking manhole Seepage in case of underground tank Ingress of moisture from vent pipe Leaking heater steam coils
<b>Pipe line plugged</b>	Sludge in oil High viscosity oil Foreign materials such as rags, scale and wood splinters in line Carbonisation of oil

## REFERENCE:

1. The Efficient Use of Fuel—HMSO, London.
2. Spirax-Sarco Manual on 'Fuel Oil Heating'—Spirax Sarco Ltd., Cheltenham GL 53 8ER.
3. The Storage And Handling of Petroleum Liquids—John R. Hughes, Charles Griffin & Co. Ltd., London.


**This booklet is one of a series on fuel oil conservation, others in the series are listed below:**

- 1) Combustion of fuel oils & Burners—operation and maintenance.
- 2) Efficient generation of steam.
- 3) Efficient utilisation of steam.
- 4) Fuel economy in furnaces and waste heat recovery.
- 5) Refractories.
- 6) Thermal insulation.

**PCRA films available for industrial sector:**

- 1) "Tuning of Boilers and Furnaces".
- 2) "Handling of Fuel Oils".
- 3) "Efficient Utilisation of Steam in Industries"  
(under production).

Set up a few years ago in anticipation of the world-wide oil crisis that's affecting us all today, PCRA seeks to promote efficient utilisation of petroleum products—in homes, in industries, in farms, on roads. Because till alternative sources of energy are found, we have to make the best use of the world's diminishing oil reserves.




## **PETROLEUM CONSERVATION RESEARCH ASSOCIATION**

Petroleum Conservation Research  
Association, 1008, New Delhi House,  
27, Barakhamba Road, New Delhi - 110 001.

## **SAVE OIL.**

**Because oil isn't going to last forever.**

# Combustion of fuel oils & Burners-operation and maintenance








# Introduction

A boiler or furnace utilises the heat generated by combustion of fuel to heat water or air or any process material. The efficiency of a boiler or furnace will depend on how efficient the combustion system is and secondly how best the generated heat is utilised.

Combustion of oil is effected by means of a burner, which mixes fuel and air in proper proportions for complete combustion and the consequent release of heat energy. This booklet explains the principles of good combustion and provides guidelines for the proper selection and maintenance of fuel oil burners for boilers and furnaces.



(Fig. 1)

## Basic combustion reactions

Carbon and Hydrogen are the principal constituents of any petroleum fuel. Sulphur is present in significantly lower percentages. In any combustion process, the reaction between fuel and Oxygen in the air releases heat energy. The combustion products are primarily Carbon Dioxide (CO<sub>2</sub>), water vapour (H<sub>2</sub>O) and Sulphur Dioxide (SO<sub>2</sub>) which pass through the chimney along with the Nitrogen (N<sub>2</sub>) in the air, as shown in Fig. 1.

After surrendering useful heat in the heat absorption area of a furnace or boiler, the combustion products or flue gases leave the system through the chimney, carrying away a significant quantity of heat with them.

Carbon, Hydrogen and Sulphur in the fuel combine with Oxygen in the air to form Carbon Dioxide, Water Vapour and Sulphur Dioxide, releasing 8084 Kcals, 28922 Kcals & 2224 Kcals of heat respectively. Under certain conditions, Carbon may also combine with Oxygen to form Carbon Monoxide, which results in the release of a smaller quantity of heat (2430 Kcals/kg of carbon).

$C + O_2 \rightarrow CO_2 + 8084 \text{ Kcals/kg of Carbon}$   
 $2C + O_2 \rightarrow 2CO + 2430 \text{ Kcals/kg of Carbon}$   
 $2H_2 + O_2 \rightarrow 2H_2O + 28,922 \text{ Kcals/kg of Hydrogen}$   
 $S + O_2 \rightarrow SO_2 + 2,224 \text{ Kcals/kg of Sulphur}$

$C + O_2 \rightarrow CO_2 + 8084 \text{ Kcals/kg of Carbon}$

$2C + O_2 \rightarrow 2CO + 2430 \text{ Kcals/kg of Carbon}$


$2H_2 + O_2 \rightarrow 2H_2O + 28,922 \text{ Kcals/kg of Hydrogen}$

$S + O_2 \rightarrow SO_2 + 2,224 \text{ Kcals/kg of Sulphur}$


By a reaction of Sulphur Dioxide with Oxygen, if excess air is used for combustion, Sulphur Trioxide ( $SO_3$ ) may also be formed as a combustion product.

## Ideal or stoichiometric combustion

Fig. 2 shows the ideal combustion process for burning one kg of a typical fuel oil containing 2% sulphur, 86% carbon and 12% hydrogen. Use is made of theoretically required minimum quantity of air, i.e., 14.1 kg (containing 3.27 kg of Oxygen and 10.83 kg of Nitrogen). Carbon reacts with Oxygen to form 3.15 kg of Carbon Dioxide and Hydrogen reacts with Oxygen to form 1.08 kg of water. Nitrogen in the air does not take part at all in the reaction. Carbon is fully converted to Carbon Dioxide releasing full heat. In addition, Carbon Dioxide, along with Sulphur Dioxide, constitutes 15.76% by volume of flue gases.




(Fig.2a)



HEAT BALANCE OF A COMBUSTION CYCLE

Fig. 2




COMPOSITION BY VOLUME

(Fig.2b)


# Optimising excess air

We have seen that we need 14.1 kg of air for every kg of fuel oil for complete combustion. This is the minimum air that would be theoretically needed if mixing of fuel and air by the burner is perfect. In actual practice, since mixing is never perfect, a certain amount of excess air is needed to complete combustion and ensure the release of the entire heat contained in fuel oil. If too much air than what is required for completing combustion is allowed to enter, additional heat would be lost in heating the surplus air to the chimney temperature. Less air would lead to the incomplete combustion and smoke. More air would lead to increased stack losses. Hence, there is an optimum excess air level for each type of fuel. Fuel savings are the most at the optimum excess air level.




(Fig.3b)

OPTIMUM EXCESS AIR




(Fig.3)

TOO LOW EXCESS AIR




(Fig.4)

AIR SHUTTER OPEN TOO WIDE








(Fig.3a)


TOO HIGH EXCESS AIR



(Fig.4a)


EXCESSIVE AIR LEAKS INTO FURNACE





(Fig.4g)

AIR BLOWER OF INADEQUATE CAPACITY.



ATOMIZATION OF  
OIL UNSATISFACTORY

(Fig.4h)


SIZE	WITHOUT	SECONDARY
	AIR	AIR
00	1-6.5	1-13
0	3-11	3-22
1	6-27	6-54
2	20-56	20-112
4	30-100	30-200
6	50-180	50-360

BURNER RATING TOO HIGH

(Fig.4i)

An experienced operator often relies on the smoke emitted by the chimney or the colour of the flame to help him adjust air at the optimum level. However, a chemical analysis of flue gases is a more objective method that helps in achieving finer air control.

### CHANGES IN FLUE GAS COMPOSITION WITH EXCESS AIR




(Fig.5)

By measuring either the content of Carbon Dioxide (CO<sub>2</sub>) or Oxygen (O<sub>2</sub>) in flue gases, it is possible to estimate the percentage of excess air in flue gases. Continuous recording instruments, as well as cheaper portable instruments are available. (See section on Flue Gas Analysis.)

In ideal combustion, Carbon Dioxide and Sulphur Dioxide together constitute 15.76% by the volume of flue gases. As excess air increases, the concentration of these gases (CO<sub>2</sub> & SO<sub>2</sub>) decreases and the concentration of oxygen steadily increases in the flue gases. This forms the basis for determination of excess air through chemical analysis.

If the temperature of flue gases at the point of the sample is also known, the heat content in flue gases at that point can be estimated. In case flue gas analysis and temperature are measured at the exit of the boiler or furnace, it would thus be possible to estimate stack losses from the graph shown below.



(Fig.6)

When heated, air becomes lighter and begins to rise. The higher the temperature to which the gas or air is heated, the faster it will rise. If this air is heated in a confined space as in a chimney, an upward flow is established. This phenomenon is known as draft.

In natural draft system, excess air can be controlled by dampers placed before the chimney. Measurement of draft helps in setting the damper correctly for various loads. Simple inclined tube manometers can be used to measure the draft.

It must be remembered that there is no precise relationship between the damper position and the amount of draft, i.e., a half-closed damper does not pass just half the quantity of air. As the damper is closed gradually, the draft gauge may not show any significant reduction in draft up to a certain point.

By a trial using flue gas analysis to monitor excess air levels, the correct draft for minimum excess air compatible with smokeless combustion can be determined for various loads. After calibrating the draft gauge for various loads, dampers should be operated to obtain the correct draft for that load.

## Smoke as an indicator of combustion efficiency

Excess air adjustment has a direct relationship with smoke. If a chimney emits a hazy brown smoke, the combustion is proper, but if the chimney emits black smoke, it indicates incomplete combustion and needless fuel wastage. Similarly, a chimney that emits white smoke, indicates too high excess air and hence fuel wastage.


The smoke density can of course be measured by smoke meters, which compare the smoke marking on a filter paper introduced in the flue gas stream with standard markings of varying smoke intensity. Optical instruments using photo cells are also available to monitor the smoke density continuously.

## Flue gas analysis

### Orsat Apparatus

The flue gases may be analysed by means of the Orsat Apparatus.

Flask A contains a solution of Caustic Soda, which readily absorbs the Carbon Dioxide from the sample. Flask B



(Fig.7)

### ORSAT APPARATUS

contains Pyrogalllic Acid and Caustic Soda, which absorbs the Oxygen from the sample. Flask C contains a solution of Cuprous Chloride in Hydrochloric Acid which absorbs the Carbon Monoxide. At the entrance to each of the flasks A, B and C are cocks a, b and c; d is a three-way cock which opens to the boiler flue or to the atmosphere. The measuring tube D is graduated and is surrounded by a water jacket in order to maintain a constant temperature. The flask E is connected to the bottom of D by a long rubber tube, and which contains water. By raising the flask E, the water in it will flow into D, and thus push out any gas inside. By lowering E below the level of D, the water will flow from D back into E, thus causing a suction by which the sample is drawn into D.

#### How to choose a sampling point for flue gas analysis

- \* Avoid sampling at downstream or at points of air infiltration.
- \* Avoid sampling at dead pockets like bends or immediately downstream of dampers.
- \* Choose a point close to the furnace exit.
- \* Use the same point where exit temperature is measured for heat balance calculations.

In order to test a sample of flue gas, the apparatus is connected to the furnace flue near the base of the chimney, cock d being open to the atmosphere, cocks a, b and c being closed. The flask E is held up so that there is 100 cc of water in D. Cock d is then opened to the flue, and E is lowered until a measured quantity of flue gas has been sucked into D. Cock d is now closed to both the flue and the atmosphere. Then, cock a is opened and flask E is raised until the water from E has forced the sample of gas into flask


A; this will absorb the Carbon Dioxide. Pump the sample in and out of the flask several times by raising and lowering flask E. This ensures that all of the Carbon Dioxide is absorbed. The sample is now sucked back into D by lowering the flask E.

The flask E must be held in such a position that the water level in E is the same as the water level in D. This ensures a constant pressure in D while taking readings. The water level in D will now be higher than before by the amount of Carbon Dioxide absorbed; thus the volume of Carbon Dioxide in the sample may be directly read off from the graduations of tube D.


The process is now repeated with flasks B and C, from which the volume of Oxygen and Carbon Monoxide in the sample are also obtained. The amount of Carbon Monoxide absorbed is extremely small and the measurement of its volume is consequently not that reliable.

## Portable absorption analysers


The Orsat Apparatus, though fairly accurate and bulky,




1. PUSH RUBBER CONNECTOR DOWN—THEN SQUEEZE BULB 18 TIMES



2. LIFT FINGER FROM RUBBER CONNECTOR—THIS SEALS ANALYSER



3. TURN BOTTOM SIDE UP AND BACK AGAIN ; TWICE ON CO<sub>2</sub>, FOUR TIMES ON O<sub>2</sub>.




4. READ FLUID LEVEL ON SCALE FOR PERCENTAGE OF GAS.


Fig. 8

### USE OF A PORTABLE GAS ANALYSER






1. WHEN PLUNGER VALVE IS DEPRESSED, GAS SAMPLE IS PUMPED INTO TOP RESERVOIR WHILE CENTRE BORE IS SEALED OFF.



2. WHEN PLUNGER VALVE IS RELEASED GAS SAMPLE IS LOCKED INSIDE THE ANALYSER AND THE TOP RESERVOIR IS OPENED TO CENTRE BORE SO THAT GAS SAMPLE CAN PASS THROUGH ABSORBING FLUID



3. ABSORPTION OF  $\text{CO}_2/\text{O}_2$  BY FLUID CREATES SUCTION WHICH CAUSES DIAPHRAGM TO FLEX UP AND FLUID TO RISE IN CENTRE BORE TO REPLACE GAS ABSORBED

WORKING OF  $\text{CO}_2/\text{O}_2$  GAS ANALYSERS

(Fig. 9)

needs a skilled operator/chemist, it is hence used for spot or occasional checks.

The portable analyser (See Fig. 9) also uses the chemical absorption method. It is quite handy and simple to operate. A sample of flue gases is sucked or aspirated through a filter into the analyser containing caustic soda solution. The change in volume is directly read off on a calibrated scale in terms of percentage of Carbon Dioxide.

A similar apparatus for measuring Oxygen using a solution of alkaline Pyragalol is also available.

## Probe type analyser

These types of analysers have come in vogue recently for oxygen analysis in flue gases. Here, the conventional arrangement for sampling of gases is avoided and it is possible to control air-fuel ratio practically instantaneously. A Zirconia Cell is incorporated in the probe. It has a tendency to develop voltage across the two sides when each side is exposed to different oxygen concentrations. By using air as the reference medium, the concentration of oxygen in the flue gases can be estimated by measuring the voltage developed.

## Other analysers

Absorption of infra-red radiation by the flue gases in various bands is also used in advanced instruments to measure the concentration of various components of flue gases. The property of ionisation and the consequent emission of radiation can also be made use for gas analysis by using a high voltage electrical discharge in flue gases. The radiation emitted is specific in wavelength for various gases and optical filters can be used to select the radiation of interest. The magnitude of radiation is a measure of concentration of the gas of interest. Instruments based on the paramagnetic property of Oxygen, or on the electro-chemical principle, are also used to measure Oxygen content in flue gases.

## General


In most small and medium plants, however, adequate combustion control can be achieved with the use of simple portable instruments based on chemical absorption. The more complex on-line analysers are justifiable for larger installations where continuous monitoring and immediate control of combustion system pays good returns in terms of fuel saved.

# Burners—Operation and maintenance

The purpose of the burner is to convert the fuel oil into millions of small droplets. The process is called atomization and its principal aim is to produce a high ratio of surface to volume in the oil to facilitate evaporation and subsequent combustion. Fortunately, atomization is fairly simple to accomplish since all that is needed is the existence of a high relative velocity between the oil and the atomizing air or steam. In pressure jet atomizers, a high velocity is imparted to the oil by discharging it under pressure through a fine orifice. An alternative approach is to expose the relatively slow moving oil to a high velocity stream of air or steam, the latter method is known as "twin-fluid" atomization.

## Classification of burners

The broad classification of burners may be done based on the principle used for atomization as under:



## Turn-down ratio

The relationship between the maximum and minimum fuel input without affecting the excess air level is called 'Turn-Down Ratio'. For example, a burner whose maximum input is 250,000 Kcals and minimum rate is 50,000 Kcals, has a 'Turn-Down Ratio' of 5 to 1.

In the widely-used low air pressure (LAP) burners, air at low pressure (about 24" water gauge) is provided by a blower

and acts as the atomizing medium. These burners work efficiently at the designed oil flow rate but the efficiency drops sharply as the oil flow rate is reduced at low loads. It is hence necessary to avoid selection of over-sized burners of this type. Air and oil flow rates are regulated by means of valves on the respective supply lines. In the self-proportioning type, it is possible to regulate air and oil flow simultaneously by the operation of a single lever.

In medium and high air pressure burners, air for atomizing is provided by a compressor at higher pressures. When load changes, the quantity of the atomizing air is not changed and only the secondary air entering the system is regulated. Therefore, these burners have better efficiency at even low loads. The compressed air may be replaced by steam as the atomizing medium in these burners. Steam aids in the cracking of oil in the combustion zone and hence steam-assisted atomization is superior for the burning of heavy fuel oils and LSHS. Medium and high air pressure burners should be maintained carefully, since a slight increase in the nozzle size can lead to considerable waste of steam or electric power besides distortion in the spray pattern. Atomizing air forms a lower proportion of total combustion air in these burners. The atomizing air velocity is high and the combustion intensity increases proportionately. For these reasons, these burners are more popular for high temperature furnaces, where combustion air has to be preheated.

Since air at 300°C may crack the oil in the burner, only colder air is fed to the burner for atomization. Hot air is fed into the combustion chamber as secondary air.


Twin-fluid atomizers are of two major types. In the common design, the fuel is injected into the high velocity air stream in the form of one or more discrete jets.

In a rotary cup burner, on the other hand, a thin film of oil is formed by injecting oil into a rapidly spinning cup. This film is converted into minute droplets as it leaves the cup, by the action of the atomizing air which is fed by the burner.


Pressure jet burners are relatively simpler and inexpensive. However, oil flow rate can be reduced in the simple design only by reducing the oil pressure and hence the quality of atomization. Efficient operation at varying loads is usually carried out by using nozzles of various jet sizes.

# Burner blocks


The oil that is atomized by the burner is brought up to ignition temperature in a burner block (or in the furnace, when a burner block is not provided). In a burner block, atomization, mixing with air, evaporation of the oil from the surface of the drops, cracking of oil and the start of




(Fig.10)




(Fig.10a)



ALIGNMENT OF BURNER  
(Fig.10b)



ROTARY CUP BURNER  
(Fig.10c)



PRESSURE JET ATOMISER  
(Fig.10d)

# Burners—Operating parameters

Type of Burner	Pressures	Turn-Down Ratio	% Air for Atomisation	Oil Viscosity at Burner tip (Redwood-Secs. -I)	Capacity Gallons/Hr.
Low Air Pressure	Oil Pressure 8-12 PSIG Air Pressure 24" W.G.	1.4:1 (without Secondary Air) 5:1 (with Secondary Air)	20-25%	70-100 Secs.	1/5-60
Medium Air Pressure	3 to 15 PSIG (Air)	6:1	3-10%	90-180 Secs.	1/2-200
High Air Pressure	Air Pressure 15 PSIG Oil Pressure Higher	Small-5:1 Large-10:1	2-3%	120-200 Secs.	5 to 500
Steam Jet	Dry Steam 25-175 PSIG Oil Pressure Nearly Same	Small-5:1 Large-10:1	Steam 2-5% of Total Output	120-150 Secs.	5 to 400
Pressure Jet	Oil Pressure 50-200 PSIG	Simplex 2:1 Wide Range 6.1 to 10.1	NIL	70-100 Secs.	Up to 3000
Rotary Cup	1/4 to 30 PSIG	4:1	15-20%	150-200 Secs.	3/4 to 250

combustion are completed. Manufacturers of oil burners adapt the cone angle in the burner block to the spray pattern of atomizing devices. Furnace builders sometimes provide additional refractory pieces for directing the flame. It is necessary to maintain the shape of the block and repair where it is damaged. While mounting the burner, care should be taken to align the burner with respect to the block so that the spray or flame does not touch the refractory and see that it is properly directed.

An additional function of the burner block is to protect the oil nozzle from furnace radiation. The block should be sufficiently long and not too wide to minimize the incidence of radiation. At the same time, it should be ensured that the flame does not impinge on the block, as that could lead to clinker formation on the block.

## Factors affecting selection of burners

There is a wide variety of burner types to choose from for any combustion installation. Satisfactory operation

depends to a large extent on the selection of the correct type of burner for an individual case. The choice usually depends upon five main factors:

### i) Range

The range over which the burner will be expected to operate i.e. the ratio of maximum to minimum fuel consumption (also called 'Turn-Down Ratio').

### ii) Temperature conditions in the combustion chamber

In a process involving high combustion temperature, which can be obtained only by burning the fuel with highly preheated air, there is a limit to the temperature of the air which can safely be passed through the burner; in such cases the arrangement must be made to take the greater part of the hot air direct to the combustion chamber. Hence the amount of cold air passing through the burner must be kept to a minimum and for this type of application, a high pressure air or steam atomizing blast burner will be the

correct choice. For such applications, the quality of atomization may be relatively less important and coarse atomization may in certain cases be tolerated if it is required to extend the flame down to a very hot combustion chamber. For very high temperature furnaces, the burner mainly serves the purpose of an ejector of fuel only, the temperature of the environment itself ensures that the fuel will ignite and burn completely.

But some chambers are much colder than the flame, a typical example being the flue tube of a shell boiler. In spite of the high rate of heat transfer from the flame, the walls remain at a temperature virtually that of surrounding water in the boiler. The high rate of heat transfer from the flame to cold wall results in a rapid cooling of the flame, hence the combustion must be quick and complete, i.e. atomization must be good, and air and oil droplets mixing should be very efficient.

### iii) Shape of flame

It is comparatively easy to design a blast burner to give away flame desired from a long and narrow passage with an included angle of (say)  $20^\circ$  to a very wide sunflower type of flame with an included angle of  $180^\circ$ . The wider the flame easier it is to introduce the air among the oil droplets and effecting good mixing. The atomizing air and the air sucked into the root of the flame by the ejector action are together usually sufficient to initiate the combustion, the remainder of the air is gradually sucked into the flame as the combustion proceeds.

In the case of pressure jet atomizers, the spray angle is to a large extent associated with the quality of atomization and it is difficult to obtain a narrow-angle spray from a pressure jet atomizer without sacrificing the quality of atomization. In the case where a burner of pressure jet type is selected for small diameter flame tube, it is necessary to use the momentum of the incoming combustion air to blend with the natural trajectory of the oil droplets to get a flame of narrow shape. For such propositions, if a pressure jet burner is selected rather than a blast burner, it should be supplied with a forced draft to ensure a reasonable air velocity through the air register.

### iv) Combustion intensity

To obtain a high rate of heat release, the combustion process must be expeditious. This is achieved by fine

atomization and high momentum of the combustion air. High combustion intensity is, therefore, obtained at the expense of auxiliary power. In certain cases, high combustion intensity results in improvement in thermal efficiency of the system, which outweighs the loss equivalent to the auxiliary power used for the expenses incurred.

### v) Local conditions and facilities

Local conditions and support facilities also have a definite bearing on the selection of burner(s) for a plant to have normal functioning. There may be limitations on the part of providing required facilities like steam and compressed air, etc. For example, in a re-rolling mill, one may not be able to use a 'steam jet' burner, as it requires steam at certain pressure, even though it has been selected based on various other factors. In that case, one may have to go in either for 'low air pressure' or 'medium air pressure'—air blast burners, as the second best choice considering all the factors.

## Trouble shooting chart for combustion

Complaint	Causes and Remedies
1) Starting difficulty	1) No oil in the tank. 2) Excessive sludge and water in storage tanks. 3) Oil not flowing due to high viscosity/low temperature. 4) Choked burner tip. 5) No air. 6) Strainers choked.
2) Flame goes out or splutters.	1) Sludge or water in oil. 2) Unsteady oil and air pressures. 3) Too high a pressure for atomizing medium which tends to blow off the flame. 4) Presence of air in oil line. Look for leakages in suction line of pump. 5) Broken burner block, or burner without block.

**3) Flame flashes back.**

- 1) Oil supply left in 'on' position after air supply was cut off during earlier shut off.
- 2) Too high a positive pressure in combustion chamber.
- 3) Furnace too cold, during starting, to complete the combustion (when temperature rises, unburnt oil particles burn.)
- 4) Oil pressure too low.

**4) Smoke and soot.**

- 1) Insufficient draft or blower of inadequate capacity.
- 2) Oil flow excessive.
- 3) Oil too heavy and not preheated to the required level.
- 4) Suction air holes in blower plugged.
- 5) Chimney clogged with soot/ damper closed.
- 6) Blower operating at too low a speed.

**5) Clinker on refractory.**

- 1) Flame hits refractory since combustion chamber is too small or burner is not correctly aligned.
- 2) Oil dripping from nozzle.
- 3) Oil supply not 'cut off' before the air supply during shut-offs.

**6) Coking of fuel in burner.**

- 1) Nozzle exposed to furnace radiation after shut-off.
- 2) Burner fed with atomizing air over 300°C.
- 3) Burner block too short or too wide.
- 4) Oil not drained from nozzle after shut off.

**7) Excessive fuel oil consumption.**

- 1) Improper ratio of oil and air.
- 2) Burner nozzle oversized.
- 3) Excessive draft.
- 4) Improper oil/air mixing by burner.
- 5) Air and oil pressure not correct.
- 6) Oil not preheated properly.

7) Oil viscosity too low for the type of burner in use.

8) Oil leaks in oil pipelines/ preheater.

## **Step-by-step Procedure for efficient operation of burners**

### **1) Start Up**

- a) Check for correct sized burner/nozzle.
- b) Establish air supply first (Start blower). Ensure no vapour/gases are present before light-up.
- c) Ensure a flame from a torch or other source is placed in front of the nozzle.
- d) Turn ON the (preheated) oil supply (Before start-up drain off cold oil).

### **2) Operations**

- a) Check for correct temperature of oil at the burner tip (consult viscosity Vs. temperature chart).
- b) Check for the correct air pressure for the LAP burners (25" to 30" w.g. or 63.5 cm to 76.2 cm air pressure is commonly adopted).
- c) Check if oil is dripping near the burner.
- d) Check for flame fading/flame pulsations.
- e) Check for positioning of burner (ensure no flame impingement on refractory walls or charge).
- f) Adjust the flame length to suit the conditions (ensure the flame does not leap out of the furnace).

### **3) Load Changes**

- a) Operate both air and oil valves simultaneously (If it is a self-proportioning burner, operate the self-proportioning lever. Do not adjust valve only in oil line).
- b) Adjust burners and damper for a light brown (hazy) smoke from chimney and at least 12% Carbon Dioxide.

### **4) Shut Down**

- a) Close oil line first.
- b) Shut the blower after a lapse of few seconds (ensure gases are purged out of the Combustion Chamber).
- c) Do not expose the burner nozzle to the radiant heat of the furnace. (When oil is shut off, remove burner/nozzle or interpose a thin refractory between nozzle and furnace).

### **Important**

**Burners should be dismantled and cleaned periodically, preferably once in a shift (always keep spare burners ready).**

#### **REFERENCE:**

- 1. The Efficient Use of Fuel—HMISO, London.**
- 2. Fuels & Fuel Technology—Wilfred Francis, Pergamon Press.**
- 3. Domestic And Commercial Oil Burners—Charles H. Burkhardt, McGraw-Hill Book Co.**

**This booklet is one of a series on fuel oil conservation, others in the series are listed below:**

- 1) Storage, handling and preparation of fuel oil.
- 2) Efficient generation of steam.
- 3) Efficient utilisation of steam.
- 4) Fuel economy in furnaces and waste heat recovery.
- 5) Refractories.
- 6) Thermal insulation.

**PCRA films available for industrial sector:**

- 1) "Tuning of Boilers and Furnaces".
- 2) "Handling of Fuel Oils".
- 3) "Efficient Utilisation of Steam in Industries"  
(under production).



Set up a few years ago in anticipation of the world-wide oil crisis that's affecting us all today, PCRA seeks to promote efficient utilisation of petroleum products—in homes, in industries, in farms, on roads. Because till alternative sources of energy are found, we have to make the best use of the world's diminishing oil reserves.



**PETROLEUM CONSERVATION  
RESEARCH ASSOCIATION**

Petroleum Conservation Research  
Association, 1008, New Delhi House,  
27, Barakhamba Road, New Delhi - 110 001.

**SAVE OIL.**  
**Because oil isn't going to last forever.**






# Introduction


Two out of three litres of fuel oil consumed in industrial units in India is for raising steam in boilers. In many industrial establishments, the largest, and at times the sole consumer of fuel oil, is the boiler house. Hence, it is important for the industrial user of boilers to know how to economise on fuel oil consumption.

## Heat balance of boilers

A heat balance of boiler indicates what type of heat losses occur and how important they are. Construction of such a balance for each boiler is hence the first step to identify areas for improvement.



(Fig.1)



(Fig.2)

## Sensible heat in flue gases

This loss is the largest in a boiler and represents the heat carried away by the hot gases leaving through the chimney. If more air than what is required for efficient combustion is allowed to enter the boiler furnace, additional heat would be lost in heating the excess air to the chimney temperature. Therefore, necessary efforts have to be made not only to keep chimney temperature as low as possible but also to minimise excess air from entering the combustion chamber by proper tuning of boiler and burner operations.

## Radiation losses

Radiation losses depend on the temperature of the boiler's external surfaces. The quantity of heat lost by radiation from these surfaces is nearly independent of the load at which the boiler operates. When a boiler is operated at low loads, radiation losses may account for a significantly high proportion of the total boiler losses. Boilers with poor insulation and poor design characteristics tend to have higher radiation losses and these losses increase in such boilers rapidly at low loads. If a number of boilers are used to meet the steam demand, it is important to allocate the load among the different boilers judiciously to reduce total losses.

## Unburnts in flue gases

Fuel oil contains Carbon and Hydrogen which, on combustion are converted into Carbon Dioxide and water vapour releasing large quantities of heat. If, however, combustion is incomplete, the carbon may be converted into Carbon Monoxide which results in a liberation of only 52% of the total heat in the fuel. Under very poor combustion conditions, unburnt fuel may leave through the chimney carrying away the entire heat content of the oil vapours. The key to complete combustion is the proper filtration and preparation of fuel oil (See booklet on Storage, handling and preparation of fuel oil) and proper operation of burners (See booklet on Combustion of fuel oils and Burners—operation and maintenance.)

## Incomplete combustion

$C + O_2 \rightarrow CO_2 + 8,084 \text{ KCAL/KG OF CARBON}$

$2C + O_2 \rightarrow 2CO + 2,430 \text{ KCAL/KG OF CARBON}$

FOR EVERY KG OF UNBURNT CARBON, 8084 KCALS OF HEAT IS LOST.


For every kg of carbon partially oxidized to carbon

monoxide, 5,654 Kcals of heat is lost. Incomplete

combustion also leads to serious pollution (smoke and carbon monoxide).

## Blow down losses

Dissolved salts enter the boiler through the make up water which is fed to it. The water evaporates continuously leaving behind the salts in the boiler. This leads to a continuous increase in the concentration of these salts in the boiler drum. These salts tend to precipitate beyond a point leading to the formation of scales. Water from the boiler drum should be regularly blown down to avoid concentration rising beyond such limits. Since the drum water is at high temperature, excess blow down however, leads to needless waste of fuel.




(Fig.3) — HEAT LOSS DUE TO BLOWDOWN

## Excess air and its control

We have seen the need for avoiding more air, than is required for combustion, from entering the boiler furnace. Air entering the boiler furnace can be controlled by proper operation of burners and through flue gas dampers. If,

### CHANGES IN FLUE GAS COMPOSITION WITH EXCESS AIR



(Fig.4)

however, too little air is fed into the combustion chamber, combustion may be incomplete, leading to smoke and unburnts in flue gases. The key to correct air control is hence the feeding of the minimum quantity of air required for smokeless combustion.

A chemical analysis of flue gases is an invaluable aid to determine excess air levels. By measuring either the content of carbondioxide (CO<sub>2</sub>) or oxygen (O<sub>2</sub>) in the flue gases, it is possible to estimate the percentage of excess air in the flue gases. Continuous recording instruments as well as cheaper portable instruments for this purpose are available. (See booklet on Combustion of fuel oils and Burners—operation and maintenance.)

## Tuning of boilers

We have to first determine excess air levels by measuring the percentage of CO<sub>2</sub> in the flue gases when the boiler is running at normal firing rates. Sample locations immediately down-stream of bends, dampers, or induced draft fans should be avoided for flue gas analysis. Make sure that there is no air infiltration at the upstream of the sample point. To start with, deliberately operate the boiler at higher excess air levels so as to achieve a low CO<sub>2</sub> reading (typically 6 to 7%). Reduce air quantities slowly and monitor CO<sub>2</sub> readings. Continue reducing the combustion air until you get good CO<sub>2</sub> reading (preferably between 12 to 14%) in the flue gases. Any further reduction of air beyond 14% would result in smoke and should be avoided. A light brown haze at the top of the chimney indicates proper combustion. The boiler operator should be trained to follow this method to achieve high CO<sub>2</sub> readings at all the firing rates encountered in the boiler.

## A pre-tuning checklist

Before tuning a boiler, several preliminary checks should be made for getting best results. The following checklist will help in this task:

- 1) Are the following as per manufacturer's recommendations?
  - a) Oil pressure at the burner?
  - b) Combustion air pressure?
  - c) Temperature of oil at the burner tip?
- 2) Is the burner aligned and mounted properly?
- 3) Is the burner block properly mounted, aligned and clean?
- 4) Are the air registers in good condition?
- 5) Is the exhaust gas temperature within 30°C of the boiler manufacturer's design value?


## Remember

**If you are not able to achieve at least 12% CO<sub>2</sub> reading by regulating the air supply without causing smoke, your burner may be defective.**

Ensure that the boiler is always operated at the air and fuel settings that have been determined. Check the settings for repeatability, at least once every fortnight.

## Damper settings

In natural draft systems, excess air can be controlled by dampers placed before the chimney. Measurement of draft helps in setting the damper correctly for various loads. Simple inclined tube manometers can be used to measure the draft.



(Fig.5) — INCLINED TUBE MANOMETER


Remember, there is no precise relationship between the damper position and the amount of draft. Thus a half closed damper does not necessarily pass half the quantity of air. As the damper is closed gradually, the draft gauge may not show any significant reduction in draft up to a certain point. By a trial using flue gas analysis to monitor excess air levels, the correct draft for minimum excess air required for smokeless combustion, can be determined for various loads of the boiler. After calibrating the draft gauge for various loads, dampers should be operated at any load to obtain the predetermined optimum draft for that load.

## Gas side deposits

When conditions do not permit complete or total combustion of fuel oil, unburnt carbon particles, known as soot, are deposited on the inside of fire tubes in case of

and packaged boilers and on the outer walls of water tubes in the case of water-tube boilers. Corrosion deposits are also found in boilers in the high temperature zones, such as the super heater, due to the melting of certain low melting point components of fuel-oil-ash. In the low temperature zones of the boiler like economiser, the air preheater and the induced draft fan, corrosion deposits due to the condensation of sulphur trioxide present in the flue gases can also occur.

These deposits slowly build up over a period of time, resulting in a higher flue gas temperature and hence greater heat loss. The fig. 6 shows the rise in flue gas temperature, over a period of time, due to soot deposition.




(Fig.6)

## Remember

**When flue gas temperature rises about 38°C above the normal, it is time for removing the soot deposits.** It is, therefore, recommended to install a dial type thermometer at the base of the chimney to monitor the exhaust flue gas temperature.

It is estimated that a coating of 3 mm thick soot on the heat transfer surface can cause an increase in fuel consumption as much as 2.5%. In large boilers, soot blowers are installed in the furnace section, superheater and in the air preheater/economiser zone. Contact your boiler manufacturer for installing a soot blower in your boiler.



(Fig.7)

## Water side deposits and water softening

Sufficient care is usually devoted to keep the gas side free from accumulation of deposits that would interfere with heat transfer. However, in many low pressure boiler installations, adequate care is not taken to keep water side free from deposits, though many simple forms of modern water treatment equipment and facilities are available. **A 1mm thick scale (deposit) on the water side could increase fuel consumption by 5 to 8%.**

All the waters irrespective of their sources, contain impurities. These impurities are usually in soluble state with the water or at times in a state of suspension. The temperature of the water has a marked effect on solubility. Some impurities become less soluble as temperature rises and starts precipitating; either in the form of a non-adhering, soft sludge (which can be removed without difficulty by boiler blow down) or as a firmly adhering scale. This accumulation considerably reduces the rate of heat transfer and introduces the risk of overheating and failure of the affected surface. This becomes more serious as the boiler pressure and heat transfer rates increase to a point when temperature approaches more closely the upper safe value for the materials used.



The most important dissolved salts from the point of boiler feed, are those of calcium and magnesium. Their presence makes water hard and a deposit or scale is formed rapidly by the use of such water in boilers. Silica is also important, particularly in the case of high pressure boilers, as it forms a hard scale. Further, silica may be steam-volatile, creating problems with turbine blades. Bicarbonates, carbonates, hydroxides, chlorides, sulphates and nitrates of calcium, magnesium and other heavy metals may be present in water. The bicarbonates, carbonates and hydroxides of calcium and magnesium give rise to 'alkaline' or 'carbonate' hardness and the chlorides, sulphates and nitrates to 'non-alkaline' or 'non-carbonate' hardness.

Treatment of raw water to prevent scale formation is called water softening. The chemical composition of water supplies vary greatly. There is, hence, no ideal treatment. Treatment has to be chosen based on a chemical analysis of the water, to find out how much of the various impurities and other chemical substances are present.

The hardness of water is expressed in different forms. A convenient form is milligrams of calcium carbonate per litre of water (mg/litre). Although the hardness may be due to soluble salts of calcium, magnesium, iron, manganese, aluminium or other heavy metals, the result is expressed as equivalent milligrams of calcium carbonate per litre of water.

The following methods are commonly used to soften water.

#### A) Precipitation method:

In this method, chemicals are added to precipitate calcium and magnesium as insoluble compounds, which are then separated by sedimentation and filtration. The lime-soda process is the oldest and most widely used method of precipitation softening. In this process, water is treated with hydrated lime (calcium hydroxide) and soda ash (sodium carbonate). Coagulants such as sodium aluminate, magnesium oxide or alum, are also added to the lime-soda mixture to improve precipitation. The theoretical quantity of chemicals required can be calculated from the following formulae:

Hydrated lime to be added in kg/1000 litres =  $0.00074 \times [\text{carbonate hardness (as CaCO}_3\text{) mg/litre} + \text{magnesium hardness (as CaCO}_3\text{) mg/litre.}]$

Soda Ash to be added in kg/1000 litres =  $0.0011 \times (\text{non-carbonate hardness (as CaCO}_3\text{) mg/litre.})$

Sodium aluminate to be added in kg/1000 litres =  $0.02 \times (\text{total hardness (as CaCO}_3\text{) —up to a maximum of 200 mg/litre hardness.})$

Or  $0.03 \times \text{total hardness (as CaCO}_3\text{) in case of higher hardness levels.}$

The quantities above are for pure chemicals based on complete reaction. In actual practice, a small excess over the above theoretical amount is found necessary to obtain best results. In general, a 5% excess is recommended. Wherever necessary, the charge may be further adjusted, to obtain the desired results.

#### b) Ion exchange method:

If water containing calcium and magnesium salts in solution is passed through a bed of ion exchange material (i.e. synthetic or natural) calcium and magnesium ions are retained by the material and replaced by sodium so that the water leaving the mineral bed contains sodium salts instead of calcium and magnesium salts. In another method, partial deionisation to reduce dissolved solids is carried out by passing the water through a bed of ion exchange resins in hydrogen ion form, which converts carbonates and bicarbonates into carbonic acid and sulphates, nitrates and chlorides into their respective acids (the cations are retained by the resin itself). The water is subsequently aerated to remove carbon dioxide and is either neutralised with sodium hydroxide to produce zero hardness water of less dissolved solid content, or can be further treated by passing through a bed of anion exchange resin to remove all free acids. The latter treatment results in demineralized water containing as low as 5 mg/litre of total dissolved solids.

#### c) Distillation method:

Raw water is distilled in an evaporator, and the distillate, which is almost completely free from dissolved solids, is used. As the evaporator itself may be considered as a very low pressure boiler, the feed may, under certain conditions, require softening. The distillation process is not generally required for low pressure boilers.

#### d) Internal treatment:


When water has low hardness, and comparatively small

water is required to be treated, an external water treatment plant based on ion exchange or precipitation or filtration becomes impracticable and uneconomical. Under such conditions, internal treatment is applied. In this treatment, certain chemicals are administered directly to the water, entering the boiler which causes the hardness, producing salts to precipitate inside the boiler in the form of a smooth flowing sludge. Different waters require different chemicals. Sodium carbonate, sodium aluminate, sodium phosphate, tannin, starch and other compounds of vegetable or inorganic origin are used for this purpose. The sludge is removed during boiler blow down. This process is suitable for use particularly in low pressure boilers.

**Remember:** Boiler water treatment involves more than just scale prevention. Important is the kind and control of chemical treatment, regulating the preheating and pretreating of make up and proper control of boiler blow down to prevent a buildup of solids and sludge in the drum. Supervision and control of this programme calls for a qualified operator. Prevention of feed water trouble usually costs far less than the repair of neglected equipment. Careful choice of water treatment plants can avoid many problems in future.

## Boiler loading

The figure 8 gives the relationship between efficiency and loading of a boiler. It is important that one should load a boiler close to its normal economic rating and



thereby achieve highest efficiency. However, this may not be possible in actual practice on account of the fluctuating loads on the process side. It is, therefore, necessary for you to determine the efficiency of the boiler at various load factors normally encountered. If you have a battery of boilers and their load characteristics are known, it would be possible for you to allocate the loads in such a manner that the total steam generation is at the highest efficiency.

## Remember

**Boilers with a steep load characteristic should always be operated close to their normal economic rated loads.**

## Example

The boiler characteristic curve of two boilers, A and B, indicate that boiler A has a steep relationship between efficiency and load as against an almost constant efficiency at varying loads encountered in Boiler B. It will be apparent to the reader that the plant's total steam demand is 7 Tonnes/Hour. Boiler A should be loaded up to 5 Tonnes/Hour at which its efficiency is maximum and Boiler B should be used to meet the remaining steam demand of 2 Tonnes/Hour.

## Blow down

The concentration of total dissolved solids (TDS) in boiler water can be chemically determined and is reported as parts per million (PPM). Different boilers can tolerate different levels of concentration of dissolved solids in the boiler drum.

To maintain boiler water concentrations within the specified upper limit of boiler water TDS, blow down is resorted to. The following formula gives the quantity of blow down required:

$$\text{blow down (\%)} = \frac{\text{TDS in feed water}}{\text{Maximum permissible TDS in boiler water}} \times (\% \text{ make up water})$$

**Example:** If maximum permissible limit of TDS in a boiler is about 3500 PPM and percentage make up water is 40 and if TDS in feed water is 350 PPM then the percentage blow down

$$= \frac{350}{3500} \times 40 = 4\%$$

If boiler evaporation rate is 5500 kg/hr, then required blow down rate:

$$= \frac{5500 \times 4}{100} = 220 \text{ kg/hr.}$$

from the drum. At today's fuel prices, it is worthwhile to consider heat recovery from blow down. The figure gives a system by which heat can be recovered from blow down.




Clean condensate from process departments is a valuable source of heat which can be used in the boiler house as feed water. Apart from reducing fuel requirements in the boiler by raising the boiler feed water temperature, this also reduces water treatment costs, since condensate is like distilled water, and needs no water treatment. Hence, before exploring the use of an economiser, it is advisable to check whether all the condensate that can be economically recovered, is being returned to the boiler house.

## Remember

**For every 6°C rise in boiler feed water temperature through condensate return, there is 1% saving in fuel.**


## Flue gas heat recovery

Waste heat which escapes through the chimney can be trapped and reused, thereby reducing fuel consumption in a




(Fig.10) — INTEGRATED HEAT RECOVERY SYSTEM

boiler. In an economiser, the waste heat is used to increase the boiler feed water temperature. On the other hand, in an air pre-heater, the waste heat is used to heat combustion air. In both the cases, there is a corresponding reduction in the fuel requirements of the boiler.



(Fig.11)



(Fig.12)


AIR PREHEATER

## Remember


For every  $22^{\circ}\text{C}$  reduction in flue gas temperature by passing through an economiser or a pre-heater, there is 1% saving of fuel in the boiler. In other words, for every  $6^{\circ}\text{C}$  rise in feed water temperature through an economiser, or  $20^{\circ}\text{C}$  rise in combustion air temperature through an air pre-heater, there is 1% saving of fuel.

## Turbulators

Turbulators are a set of baffles arranged at different angles which are installed in the secondary passes of an oil fired



(Fig. 13) HOTTEST GAS FLOWS THRU TOP ROWS OF TUBES ONLY.



(Fig. 14) GAS FLOW EQUALIZED THRU ALL TUBES  
TWO PASS FIRETUBE BOILERS WITH AND WITHOUT TURBULATORS.

fire-tube boiler to increase flame turbulence and thereby increase convective heat transfer to the surrounding boiler water.

This device also helps in balancing the flue gas flow through the fire-tubes to achieve more effective utilization of existing heat transfer surfaces. The figures 13 and 14 depict a two pass Scotch Marine fire-tube boiler with and without turbulators. The improvement in boiler performance will be indicated by the decrease in stack temperature and the corresponding increase in steam generation.

## Boiler feed tank


It is desirable to provide a feed water tank with a capacity, at least equal to one hour's maximum boiler evaporation. The feed water should be maintained at as high a temperature as possible by recovering heat from all the sources of waste heat such as condensate return, heat from boiler blow down, heat from steam pre-heater condensate or exhaust heat where steam pumps are used.

To avoid cavitation at the pump, it is advisable to provide the feed tank at a sufficient height above the pump. The following table gives recommended heights where steam feed water pumps are used.

Feed water temperature	Required height
86°C	1.5 metres
90°C	2.1 metres
95°C	3.5 metres
100°C	5.2 metres

Slightly lower heads can be used for centrifugal pumps.

The feed tank should be provided with a tight fitting lid preferably bolted on, and should have an adequately sized vent pipe and over flow. The condensate return line normally carries some flash steam. If it is connected with the top of the tank, this steam will easily escape through the vent pipe. The return line should therefore be carried below the water level so that much of the flash can be condensed. A check valve should be fitted to act as a vacuum breaker to prevent the water from the tank being sucked back into the condensate return line. Where large quantity of flash is



(Fig. 15)

be capable at the feed tank, and a reasonable amount of cold make-up water is required, a heat exchanger may be used to condense the flash steam and cool the condensate using either cold make up or process water as the cooling medium.

A supply of water should be connected to the tank to make-up for any difference between the amount of condensate returned and boiler evaporation.

This make-up supply should be automatically controlled by means of a float operated valve.

The level of the float should be so adjusted that cold water is admitted only after full allowance has been made to receive all possible hot water.

The most suitable level can only be decided with a knowledge of the operating conditions in the individual installation. If an ordinary ball valve is used to control the make-up, it may not last long in the hot turbulent conditions that exist in the tank. It can be fitted in a small separate tank to overcome this trouble.

The feed tank should be well lagged to conserve as much heat as possible. A water meter fitted on the suction line of the feed pump gives a very useful indication of total boiler evaporation.

It is important to remember that for approximately every 6°C rise in feed water temperature, the boiler will require 1% less fuel. A thermometer on the feed tank or pump suction line can be of considerable use in keeping a check on feed temperature.

## Selection of boiler

Is the boiler really necessary?

What should be its specifications?

What type of boiler should be selected?

These are some vital questions which have to be carefully answered before a new boiler is purchased.

The first step is to examine the need for the boiler. The pattern of steam demand of the plant should be carefully assessed. In many instances, careful production planning and scheduling can help in minimising the steam demand peaks, and hence the need for a new boiler to meet these peaks. A vigorous steam economy drive also often results in avoiding the need for a new boiler. Having determined the pattern of steam demand in the plant, the required additional boiler capacity can easily be worked out. While planning for a new boiler, future expansion and steam demand should be kept in mind for fixing the boiler

capacity. It should be remembered that too high a capacity may necessitate the operation of the boiler uneconomically at low loads.

The next step is to determine the steam pressure required. The operating pressure of the boiler should be slightly higher (around 1 kg/cm<sup>2</sup>, in small and medium plants) than the maximum pressure of steam required by any process for which supply is to be made by the boiler. The boiler should be capable of generating steam at least at this pressure or at a higher pressure.

Once the required steam pressure, temperature and capacity are known, suitable selection can be made from the boiler ranges available with manufacturers. It should, however, be remembered that there are fairly wide variations in the efficiency of generation among different types of boilers.

A study of over 2500 boilers of various makes and sizes by PCRA in Indian Industry has indicated the performance of boilers commonly used as shown in figure 16.


It may be noted that package boilers have significantly higher thermal efficiencies. In spite of lower efficiencies, Lancashire and vertical boilers are very common in India. They are more rugged and can tolerate poor quality feed water as well as poor operation with greater safety than other boilers. With increasing emphasis on efficiency of generation along with improvements in operators' skills and quality of water treatment, the era of such boilers is slowly coming to an end.

The steam generating capacity of a boiler is often specified in terms of Equivalent Evaporation (Kg of steam/hour from and at 100°C). Equivalent Evaporation expresses the heat capacity of the boiler in terms of the heat required to evaporate the specified quantity of feed water from a temperature of 100°C to dry saturated steam at 100°C (i.e. 540 Kcal/kg). In actual boilers, feed water temperatures may be different and the generated steam is at a higher temperature. Actual Evaporation hence, tends to be lower than Equivalent Evaporation.

$$\text{Equivalent Evaporation} = \frac{\text{Actual Evaporation} \times (H - h)}{540} \text{ kg/hr}$$

where H = total heat in generated steam (Kcal/kg)  
and h = heat content in feed water (Kcal/kg).

If the pressure and temperature of steam as well as the temperature of feed water is known, values of H and h can be obtained from steam tables.



(Fig.16) — PERFORMANCE RANGE OF BOILERS

**Example:** If a boiler generates 4.0 tonnes of steam/hr at a pressure of 7 kg/cm<sup>2</sup> and dryness fraction of 0.9 with a feed water temperature of 30°C—

$$H = 612 \text{ Kcal/kg}$$

$$h = 30 \text{ Kcal/kg}$$

$$\text{Equivalent Evaporation} = \frac{4.0 \times (612 - 30)}{540} = 4.3 \text{ T/hr.}$$

Manufacturers may be asked to specify guaranteed levels of Equivalent Evaporation as well as efficiency.

$$\text{Efficiency} = \frac{\text{Actual Evaporation} \times (H-h)}{\text{Fuel consumed per hour} \times \text{Gross caloric value of fuel}}$$

After installing a boiler, a boiler trial should be conducted. Actual Evaporation may be measured by means of either a freshly calibrated steam flow meter, or by a hot water meter fitted on the feed water line. If a water meter is used, care should be taken to equalise the water level in the boiler drum before taking water consumption readings. If flow meters are not available, water should be taken from a separate calibrated tank to which the condensate is not returned. Fuel consumption during the trial period is usually measured by dip readings of the service tank or by using a correctly calibrated fuel flow meter.

**REFERENCE :**

1. The Efficient Use of Steam — Oliver Lyle, HMSO, London.
2. Boilers — Types, Characteristics & Functions — Carl D. Shields, McGraw-Hill Book Co.

**This booklet is one of a series on fuel oil conservation others in the series are listed below:**

- 1) Storage, handling and preparation of fuel oil.
- 2) Combustion of fuel oils & Burners—operation and maintenance.
- 3) Efficient generation of steam.
- 4) Efficient utilisation of steam.
- 5) Refractories.
- 6) Thermal insulation.

**PCRA films available for industrial sector:**

- 1) "Tuning of Boilers and Furnaces".
- 2) "Handling of Fuel Oils".
- 3) "Efficient Utilisation of Steam in Industries" (under production).





Set up a few years ago in anticipation of the world-wide oil crisis that's affecting us all today, PCRA seeks to promote efficient utilisation of petroleum products—in homes, in industries, in farms, on roads. Because till alternative sources of energy are found, we have to make the best use of the world's diminishing oil reserves.



**PETROLEUM CONSERVATION  
RESEARCH ASSOCIATION**

Petroleum Conservation Research  
Association, 1008, New Delhi House,  
27, Barakhamba Road, New Delhi - 110 001.

**SAVE OIL.**

**Because oil isn't going to last forever.**

# 4

## Efficient utilisation of steam



Small, illegible text at the bottom left corner, possibly a page number or reference code.



# Introduction

Nearly 2 out of every 3 litres of fuel oil used in industry is for generating steam in industrial boilers. The very purpose of generating steam at the highest thermal efficiency is lost if the steam is subsequently wasted through improper distribution or utilisation.

Saving steam will have a multi-directional impact on the overall conservation programme. Foremost, it would result in considerable savings of furnace oil in the boilers than the same effort on improving boiler efficiency. The peak demand for steam could drop down to a level within the operating capacity of the boiler house, thereby avoiding fuel wastage through overloading or the need for additional boiler(s). Overall production time too could be reduced, thus increasing the output of the steam consuming equipment. Thus, the productivity of the overall steam-consuming manufacturing operation could be improved.


In this booklet, such key result measures are covered as can be readily followed and implemented to improve steam distribution and utilisation in industries.

# Key result areas for efficient steam utilisation

- 1) Avoiding steam leakages.
- 2) Providing dry steam for process.
- 3) Utilising steam at the lowest practicable pressure for process.
- 4) Insulation of steam pipelines and hot process equipments.
- 5) Proper utilisation of directly injected steam.
- 6) Proper air venting.
- 7) Minimising barriers to heat transfer.
- 8) Condensate recovery.
- 9) Flash steam recovery.
- 10) Proper selection and maintenance of steam traps.
- 11) Proper sizing of steam and condensate pipelines.
- 12) Reducing the work to be done by steam.

## 1. Avoiding steam leakages

Steam leakage is a visible indicator of waste and must be avoided. It has been estimated that a 3 mm diameter hole on a pipeline carrying 7 kg/cm<sup>2</sup> steam would waste 32.65 KL of fuel oil per year. Steam leaks on high pressure mains are prohibitively costlier than on low pressure mains.



(Fig. 1)—STEAM LEAK LOSSES

Any steam leakage must be quickly attended to. In fact, the plant should consider a regular surveillance programme for identifying leaks at pipelines, valves, flanges and joints as soon as they occur. Indeed, by plugging all leakages, one may

be surprised at the extent of fuel savings, which may reach up to 5% of the steam consumption in a small or medium scale industry or even higher in installations having several process departments.

To avoid leaks it may be worthwhile considering replacement of the flanged joints which are rarely opened in old plants by welded joints. These days, technology is available to plug online steam leaks. Even continuous process industries can take advantage of this.

## 2. Providing dry steam for process


The best steam for industrial process heating is dry saturated steam—neither wet nor superheated. If steam is wet, the trapped moisture particles reduce the total heat in the steam (since they carry no latent heat), and increase the resistance of water on the heat transfer surfaces, thereby slowing down the rate of heat transfer. Such moisture also overloads the traps and other condensate handling equipment. On the other hand, superheated steam is not so practical or desirable for process heating because its temperature in the plant cannot be effectively controlled (unlike saturated steam whose temperature depends only on the pressure), and also because it gives up its heat at a rate slower than the condensation heat transfer of saturated steam.

It must be remembered that a boiler without a superheater cannot deliver perfectly dry saturated steam. At best, it can deliver only 95% dry steam. The dryness fraction of steam depends on various factors, such as the level of water in the boiler drum, the effect of peak loads, the surging within the boiler, the pressure on the water surface in the boiler and the solids content in the boiler water. Any one of these factors or a combination of them can cause droplets of water to be a part of the steam. Indeed, even as simple a thing as improper boiler water treatment can become a cause for wet steam.

As steam flows through the pipelines, it undergoes progressive condensation due to the loss of heat to the colder surroundings. The extent of the condensation depends on the effectiveness of the lagging. For example, with poor lagging, the steam can become excessively wet.

Since dry saturated steam is required for process equipment, due attention must be paid to the boiler operation and lagging of the pipelines. A steam separator may be installed on the steam main as well as on the branch lines to reduce wetness in steam and improve the quality of the steam going to the user units.

There are two types of steam separators commonly used in industries, as shown in Fig. 2.



Both types of steam separators, a change in the direction of the steam flow results in the trapped water particles being dropped and delivered to a point where they can be drained away as condensate through a steam trap.

The simple baffle type separator provides the moisture with an obstacle on which they impinge and fall to the bottom of the unit thereby allowing only dry steam to pass on further.




Fig.3 - COMPARISON OF LATENT AND SENSIBLE HEAT TO THE TOTAL HEAT AT TWO DIFFERENT PRESSURES OF STEAM

### 3. Utilising steam at the lowest practicable pressure for process

A study of the steam tables would indicate that the latent heat in steam reduces as the steam pressure increases.

It is only the latent heat of steam which takes part in the heating process when applied to an indirect heating system. Thus, it is important that its value be kept as high as possible. This can only be achieved if we go in for lower steam pressures. As a guide, the steam should always be generated and distributed at the highest possible pressure but utilised at as low a pressure as possible since it then has higher latent heat. However, it may also be seen from the steam tables that the lower the steam pressure, the lower will be its temperature. Since temperature is the driving force for the transfer of heat at lower steam pressures, the rate of heat transfer will be slower and the processing time greater. In equipment where fixed losses are high (e.g. big drying cylinders), there may even be an increase in steam consumption at lower pressures due to increased processing time. There are, however, several equipment in certain industries where one can profitably go in for lower pressures and realise economy in steam consumption without materially affecting production time.

Therefore, there is a limit to the reduction of steam pressure. Depending on the equipment design, the lowest possible steam pressure with which the equipment can work, should be selected without sacrificing either on production time or on steam consumption.

### 4. Insulation of steam pipelines and hot process equipment

Bare steam pipelines, flanges and hot process equipment give up heat to the atmosphere by radiation. Insulation seeks to reduce these heat losses.

It has been estimated that a bare steam pipe, 150mm in dia and 100 meters in length, carrying saturated steam at 8 kg/cm², could waste 25KL furnace oil in one year.

In case, the pipelines are already lagged, it pays to periodically review the effectiveness of the insulation. The booklet on 'Thermal Insulation' in this series provides detailed information on the types of insulation available, the determination of the optimum thickness and the method of applying insulation. (For details, refer within this booklet).

## 5. Proper utilisation of directly injected steam

The heating of a liquid by direct injection of steam is often desirable. The equipment required is relatively simple, cheap and easy to maintain. No condensate recovery system is necessary. The heating is quick, and the sensible heat of the steam is also used up along with the latent heat, making the process thermally efficient. In particular processes where a certain amount of agitation is required, which can be created by blowing steam into the liquid—direct steam injection is applied. If, however, the diffusion of the tank contents and agitation are not acceptable in the process, indirect steam heating is the only answer.

In a good number of plants, where water or process liquor is heated by direct steam injection, one can see the liquid in the tank boiling away, creating clouds of vapour.

This is a waste of steam. Besides, it creates unpleasant working conditions.


Ideally, the injected steam should be condensed completely as the bubbles rise through the liquid. This is possible only if the inlet steam pressures are kept very low—around  $0.5 \text{ kg/cm}^2$ —and certainly not over  $1 \text{ kg/cm}^2$ . If pressures are high, the velocity of the steam bubbles will also be high and they will not get sufficient time to condense before they reach the surface. Fig. 4 shows a recommended arrangement for direct injection of steam.

A large number of small diameter holes (2 to 5 mm), facing downwards, should be drilled on the sparge pipe. That way, the initial velocity of the bubbles is dissipated in the depths of the liquid.

Many processes call for the use of open vats of hot liquor. To allow, the temperature of the contents of such a vat to increase beyond required levels, for example upto  $82^\circ\text{C}$ , when  $66^\circ\text{C}$  is all that is needed, is to wastefully use as much as one-third of the total steam used in the process. If steam is used for 24 hours/day and seven days a week, the excess steam utilisation represents a fuel waste of approximately 90KL of oil a year. In such a situation, an automatic temperature controller, as illustrated in Fig. 4, should be used to reduce and control the heat demand.

A thermostatic control of steam admitted is also desirable, to avoid overheating of the liquor and wastage of steam. If however, the liquid must be kept boiling, it would be difficult to regulate the injection of steam, since the temperature of the liquid will not rise if excessive steam is admitted. If possible,

such tanks should be provided with a lid and a vent. The escape of steam through the vent, visible to the operator, can then be used to control steam admission.



(Fig.4) — RECOMMENDED ARRANGEMENT FOR DIRECT REJECTION OF STEAM

Steam in the pipe downstream of the controller tends to condense, forming a partial vacuum at the time of steam supply shut-off either by the temperature controller or due to the boiler shut-downs. As a result, liquor will be sucked back into the pipe system. This is bound to adversely affect not only the pipes, but may also harm the temperature controller, particularly if the liquor being heated is of corrosive nature and has suspended particles. Thus, some provision should be made to release the vacuum. It is a common practice to provide a check valve in reverse as shown in (Fig. 4).

## 6. Proper air venting

A 0.25 mm thick air film offers the same resistance to heat transfer as a 330 mm thick copper wall. The presence of air inside the process equipment will reduce the partial pressure of steam in the steam-air mixture, thus dropping the overall temperature of the steam air mixture, which is the heating media. It is, however, impossible to avoid the entry of air into a steam system that is working intermittently. If the steam condenses during the shut downs, air tends to be sucked in due to the partial vacuum created. Air is also pushed into the process equipment from the steam mains at the time of start up. The situation can be improved by installing properly sized air vents at appropriate positions in the pipelines and the



ment. The air vent should be so positioned that the trapped air is pumped out of the equipment as quickly as possible. The air vent should be positioned at the stagnant point remote from the steam inlet point. If steam inlet is low, the air vents should necessarily be placed at the top and at the bottom. This will ensure that the incoming steam will push out the entire trapped air in the equipment towards the vents. Fig. 6 shows the desirable locations of air vents in typical applications.

Hand operated cocks are widely used to remove air from steam installations, but they are often abused. If the start-up is sluggish, the operator tends to open the vent, which he then closes either too early or too late.


Automatic air vents are also available but they are relatively expensive and should be carefully maintained. The best automatic air vents are the balanced pressure or the liquid expansion types. The former are lighter, cheaper and have a quicker response, whereas the latter are more robust.

## 7. Minimising barriers to heat transfer

Heat is transferred from the steam to the material being heated in two ways:


- By direct contact when steam is directly injected into the material in the chamber.
- Through an intermediate heating surface which acts as a barrier between the steam and the material being heated.

OBSTACLES IN EFFECTIVE HEAT TRANSFER



(Fig.5)

Once the plant is running, the vent cock is probably left untouched, until output drops significantly, drawing the operator's attention to the open air vent. Where an inverted bucket or thermostatic trap is used to drain out the condensate, there may be no need to make the provision for a separate air vent, since these traps can handle and remove air and the condensate simultaneously.




(Fig.6) — POSITIONING OF AIR VENT




The direct method has been discussed earlier. In the second method, that of indirect heating, a temperature difference is required to overcome the resistance of the barrier between the steam and the material. However, it is not just the thermal conductivity of the barrier which is an important factor. Alongside the heat transfer barrier is an air film as well as scaling on the steam side, and scaling as well as a stagnation product film on the product side. Fig. 5 illustrates the barriers which are formed that impede the flow of heat from steam to the material. It has been estimated that air is 1500 times more resistant to heat transfer than steel and 13,000 times more resistant than copper. Thus, an air film of 0.025mm thickness offers the same resistance to heat transfer as a 330mm thick copper wall. Air is probably the best heat insulator ever known. It is also the most likely material to be trapped in all steam supplies, because when steam condenses, air always tries to take its place on account of the partial vacuum created. Air is also carried into the steam space by incoming steam during start-ups. It is, therefore, essential that the equipment should be so designed that the trapped air is pumped out automatically at the very beginning.

Adequate air venting provision should be made to purge out air as quickly as possible from the equipment, making heat transfer more efficient. Fig. 6 gives the positioning of the air vent on steam mains. The location of the air vent in a steam cylinder is given in Fig. 7. Also, a typical air vent insulation for a jacketed vessel is indicated in Fig. 8.



(Fig.7)— BEHAVIOUR OF TRAPPED AIR



(Fig.8)— AIR VENTING OF STEAM JACKETED BOILING PANS

Now a word about removal of the condensate film. It is not possible to remove the condensate film for the simple reason that steam, when it comes into contact with the surface to be heated, gives up its latent heat and condenses, forming the insulating film we are seeking to reduce. When it enters the steam space, the water it carries is deposited on the heated surface, increasing the insulating water film, but contributing no actual heat transfer process. To prevent water droplets from entering the equipment, it may be necessary to use a steam separator, as already discussed in (2.)

## 8. Condensate recovery

The steam condenses after giving off its latent heat in the heating coil or the jacket of the process equipment. A sizeable portion (about 25%) of the total heat in the steam leaves the process equipment as hot water. If this water is returned to the boiler house, it will reduce the fuel requirements of the boiler. For every 6°C rise in the feed water temperature, there will be approximately 1% saving of fuel in the boiler. However, in most cases, the boiler water has to be chemically treated to prevent or reduce scale formation, whereas the condensate is almost entirely pure water which needs no treatment. With a good percentage of the condensate returning to the boiler house, the expenses involved for water treatment will be reduced by an appreciable amount.

In some cases, the return of the entire condensate can make the feed too hot to handle. The extra-high temperature feed water may lead to the cavitation of the feed pump, which can be overcome by arranging the feed tank at a certain height, so that it provides a positive head at the suction point of the pump. The necessary head will depend upon the temperature of the water and the type of the pump. Table I gives the height required for the feed temperature for most of the pumps. This can, in some cases, be reduced, in consultation with the pump manufacturers.


**Table I**

Temperature of water (°C)	Height required (Metres)
88	1.6
93	3.2
99	4.8
100	5.5

In some cases, where the boiler plant incorporates an economiser, the recycling of the entire condensate may lead to the feed water inlet temperature exceeding the limit that can be safely handled by the economiser. In such cases, some heat can often be taken out of the condensate in the form of flash steam and efficiently utilised in other processes.

There may be some exceptions, particularly in very large plants. Here, the investment of such a return system is very high while the heat that can be recovered is very small. In such cases, the condensate is not fully recycled to be used as boiler feed. The real justification and working of cost-benefit analysis depends on the actual site conditions. But in most cases, it is possible to make use of the heat in the condensate, either using it directly as process hot water or by recovering the heat through a heat exchanger.

Another reason for not returning the condensate may be the fact of its being contaminated in certain processes, such as in the plating process, where the vats are heated by steam coils, and a small leak in the coil allows acid to pass into condensate system. To prevent this from being recycled into the boiler, the condensate from these vats is made use of in the hot tanks.



(Fig.9) — UTILISING CORROSIVE CONDENSATE

Alternatively, heat can be usefully recovered from contaminated condensate by passing it through a heat exchanger. Where the occurrence of contamination is not frequent, but to protect the plant against such incidents, it is best to use conductivity meters on the condensate line.

Pumping of the condensate from the condensate collection tank to the main feed water tank can then be automatically stopped as soon as the meter detects contamination. In many instances, such as in Oil Refineries, where there are possibilities of oil contamination, the condensate is passed through a 'Trace Detector' which can detect the contamination and give adequate warning. Such instrumentation is usually expensive and is only justifiable where large quantities of condensate are being recovered from sources of possible contamination.

## 9. Flash steam recovery

Flash steam is produced when condensate at a high pressure is released to a lower pressure and can be used for low pressure heating.

The flash steam quantity can be calculated by the following mathematical formula with the help of a steam table:

$$\text{Flash steam available \%} = \frac{S_1 - S_2}{L_2}$$

where:  $S_1$  is the sensible heat of higher pressure condensate.

$S_2$  is the sensible heat of the steam at lower pressure (at which it has been flashed).

$L_2$  is the latent heat of flash steam (at lower pressure).


Alternatively, it can be determined from the graph given in Fig. 10. For example, if condensate at 11 kg/cm<sup>2</sup>, about 5%

by weight of the condensate could be generated as flash steam. This steam can be used on low pressure applications like direct injection and can replace an equal quantity of live steam that would be otherwise required. The higher the steam pressure and the lower the pressure of flash steam, the greater the quantity of flash steam that can be generated.


The demand for flash steam should exceed its supply, so that there is no build up of pressure in the flash vessel and the consequent loss of steam through the safety valve. Generally, the simplest method of using flash steam is to flash from a machine/equipment at a higher pressure to a machine/equipment at a lower pressure, thereby augmenting steam supply to the low pressure equipment (from the need of steam regularly through a reducing valve).

In general, a flash system should run at the lowest possible pressure so that the maximum amount of flash is available and the back pressure on the high pressure systems is kept as low as possible.

Flash steam from the condensate can be separated in an equipment called the 'flash vessel'. This is a vertical vessel as shown in Fig. 11. The diameter of the vessel is such that a considerable drop in velocity allows the condensate to fall to the bottom of the vessel from where it is drained out by a steam trap preferably a float trap. Flash steam itself rises to leave the vessel at the top. The height of the vessel should be sufficient enough to avoid water being carried over in the flash steam.



(Fig.10) — Kg FLASH PER Kg CONDENSATE




(Fig.11) — FLASH VESSEL

goes out through the steam trap (D). The flash vessel is usually fitted with a 'pressure gauge' to know the quality of flash steam leaving the vessel. A 'safety valve' is also provided to vent out the steam in case of high pressure build up in the vessel.

### Typical application of flash vessel

For example, if we have a situation as shown in Fig. 12, such that there are two plants A and B operating simultaneously in a factory, Plant A needs high pressure steam and Plant B requires low pressure steam, the flash steam from the condensate of Plant A can be utilised in Plant B through a flash vessel reducing the requirement of high pressure steam which otherwise would be used in Plant B through the pressure reducing valve.

The condensate from the traps (A) along with some flash steam generated passes through vessel (B). The flash steam is let out through (C) and the residual condensate from (B)



(Fig.12)

## 10. Proper selection and maintenance of steam traps

It has been seen that the main causes of unsatisfactory condensate removal include the choice of the wrong type of steam trap for the application, the use of a trap incorrectly sized for the load and pressure conditions, and bad installation. Any of these factors can seriously reduce the plant output. If the user of steam traps is fully aware of traps, their functions and types, correct application and installation, the poor equipment performance, waste of

steam and high maintenance cost of the traps can easily be avoided.

The steam trap is an automatic valve capable of distinguishing between condensate and live steam. It opens to discharge the former (condensate) but closes to trap the latter (steam).

The difference between condensate and steam is sensed in several ways. One group of traps detect the difference in density. Another group react to a difference in temperature and the third rely on the difference in flow characteristics.

### Classification of commonly used steam traps

Mechanical Traps	Thermostatic Traps	Thermodynamic Traps	General
(Operates on the difference in density between condensate & steam.)	(Operates by sensing a difference in temperatures between condensate & steam.)	(Operates on the forces generated by flashing condensate and steam flowing through orifice.)	1) Impulse Traps 2) Pilot Operated Traps 3) Labyrinth Traps 4) Orifice Plates 5) Ogden Pump, etc.
1) <b>Float Traps:</b> a) Plain Float b) Trip Float	1) Balanced-Pressure Traps. 2) Liquid Expansion Traps. 3) Bimetal Traps.		
2) <b>Bucket Traps:</b> a) Open-top bucket traps. b) Inverted bucket traps.			

The various characteristics of steam traps are summarised in Table II on next page.

### Steam trap selection

The selection of a steam trap for a particular application depends on the process conditions (like temperature, pressure and quantity of condensate, etc.) and derives from the judgement based on past experience. However, a widely accepted guide for this purpose is given below to help the users in making an appropriate decision.

S.No.	Application	First choice	Second choice
1)	Steam Mains & Separators	T.D.	Ogden
2)	Steam Mains, Horizontal Runs	T.D.	Ogden
3)	Branch Mains to Process	T.D.	T.S.U.
4)	Heat Exchanger (Calorifiers)	F.T.	Ogden
5)	Steam Radiator	I.B.T.	T.D.
6)	Unit Heaters	F.T.	F.T.
7)	Boiling Pans (Pedestal)	T.S.U.	F.T.
8)	Boiling Pans (Fixed)	F.T.	T.D.

S.No.	Application	First choice	Second choice
9)	Boiling Pans (Tilting)	F.T.(SLR)	F.T. (SLR)
10)	Boiling Pans (Extra Rapid Tilting)	F.T.(SLR)	T.S.U.
11)	Brewing Copper	F.T.	Ogden
12)	Drying Units (Short)	T.D.	T.S.U.
13)	Drying Units (Long)	T.D.	T.S.U.
14)	Dryers-Cylinder	F.T.(SLR)	F.T. (SLR)
15)	Digesters	F.T.	Ogden
16)	Multi-Platen Presses (Parallel individual connections)	T.D.	T.D.
17)	Oil Storage Tanks	Ogden	T.S.U.
18)	Tracer Lines	T.D.	T.D.
19)	Steam Hammers	T.D.	T.D.
20)	Hot Tables (Process)	T.S.U.	T.D.

**Legend:** T.D. ... Thermodynamic Traps  
Ogden ... Ogden Traps  
F.T. ... Float Traps  
F.T. (SLR) ... Float Traps with steam lock release  
T.S.U. ... Thermostatic Unit

Table II

## Characteristics of steam traps

TYPE OF TRAP	TYPE OF DISCHARGE	OPENING FORCE	CLOSING FORCE	TEMPERATURE OF CONDENSATE	DISCHARGE AIR	WITHSTAND WATER HAMMER	STRAINER BEFORE TRAP	CONDENSATE DRAINED	WILL LIFT CONDENSATE	DAMAGE BY FROST	CHECK VALVE BEFORE TRAP	SUITABLE FOR SUPERHEATED STEAM	SUITABLE FOR VARYING PRESSURE
Plain float	Continuous	Buoyancy	Float weight	Saturation	No	No	Highly desirable	Instantly	Yes	Yes	No	Yes	Yes
Tip float	Intermittent	Buoyancy	Float weight	Saturation	No	No	Desirable	As formed	Yes	Yes	No	Yes	Yes
Open bucket	Intermittent	Weight of bucket	Buoyancy	Saturation	No	Yes	Not essential	As formed	Yes	Yes	Yes	Yes	Yes
Inverted bucket	Intermittent	Weight of bucket	Buoyancy	Saturation	Yes	Yes	Not essential	As formed	Yes	Yes	Yes	Yes	Yes
Metallic expansion	Semi-continuous	Metallic contraction	Metallic expansion	Pre-set temperature	Yes	Yes	Highly desirable	At pre-set temperature	Yes	No	No	Yes	No
Liquid expansion	Semi-continuous	Steam pressure	Liquid expansion	Pre-set temperature	Yes	Yes	Highly desirable	At pre-set temperature	Yes	No	No	Yes	No
Balanced pressure expansion	Semi-continuous	Differential pressure	Differential pressure	Below saturation	Yes	No	Highly desirable	After cooling	Yes	No	No	No	Yes
Relay float, bucket, bottle.	Continuous if compensated	Outside source unlimited	Outside source unlimited	Saturation	No	—	Desirable	As formed	Yes	Yes	No	Yes	Yes
Pumping or jifting	Intermittent	—	—	Any temperature below steam temperature	No	—	Not essential	As formed	Yes	Yes	In trap	Yes	Yes

## Installation of steam traps

In most cases, trapping problems are caused by bad installation rather than by the choice of the wrong type or faulty manufacture. To ensure a trouble-free installation, careful consideration should be given to the drain point, pipe sizing, air venting, steam locking, group trapping vs. individual trapping, dirt, water hammer, lifting of the condensate, etc.

### 1) Drain point

The drain point should be so arranged that the condensate can easily flow into the trap. This is not always appreciated. For example, it is useless to provide a 15 mm drain hole in the bottom of a 150 mm steam main, because most of the condensate will be carried away by the steam velocity. A proper pocket at the lowest part of the pipe line; into which the condensate can drop; of at least 100 mm diameter is needed in such cases.


Fig. 13 and 14 show the wrong and the correct practices in providing the drain points on the steam lines.

### 2) Pipe sizing


The pipes leading to and from steam traps should be of adequate size. This is particularly important in the case of thermodynamic traps, because their correct operation can be disturbed by excessive resistance to flow in the condensate pipe work. Pipe fittings such as valves, bends and tees close to the trap will also set up excessive back-pressures in certain circumstances.

### 3) Air binding

When air is pumped into the trap space by the steam, the trap function ceases. Unless adequate provision is made for removing air either by way of the steam trap or a separate



(Fig. 13) — WRONG WAYS OF DRAINING PIPES



(Fig. 14) — RIGHT WAYS OF DRAINING PIPES

air vent, the plant may take a long time in warming up and may never give its full output.


### 4) Steam locking

This is similar to air binding except that the trap is locked shut by steam instead of air. The typical example is a drying cylinder. It is always advisable to use a float trap provided with a steam lock release (F.T. SLR) arrangement.


### 5) Group trapping vs. individual trapping

It is tempting to try and save money by connecting several units to a common steam trap as shown in Fig. 14(a). This is known as group trapping. However, it is rarely successful, since it normally causes water-logging and loss of output.





(Fig. 14a) — GROUP TRAPPING



INDIVIDUAL TRAPPING

(Fig. 14b) — COMPARISON OF GROUP & INDIVIDUAL TRAPPING


The steam consumption of a number of units is never the same at a moment of time and therefore, the pressure in the various steam spaces will also be different. It follows that the pressure at the drain outlet of a heavily loaded unit will be less than in the case of one that is lightly or properly loaded. Now, if all these units are connected to a common steam trap, the condensate from the heavily loaded and therefore lower pressure steam space finds it difficult to reach the trap as against the higher pressure condensate produced by lightly or properly loaded unit. The only satisfactory arrangement, thus would be to drain each steam space with own trap and then connect the outlets of the various traps to the common condensate return main as shown in Fig. 14(b).

## 6) Dirt

Dirt is the common enemy of steam traps and the causes of many failures. New steam systems contain mill scale, castings and, weld metal and pieces of packing and jointing materials, etc. When the system has been in use for a while, the inside of the pipework and fittings, which is exposed to corrosive condensate can get rusted. Thus, rust in the form of a fine brown powder is also likely to be present. All this dirt will be carried through the system by the steam and condensate until it reaches the steam trap. Some of it may pass through the trap into the condensate system without doing any harm, but inevitably, the remaining dirt will eventually jam the trap mechanism. It is advisable to use a



strainer (Fig. 15) positioned before the steam trap to prevent dirt from passing into the system.



(Fig. 15) — STRAINER


## 7) Water hammer

A water hammer in a steam system is caused by condensate collection in the plant or pipework. Picked up by the fast moving steam and carried along with it, when this collection hits obstructions such as bends, valves, steam traps or some other pipe fittings, the resulting shock is likely to cause severe damage to fittings and equipment and result in leaking pipe joints. The problem of water hammer can be eliminated by positioning the pipes so that there is a continuous slope in the direction of flow. A slope of at least 12mm in every 3 metres is necessary, as also an adequate number of drain points every 30 to 50 metres.

## 8) Lifting the condensate

In the interest of energy and treated water savings, every effort should be made to recover and re-use the condensate. Generally, this means lifting the condensate into a return main above the equipment. There may also be a case where the layout of the plant dictates that the steam traps be fitted above the equipment being drained. Wrong installation can lead to trouble. Because of the back pressures imposed upon the steam trap, it is often better not to lift the condensate directly from the trap, but to let it flow by gravity to a pump or a pumping trap which can then do the lifting. However, if it is decided that the condensate has to be lifted by its own pressure at the trap, it is important to ensure that the installation is correctly arranged.

Figure 16 shows a desirable arrangement of condensate draining and lifting. The rising pipe coil is looped to form a water seal. A small bore pipe is then passed through a steam tight joint at the top of the rising pipe, and its end is



(Fig. 16) — COIL-HEATED TANK: CORRECT LAYOUT

pushed well into the loop seal. The trap is fitted as close to the top of this pipe as possible. The water seal now makes it near impossible for the steam to enter the pipe leading up to the trap, and the small bore of this pipe ensures that the water column rises steadily due to steam bubbles.

## Maintenance of steam traps

Dirt is one of the most common causes of steam traps blowing steam. Dirt and scale are normally found in all steam pipes. Bits of jointing material are also quite common. Since steam traps are connected to the lowest parts of the system, sooner or later this foreign matter finds its way to the trap. Once some of the dirt gets logged in the valve seat, it prevents the valve from shutting down tightly thus allowing steam to escape. The valve seal should therefore be quickly cleaned, to remove this obstruction and thus prevent steam loss.

In order to ensure proper working, steam traps should be kept free of pipe-scale and dirt. The best way to prevent the scale and dirt from getting into the trap is to fit a strainer before each trap. The strainer element is a detachable, perforated or meshed screen enclosed in a metal body. It should be borne in mind that the strainer collects dirt in the course of time and will therefore need periodic cleaning.

It is of course, much easier to clean a strainer than to overhaul a steam trap (Fig. 15).

At this point, we might mention the usefulness of a sight glass fitted just after a steam trap. Sight glasses are useful in ascertaining the proper functioning of traps and in detecting leaking steam traps. In particular, they are of considerable advantage when a number of steam traps are discharging into a common return line. If it is suspected that one of the traps is blowing steam, it can be quickly identified by looking through the sight glass.

In most industries, maintenance of steam traps is not a routine job and is neglected unless it leads to some definite trouble in the plant. In view of their importance as steam savers and to monitor plant efficiency, the steam traps require considerably more care than is given. One may consider a periodic maintenance schedule to repair and replace defective traps in the shortest possible time, preferably during regular maintenance shut downs in preference to break down repairs.

## Steam trap capacity

The condensate discharge capacity of a steam trap depends mainly on three factors, viz. the size of the valve orifice, the differential pressure across it and the temperature of the condensate. It does not depend on the size of the pipe connections. But in practice, it is seen that traps are ordered on the basis of the pipe connections and not on actual process conditions.

Careful consideration should be given to the factors responsible for trap discharge capacity. For the actual discharge capacity at various differential pressures, the manufacturers' booklets should be consulted.

As a general rule, traps should not be too oversized. There are some types, such as thermodynamic traps, where the cycling rate increases if the trap is oversized, leading to rapid wearing down of the moving disc. Similarly, in very lightly loaded inverted bucket traps, the rate will increase because steam passing through the vent hole in the bucket condenses in the body. This is wasteful, if the trap is oversized. Finally, oversized traps which are physically larger than they need be, increase the radiation loss.

## 11. Proper sizing of steam and condensate pipelines

It must be remembered that there is always a right size for the steam pipe for the amount of steam it has to carry at a particular pressure. If the size is too small, then a high pressure drop as well as steam starvation at the using end will be the result. If it is too large, the capital cost of installation will unnecessarily be high, as will be the running cost due to the higher radiation losses from the larger surfaces.

### Sizing of short branch lines

For sizing short branch lines, to avoid excessive pressure drops, it is recommended that the pipe sizing be based on a

steam velocity of about 15m/sec. At velocities higher than this, for instance 25 to 30m/sec., there would be considerable noise and the erosion would be greater particularly when the steam is wet.

### Sizing of long steam mains

A sizing of steam mains based upon a velocity of 15m/sec. may lead to unacceptably high pressure drops due to heavy friction losses in long lengths of pipelines. The pressure at the receiving end would be too low. In such cases, the mains should be sized on the basis of pressure drop considerations.

### Condensate pipe sizes

If the condensate pipes are not sized properly, they may either impose unacceptably high back pressure on the traps when they are undersized, or a heavy capital investment when they are unnecessarily oversized. It should be remembered that a trap will have to handle air and flash steam in addition to the condensate from the process equipment at the time of start-up. This is followed by a large amount of relatively cool condensate (the starting load is usually two or even three times the normal running load). As normal running conditions are established, the volume of water reduces but since the pressures are higher, larger quantities of flash steam will have to be handled. As a good thumb rule, it is best to size a condensate pipe as if it were carrying water under starting conditions only. It would then have adequate capacity to carry the condensate, as well as flash steam, under running conditions and to allow for the discharge of air at start-ups. If the starting load is not known, it may be assumed, under average conditions, to be twice the running load. An appropriate size has to be chosen keeping the allowable back pressure in mind. All pipelines should preferably have a fall in the direction of the condensate flow. If the fall in a water pipe is graded so that the fall per metre is equal to or greater than the frictional resistance per metre, then the water will flow freely without causing back pressure on the traps.

## 12. Reducing the work to be done by steam


When the steam reaches the place where its heat is required, it must be ensured that the steam has no more work to do than is absolutely necessary. Air-heater batteries, for example, which provide hot air for drying, will

use the same amount of steam whether the plant is fully or partly loaded. So, if the plant is running only at 50 per cent load, it is wasting twice as much steam (or twice as much fuel) than necessary.

Always use the most economical way of removing the bulk of water from the wet material. Steam can then be used to complete the process. For this reason, hydro-extractors, spin dryers, squeeze or calender rolls, presses, etc. are initially used in many drying processes to remove the mass

#### REFERENCE:

1. The Efficient Use of Steam—Oliver Lyle, HMSO, London.
2. Spirax Sarco Manuals—Spirax Sarco Ltd., Cheltenham GL 53 8ER.
3. Fuel Economy Hand Book—NIFES, London.
4. The Efficient Use of Steam—General Editor, P.M. Goodall, Westbury House, England.



STEAM WASTAGE DUE TO INSUFFICIENT MECHANICAL DRYING

(Fig. 17)

of water. The efficiency with which this operation is carried out is most important. For example, in a laundry for finishing sheets (100 kg/hr. dry weight), the normal moisture content of the sheets as they leave the hydro-extractor, is 48% by weight.

Thus, the steam heated iron has to evaporate nearly 48 kgs of water. This requires 62 kgs of steam. If, due to inefficient drying in the hydro-extractor, the steam arrive at the iron with 52% moisture content i.e. 52 kgs of water has to be evaporated, requiring about 67 kgs of steam. So, for the same quantity of finished product, the steam consumption increases by 8 per cent. This is illustrated in Fig. 17.

**This booklet is one of a series on fuel oil conservation, others in the series are listed below:**

- 1) Storage, handling and preparation of fuel oil.
- 2) Efficient generation of steam.
- 3) Efficient utilisation of steam.
- 4) Fuel economy in furnaces and waste heat recovery.
- 5) Refractories.
- 6) Thermal insulation.

**PCRA films available for industrial sector:**

- 1) "Tuning of Boilers and Furnaces".
- 2) "Handling of Fuel Oils".
- 3) "Efficient Utilisation of Steam in Industries"  
(under production).

Set up a few years ago in anticipation of the world-wide oil crisis that's affecting us all today, PCRA seeks to promote efficient utilisation of petroleum products—in homes, in industries, in farms, on roads. Because till alternative sources of energy are found, we have to make the best use of the world's diminishing oil reserves.



**PETROLEUM CONSERVATION  
RESEARCH ASSOCIATION**


Petroleum Conservation Research  
Association, 1008, New Delhi House,  
27, Barakhamba Road, New Delhi - 110 001.

**SAVE OIL.**

**Because oil isn't going to last forever.**

5

# Fuel economy in furnaces and waste heat recovery





# Introduction

In the context of the oil crisis and high cost of fuel oil, the subject of fuel economy and waste heat recovery now requires due importance from users of industrial furnaces. Fuel costs constitute about 40 per cent of the total value added during the process of manufacture in fuel-intensive industries such as glass and ceramics, forging, re-rolling, ferrous and non-ferrous foundries, galvanizing, and several other applications.

The scope of fuel savings to the tune of 30 to 40 per cent by adoption of first aid and long term conservation measures has been amply demonstrated by PCRA's experiences in several Indian Engineering Industries.


## Fuel consumption and heat economy

The performance of a furnace installation can be expressed in various ways, the ultimate aim being the determination of the total quantity of fuel required to perform the required operation.

The term 'efficiency' in an industrial furnace, when used in the true sense, has reference to heat cost per unit weight of finished saleable product, or as the quantity of fuel expended to heat a unit weight of stock. While the efficiency in a boiler ranges from 60 to 85 per cent, the efficiency of furnaces are some times as low as 5 per cent. One reason for the difference in the efficiency between boilers and industrial furnaces is in the final temperature of the material being heated. Gases can give up heat to the charge only as long as they are hotter than the charge. Consequently, flue gases leave industrial furnaces at a very high temperature. This factor is responsible for low furnace efficiencies.

The ideal and common efficiencies of Industrial furnaces are shown in Fig.1.





(Fig.1)— IDEAL COMMON EFFICIENCIES OF INDUSTRIAL FURNACES OF THE INTERMITTENT OR BATCH TYPE

In order to have a clear understanding of the distribution of heat in a simple furnace, let us examine Fig.2 below:




Fig.2) — FLOW OF HEAT IN A FURNACE

- |                          |   |
|--------------------------|---|
| 1: STOCK                 | 5: DOOR                                 |
| 2: GROUND & SURROUNDINGS | 6: PORTION OF STOCK PROTRUDING OUTSIDE. |
| 3: HEARTH                | 7: STACK                                |
| 4: CRACKS AND OPENINGS   |   |

### Flow of heat in a furnace

The fuel oil required for combustion is cleaned, preheated and burnt in the combustion zone of the furnace. It would be desired that most of the heat liberated be imparted to the stock but the heat goes elsewhere. Some of it passes into the furnace wall and hearth as shown in Fig.2. Another portion of heat is lost to the surroundings by radiation and convection from the outer surface of the walls or by conduction, into the ground. Heat is also radiated through cracks or other openings and furnace gases pass out around the door, frequently burning in the open and carrying off heat. Heat is also lost every time the door is opened. Another form of heat dissipation is through the stock which protrudes out in certain cases. Finally, the bulk of the heat loss passes out along with the products of combustion, either in the form of sensible heat or as incomplete combustion. Fuel economy demands that the fraction of total heat that passes into the stock be as large as possible and that all the losses be minimised.

The purpose of finding out efficiency of a plant is to establish how well the plant is designed or run in comparison to another similar plant. If this view is accepted, then the efficiency of furnaces can be better assessed by measuring the amount of fuel required per unit weight of material.

## Factors affecting fuel economy

Various factors which affect fuel economy in industrial furnaces are:

- 1) Complete combustion with minimum excess air.
- 2) Proper heat distribution.
- 3) Operating at the desired temperature.
- 4) Reducing heat losses from furnace openings.
- 5) Minimising wall losses.
- 6) Control of furnace draught.
- 7) Optimum capacity utilization.
- 8) Waste heat recovery from furnace flue gases.

## 1. Complete combustion with minimum excess air

To achieve complete combustion of fuel with minimum excess air, a number of factors (such as proper selection and maintenance of control, excess air monitoring, air infiltration, pressure of combustion air) are to be considered. The magnitude of stack losses with different quantities of excess air in the case of a furnace carrying away flue gases at 900°C, is depicted in Table. I

Table-I

Table showing excess air and heat loss

Excess air percentage	Percentage of total heat in the fuel carried away by waste gases. (flue gas temperature-900°C)
25	48
50	55
75	63
100	71

Besides abnormal increase in stack losses, with the increase in excess air, the ingress of too much excess air lowers the flame temperature and consequently reduces furnace temperature and the heating rate. If too little excess air were used, combustion would be incomplete and chimney gases will carry away unused fuel potential in the form of unburnt combustible gases such as carbon monoxide, hydrogen and unburnt hydrocarbons which should have otherwise been usefully burnt in the combustion chamber.


Various considerations for better preparation of fuel oil are adequately covered in our booklet entitled 'Storage, handling and preparation of fuel oil'. The booklet entitled 'Combustion of fuel oil and burners—operation and maintenance' covers various consideration affecting combustion, selection, operation and maintenance of

burners for minimizing excess air. These aspects are not being dealt with in this booklet.

## 2. Proper heat distribution


Ideally, a furnace should be designed so that in a given time, as much material as possible, be heated to as uniform a temperature as possible with the minimum fuel firing rate. To achieve this, the following points should be considered.

- i) The flame should not touch the stock and should propagate clear of any solid object. Any obstruction whatsoever, deatomises the fuel particles thus affecting combustion and creating black smoke. If the flame touches the stock, the scale losses increase manifold (Fig. 3).



(Fig. 3) — ALIGNMENT OF BURNERS IN FURNACES

- ii) Refractories are leached if the flames touch any part of the furnace, as the incomplete combustion products can react with some of the refractory constituents at high flame temperatures.
- iii) The flames from various burners in the combustion space should also stay clear of each other. If the flames intersect, inefficient combustion would occur. This can be controlled by staggering the burners of the opposite walls.
- iv) The flame has a tendency to travel freely in the combustion space just above the material. In small reheating furnaces, the burner axis is never placed parallel to the hearth but always at an upward angle. Every precaution should be taken to ensure that the flame never hits the roof.
- v) The larger burner produces a long flame which may be difficult to contain within the furnace walls. More burners of less capacity give better distribution of heat in the furnace, and also reduce scale losses while increasing furnace life as shown in Fig. 4.



(Fig. 4) — HEAT DISTRIBUTION IN FURNACES

- vi) For smaller reheating furnaces, it is advisable to maintain a long flame with a golden yellow colour while firing furnace oil for uniform heating. It should be seen that flame should not be so long that it enters the chimney and comes out at the top or through doors. This occurs when excessive oil is fired normally to increase the production rate. Such an operational practice in the real sense helps marginally. A major portion of the additional oil fired is carried away into the stack as waste heat. It is, therefore, advisable to contain the flame within the furnace.
- vii) It is also desirable to provide the combustion volume adequate to the heat release rate. As a thumb rule, for direct fired heating furnace, a heat release equivalent to 700,000 Kcal per hr. per cubic metre of combustion volume may be used.

## 3. Operating at the desired temperature

For any given industrial heating or melting operation, there is an optimum temperature for operation of the furnace. Table II below shows operating temperature for different furnaces.

Table-II

Operating temperature for different furnaces

Slab reheating furnaces	1200°C
Rolling Mill furnace	1180°C
Bar Furnace for sheet mill	850°C
Bogey type annealing furnace	650 - 750°C
Bogey type roll annealing furnace	1000°C
Small forging furnace	1150°C
Rotary iron melting furnace	1550°C
Enamelling furnace	820 to 860°C

## Regenerators

The regeneration which is preferable for large capacities has been very widely used in glass and steel melting furnaces. Important relations exist between size of the furnace (and regenerator), time between reversals, thickness of brick, conductivity of brick and heat storage ratio of the brick.

In the regenerators, the time between the reversals is an important aspect, long periods would mean higher thermal storage and hence larger regeneration and higher cost. Furthermore, long periods of reversal result in lower average temperature of preheat and consequently reduce fuel economy.

Accumulation of dust on the bricks and slagging of the brick surfaces, cause the efficiency of heat transfer in the regenerator to decrease as the furnace becomes old. Heat losses from the walls of the regenerator and leakage of air inwards during the gas period and out during the air period, also cause an apparent decrease in the heat transfer coefficient. Taking into effect all the above factors, the overall heat transfer coefficient for checkers operating with natural draft can be taken as 4.0 to 6.5 Kcal/m<sup>2</sup>/hr/°C.

Besides, the checker brick work heat can be salvaged from flue gases by means of rotary regenerators. This device consists of multiples of slightly separated metal plates supported in





Fig. 14b - Illustration of a regenerative furnace

## Recuperators

A recuperator is a heat exchanger between the waste gas and the air to be pre-heated. It usually consists of a series of ducts or tubes, some of which carry the air to



(Fig. 14a) - REGENERATOR


a frame attached to a slowly moving rotor shaft, which is arranged edge on to the gas and air flow. As these plates pass progressively through the gas stream, they give up heat to the air before re-entering the hot gas stream, thus maintaining the regenerative cycle. Seals are provided to reduce air infiltration into the gas. Soot blowers are located in the assembly to remove soot and oil deposits periodically. The general principle of working is shown in Fig. 14.

## Charge preheating

The direct recovery of energy from waste gases can be achieved in metallurgical furnaces by preheating the incoming raw materials. The effectiveness of charge preheating depend upon the physical and dimensional properties of the material being heated along with the handling methods employed.

A continuous furnace of pusher type can be so operated that it utilises the waste heat by preheating the stock. If the rate of heating is low, most of the heat is imparted to the stock at the hot end, and the products of combustion can preheat the slowly moving ingots.

A typical example of charge preheating with waste gases is a forging furnace for production of hand tools. This is explained schematically in Fig. 12.




(Fig. 12)

**Preheating of combustion air**

Considerable fuel savings can be affected by preheating the combustion air, and the heat saving devices used for this purpose, are the recuperator and the regenerator. The saving of fuel oil by preheating of air is shown in Fig. 13

**Advantages of hot combustion air**

- 1) Saving in fuel consumption.
- 2) Increase in flame temperature.
- 3) Improvement in combustion.
- 4) Reduction in initial heating time.
- 5) Reduction in scale losses.



(Fig. 13)

In a recuperator, heat exchange takes place between the flue gases and the air through metallic or ceramic walls. On the other hand, in a regenerator, the flue gases and the air to be heated are passed alternatively through a heat storing medium, thereby resulting in transfer of heat.

A comparison of the advantages of recuperator over a regenerator is shown below:

Recuperator	Regenerator
Requirement of size and space	Higher
Where used	Glass and Steel
Smaller engines	Smaller engines
Requirement of civil work	Large
Initial installation and maintenance cost	High
Low	Small

## Insulating materials

Insulating materials owe their lower conductivity to the pores, while their thermal inertia depends on the weight per unit volume of solids and its specific heat. There are, in general, three types of insulating bricks:

- Products made from diatomaceous earth.
- Products derived from vermiculite.
- Refractory (fireclay or silica) based products.

The latter (c) are known as insulating refractories and are used as inner lining in furnaces.

There are two methods of insulation normally used for high temperature furnaces. When the furnace is operating continuously under severe condition of atmosphere or high temperature, a lagging of diatomaceous insulation is placed behind a dense refractory base. In other installations where cleaner conditions or a lower temperature prevail, particularly in short cycle intermittent furnaces and kilns, the insulating material can itself form the refractory lining with no back up refractory bricks.

Materials of the latter type are highly porous refractory and have fair strength and spalling resistance, and can in general, be used up to a temperature as high as 1800°C.

Another class of materials (ceramic fibres) with very low conductivity, and extremely light weight, with the capacity to withstand thermal shocks can also be used in intermittent furnaces.

Various aspects, on heat savings through the choice of appropriate refractories and insulation, have been highlighted in a booklet in this series entitled 'Refractories'.


## 6. Control of furnace draught

In any furnace, the entrance of uncontrolled free air must be prevented. It pays to maintain a slight excess pressure inside the furnaces to avoid air infiltration. Large furnaces, especially those with stack draft, are equipped with pressure sensing devices which by relays and servomotors, adjust dampers or adjust the flow of protective gas into the furnace.

At furnace temperatures, oxygen attacks the common metals and forms oxides or scale. Carbon monoxides and hydrogen reduce the oxides to metal. On the basis of these considerations, the term "oxidizing atmosphere" and "reducing atmosphere" (both referring to products of combustion) were coined and adopted years ago.

Reducing atmospheres (excess of fuel) form less scale than that which is formed by oxidizing atmospheres (excess of air) but the scale is tight and adheres firmly. More scale is formed in oxidizing atmospheres but this scale is more easily removable.

The effect of air infiltration on furnace draught is illustrated in Fig. 9.




(Fig.9)— EFFECT OF NEGATIVE PRESSURES ON AIR INFILTRATION

If negative pressures exist in the furnace, air infiltration is liable to occur through the cracks and openings thereby affecting air-fuel ratio control. Tests conducted on apparently air tight furnaces have shown air infiltration up to the extent of 40%. Neglecting furnace pressure could mean problems of cold metal and non-uniform metal temperatures, which could affect subsequent operations like forging and rolling and result in increased fuel consumption.

The furnace pressure is constant in different parts of the furnace. The zero level in the furnace is the level at which the furnace pressure equalizes the atmospheric pressures. The effect of air pressure on the location of zero level is shown in Fig. 10.

It has been observed that minimum consumption of fuel occurs at considerably higher furnace pressures, than that required to keep zero level at the hearth. This phenomenon is due to exfiltration. Exfiltration is less serious than infiltration. Some of the associated problems with





(Fig.10) — EFFECT OF PRESSURE ON THE LOCATION OF ZERO LEVEL AND INFILTRATION OF AIR.

exfiltration are leaping out of flames, overheating of the furnace refractories leading to reduced brick life, increased furnace maintenance, burning out of ducts and equipments attached to the furnace, etc.

## 7. Optimum capacity utilisation

When the initial design of a furnace is considered, it is desirable that discussions take place with all parties involved in the process. The aim being to obtain the correct furnace for the jobs in hand. One factor which must be considered is whether the work can be processed in a continuous furnace or should a batch type be used.

If stock can be fed continuously at one end of a furnace and discharged through the other, then the overall efficiency will increase with load recuperation from the waste gas products.

If it is not possible to use a continuous furnace, then careful planning of the loads for batch type furnaces is essential. A furnace should be recharged as soon as possible (within the metallurgical and other physical limitations) to enable any residual furnace heat to be used.

### Furnace loading


One of the most vital factors affecting efficiency is loading. There is a particular loading at which the furnace will operate at maximum thermal efficiency. If the furnace is

under-loaded, a smaller fraction of the available heat in the working chamber will be taken up by the load and therefore the efficiency will be low.

The best method of loading is generally obtained by trial, noting the weight of material put in at each charge, the time it takes to reach a given temperature and the amount of fuel used.

Care should be taken to load a furnace at the rate associated with optimum efficiency, although it must be realised that limitations to achieving this are sometimes imposed by work availability or other factors beyond operational control.

The "no-load" consumption to maintain a simple batch type furnace at 1300°C when empty is about 70% of that required to operate at the optimum loading rate.



(SLOT REHEATING FURNACE: 1.35 m<sup>2</sup> HEARTH AREA TEMPERATURE 1300°C)  
(Fig.11)

Fig 11 above indicates the effect of increased loading rates on thermal efficiency, and performance of a typical slot type reheating furnace for drop forgings. The heat balance computations are at different hearth loading values, given in Table III. The effect of loading on continuous furnace performances are tabulated in Table IV. This illustrates the advantage of operating the furnaces at the highest economic furnace loading. Hearth loading rates normally expected in good practices for some typical furnaces are given in Table V.

Table-III

## Effect of hearth loading on thermal balance and specific fuel consumption

	Hearth loading (kg/m <sup>2</sup> /hr.)			
	98	147	244	366
Furnace output kg/hr	125	187	312	468
Heat in steel at 1200°C million Kcal/hr. = H <sub>c</sub>	.026	.039	.065	.097
Heat in furnace structure million Kcal/hr. = H <sub>s</sub>	.063	.063	.063	.063
Total Heat required: $\frac{H_c + H_s}{0.4} = H_I$	0.222	0.255	0.318	0.403
Ratio of $\frac{\text{Heat to Steel } H_c}{\text{Heat to Structure } H_s} = \frac{H_c}{H_s} \%$	11.6	15.2	20.3	29.0
Fuel consumption Million Cal/tonne	1800	1384	1040	880
Fuel and Financial Savings%	—	23	42	51

Slot Type Reheating Furnace for Drop Forging

Effective Hearth Area: 1.277 metre<sup>2</sup>.

Exit Gas Condition: 1320°C and 10% Excess Air

Total heat to structure: .063 million Kcal/hr, Heat in gas leaving furnace: 60%

Heat available in furnace: 40%

Table-IV

## Effect of loading on continuous furnace performance

Production Rate	Tonnes/hr.	10.0	5.0	3.0	1.0
Heat to stock	million Cal	1760	880	530	176
Waste gas loss	"	2520	1760	1510	1290
Structure loss	"	1760	1760	1760	1760
Heat loss input	"	6040	4400	3800	3226
Specific heat consumption	million Cal/tonne	604	880	1267	3226



**Table-V**

**Typical hearth loading rates normally expected in good practice**

	Kg/m <sup>2</sup> /h
Heat treatment furnace	147 — 195
Annealing furnace	195 — 293
Drop stamping and forging	293 — 390
Continuous reheating	342 — 489

### Placing of stock

The disposition of the load on the furnace hearth should be arranged so that:

- It receives maximum radiation from the hot surfaces of the heating chamber and the flames.
- The hot gases are efficiently circulated around the heat receiving surfaces.
- There should be adequate spacing between the billets. Overlapping of materials, results in non-uniformity of temperature and should be avoided.

Stock should not be placed in the following positions:

- In the direct path of the burners or where flame impingement is likely to occur.
- In an area which is likely to cause a blockage or restriction of the flue system of the furnace.
- Close to any door openings where cold spots are likely to develop.

### Load residence time

In the interest of fuel economy and work quality, the materials comprising the load should only remain in the furnace for the minimum stipulated time to obtain the required physical and metallurgical requirements.

When the materials attain these properties they should be removed from the furnace to avoid damage and fuel wastage. For heating steels, the general rule is that heat travels 3mm in 5 minutes. For cylindrical square bars, the prescribed heating rate is 20 minutes per 25 mm of diameter of mild steel; and 40 minutes per 25 mm of diameter for alloy steels. For annealing of steel, 60 minutes are needed per 25 mm of diameter or thickness. The above values hold for the furnaces where the stock size is relatively small with respect to the size of the furnace.

Furnaces should be operated at their optimum rated capacity to achieve best fuel economy. This involves proper

co-ordination among the various departments, selection of appropriate size and type of the furnace and material handling system. Frequent breakdowns in the production machines make the furnace idle for lengthy periods, thus causing extra expenditure on fuel. Economy could be achieved by collecting an adequate sequence of charges, operating the furnace continuously at the most economical loading and then shutting down entirely for a given period if insufficient work is available. When shut down, all sources of air leakage should be minimised.

## 8. Waste heat recovery from furnace flue gases

In any industrial furnace the products of combustion leave the furnace at a temperature higher than the stock temperature. Sensible heat losses in the flue gases, while leaving the chimney, carry 35 to 55 per cent of the heat input to the furnace. Typical quantities of waste heat available in different operations are listed in Table VI below:

**Table-VI**

Furnace	Temperature (°C)
Copper reverberatory furnace	: 1100-1400
Forge and billet heating furnace	: 800-1100
Glass melting furnace	: 1000-1300
Open hearth steel furnace air blown	: 550- 700
Furnace oxygen blown	: 700-1150
Annealing furnace	: 600-1100
Ceramic kilns (Down draft)	: 70-1100

The higher the quantum of excess air and flue gas temperature, the higher would be the waste heat availability.

The sensible heat in flue gases can be generally salvaged by the following two methods:

- Charge preheating.
- Preheating of combustion air.

Besides, there are other recovery techniques such as steam generation through waste heat boilers, gas turbine systems, vapour absorption, refrigeration systems, etc. However, coverage on the above systems fall outside the perview of this booklet.

One of the industries for melting 500 kg of gun metal per hour in a reverberatory furnace, it was found that there was as much flame burning outside the furnace as it was inside. This was being practised by the operators thinking that melt time was shorter if the flame leaps out.

In order to stop this wasteful practice, an experiment was conducted on two identical furnaces; gun metal to be melted was weighed and charged to both furnaces at the same time. One furnace was operated as it was normally done by the operators, and the other furnace was operated by confining the flame within the furnace and closing all openings with refractory bricks. In both cases, the time taken and fuel consumed to melt the charge was noted. The exercise was repeated by interchanging the furnaces and the time taken and fuel consumed noted again.

The experiment revealed, to the surprise of the management of the industry and their operators, that the time taken to melt the charge by controlling the flame within the furnace was the same as in the case of the furnace with flames leaping out. But most important of all was that the fuel consumption was almost half where the flames were contained within, as opposed to the other furnace where flames leapt out.

Hence it is imperative that all unnecessary openings of the furnaces be sealed and the flame be contained within the furnace.

Doors should be tightly shut and made of light material that is durable and heat proof. Doors that are hinged or swinging type may be provided. To minimise heat losses, the refractory lining should be sufficiently thick and of good insulation quality. Fig.7 illustrates the method of holding cement in a door frame.


In order to reduce fatigue as well as to ensure ease in closing the opening, vertically lifting doors balanced by counter weights, should be used as shown in Fig. 8.

## 5. Minimising wall losses


About 30-40% of the fuel input to the furnace generally goes to make up for heat losses in intermittent or continuous furnaces. The appropriate choice of refractory and insulation materials goes a long way in achieving fairly high fuel savings in industrial furnaces.

### Insulation for furnaces

In industrial furnaces, fuel consumption can be substantially reduced by judicious application of external



(Fig.7) — METHODS OF HOLDING CEMENT IN DOOR FRAME



(Fig.8) — FURNACE DOOR LIFTING MECHANISM WITH COUNTER WEIGHT

insulation. Several material with different combinations of heat insulation and thermal inertia should be considered to minimise heat losses through furnace walls. The use of insulating refractories of appropriate quality and thickness can cut down heat storage capacity of walls, and time required to bring the furnace to operating temperature by as much as 60-70 per cent in intermittent furnaces.

Operating at too high a temperature will not only mean unnecessary waste of fuel in terms of heat, but will also cause overheating of the stock, its spoilage or excessive oxidation and decarburization as well as over-stressing the refractories. Normally, in most of the plants, the decision on the proper operating temperature is left to the judgement of the operators. In order to avoid human error, provisions for temperature control instruments should be made.

The furnaces are often run without any temperature controls, often with 'on-off control', which is extremely harmful to the optimum performance of the furnace. In the 'off' condition, only the atomising air enters the furnace bringing down its temperature rapidly so that when the oil firing process is recommended, the amount of oil supplied to the furnace to bring up the temperature, is much more than would be necessary had the furnace been operated on a 'proportional control'.

## 4. Reducing heat losses from furnace openings

In oil fired furnaces, substantial heat losses occur through furnace openings. For every large opening, heat loss due to openings may be calculated by computing black body radiation at furnace temperature, and multiplying these values with emissivity (usually 0.8 for furnace brick work), and the factor of radiation through openings. The black body radiation losses can be directly computed from the curve as seen in Fig.5. Factor for radiation through openings can be determined with the help of nomogram as in Fig.6.

Heat loss through openings = Area of cross section × Factor of radiation through openings × Black body radiation.

### Example

A furnace front at 1000°C is bricked up with a 115mm wall through an observation opening (peephole) of 65mm × 115mm which is left open. The heat losses through the opening are worked as under:

Area of opening =  $6.5 \times 11.5 = 74.75 \text{ cm}^2$

D/X Ratio of sides of rectangle =  $115/65 = 1.77$


Factor for radiation through opening = 0.71 (from Fig.6)

Emissivity = 0.8


Black Body Radiation corresponding to 1000°C  
= 1200 Kcal/cm<sup>2</sup>/hr. (from Fig.5).

Therefore heat loss =  $74.75 \times 1200 \times 0.71 \times 0.8$   
= 51,000 Kcal/hr.

Equivalent fuel oil loss = 5.4 lit/hr



(Fig.5) — BLACK BODY RADIATION



(Fig.6) — RADIATION THROUGH OPENINGS OF VARIOUS SHAPES

Assuming the heat carried in the stack to be 60% of heat supplied  
equivalent oil savings = 13 litres/hour.

combustion to be pre-heated, the others contain the sources of waste heat.

The recuperators may be of ceramic or metallic types. The ceramic recuperators are bulky and offer considerable resistance to transfer of heat because of low conductivity and also have a greater tendency for leakages. Metallic recuperators, however, are less prone to leaks and thermal expansions and can be controlled. Metallic recuperators are easier to maintain and install and involve less initial cost. Due to the above reasons, ceramic recuperators are not widely in use.

Some of the common flow arrangements encountered in recuperators are depicted in Figs. 15 and 16.


In a parallel flow recuperator, the air and hot gases flow in the same direction. In a counter flow recuperator, the direction of flow of hot gases is opposite to that of air.

However, in a cross flow recuperator, the air and hot gases flow at right angles to each other.


The considerations for design and selection of a metallic recuperator must take into account

- waste gas temperature.
- desired air/fuel gas pre-heat.
- initial cost and maintenance cost.
- materials available for use in recuperator.
- operating pressure, on the fuel gas and combustion air side, as well as permissible pressure drops in the recuperator system.
- availability of space for installation of recuperator.
- campaign life of furnace and reliability desired in the system.


Metallic recuperators can be of three basic types depending on the method of heat transfer, viz., radiation, convection, combined convection and radiation type.




**GAS DOWNFLOW  
AIR AND GAS COUNTERFLOW  
SINGLE PASS**




**GAS UPFLOW  
AIR COUNTERFLOW,  
THREE PASS**




**GAS UPFLOW AND DOWNFLOW  
AIR COUNTERFLOW,  
SINGLE PASS**



**GAS UPFLOW AND DOWNFLOW  
AIR COUNTERFLOW, SINGLE PASS**





**GAS UPFLOW  
AIR COUNTERFLOW, TWO PASS**





**GAS DOWNFLOW  
AIR PARALLEL FLOW, THREE PASS**



(Fig.15)



**COUNTER-FLOW RECUPERATOR AND TEMPERATURE DISTRIBUTION.**




**PARALLEL-FLOW RECUPERATOR AND TEMPERATURE DISTRIBUTION.**



**CROSS-FLOW RECUPERATOR AND TEMPERATURE DISTRIBUTION**

### Radiation recuperator

In a radiation recuperator, the products of combustion enter the recuperator through an opening in the furnace roof while air flows at a higher velocity through a narrow annulus between the outer and inner walls. The outer shell is insulated. Fins are provided on the inner shell to increase the heat transfer area. This type of a simple recuperator is particularly suitable for small forging furnaces. This is shown in Fig. 17



(Fig.17) — METALLIC RADIATION RECUPERATOR

Radiation recuperators can operate with waste gas temperatures in the range of 1000 to 1500°C to pre-heat air up to 600°C. The advantage of radiation recuperator over convection recuperator is that the heat transfer is intensive through radiation and also offers possibility of a higher air pre-heat. Other advantages are low pressure drop in flue gas side because of larger cross sections, thereby enhancing the possibility of using dust laden waste gases.

### Convection recuperator

These types of recuperators can be with a heating system made up of either drawn steel tubes, or cast tubes. Convection recuperators are used with flue gas temperatures from 300 to 1050°C; the degree of air preheat is limited to 600°C

### Combined radiation and convection recuperator

The advantages of radiation and convection recuperators are combined in the arrangement of heat exchanging surfaces. In this system, a tube bundle is arranged in a ring inside a double shell type recuperator.

A case study of a galvanizing furnace in a steel tube plant showed significant fuel savings on installation of a metallic recuperator as illustrated below:

System: heating of combustion air in a recuperator.

Average consumption of furnace oil in the furnace: 3000 litres/day (24 hrs.)

Temperature of flue gases before heat recovery: 580°C.

Temperature of flue gases after installation of recuperator at the exit: 400°C.

Temperature of combustion air at recuperator outlet: 320°C.

Quantity of air heated: 2000 N. Cubic Metres/hr.

Quantity of heat recycled back to the furnace by preheating of combustion air: 1,71,000 Kcal/hr.

Quantity of furnace oil saved per day: 500 litres/day (Rs. 1400/day)

Monthly saving in furnace oil: Rs. 42,000

Investment on the system: Rs. 1,05,000

Payback period on investment: 2½ months.

**Quantitatively, every 21°C rise in combustion air temperature results in one percent fuel oil savings.**

However, the quantum of savings are normally greater with higher flame temperature, reduced excess air levels and higher productivity of the furnace.

### Failure of metallic recuperator

Some of the major sources of metallic recuperators and the possible remedies are discussed here below:

#### Oxidation

Parts of the recuperator which reach temperatures of 500°C and above are subjected to oxidation by oxygen, water vapour or carbon dioxide present in waste gases. The

intensity of attack depends on the temperature of surfaces as well as the concentration of oxidants in the gases. However, alloys are readily available today to counter oxidation up to a wall temperature of 1100°C. However, one must consider the fact that ultimately the recuperator will suffer scaling and will need replacement. Alloying elements in steel such as chromium, silicon, nickel are used to withstand high temperature services.

### **Sulphur attack**

The action of sulphur on the waste gases depends on the nature of gases (oxidising or reducing), temperature of gases, wall temperature and on the type of metal used as the heat exchanging surfaces. At the hot end of a recuperator with flue gases of oxidising nature, and the presence of vanadium oxides sulphur in the waste gases is corrosive. At the cooler end of recuperator, acid corrosion may occur due to the action of sulphur, if metal temperatures drop below the acid dew point of gases. Acid dew point for products of combustion depends mainly upon the sulphur content of the fuel and varies from 130°C with 1% sulphur to about 180°C with 4% sulphur in the fuel. The problem of low temperature corrosion is taken care of at the time of designing the recuperator, by ensuring that the wall temperature in all parts of the recuperator are well above the acid dew point of gases. This is done by choosing a suitable gas/air flow pattern and other changes in the constructional features of a recuperator.

### **High temperature corrosion**

High temperature corrosion means the corrosion attack on metallic surfaces in a certain temperature range caused through traces of vanadium contained in the fuel oil ash. The insoluble metal oxides in the fuel ash, viz., vanadium pentoxide and sodium oxide, cause considerable corrosion when the metal temperature is in the range of about 680°C. The hazards of high temperature corrosion is to be avoided by maintaining the metal wall temperature of a recuperator below 600°C. This limitation is not there in case of Ceramic Recuperator.

### **Cracking and leakage in heat exchanging parts**

This type of failure in a recuperator is due to the thermal expansion not being contained fully in different parts of the recuperator. Sometimes, this also occurs if the recuperator which is supposed to expand in a particular direction is restricted due to any shift or changes in the refractories housing the recuperator. This problem can be countered by paying considerable attention to thermal expansion in the metallic recuperator at the design stage.

### **REFERENCE:**

1. Industrial Furnaces (Vol. I & II)—W. Trinks & M.H. Mawhinney, John-Wiley Publication.
2. Fuel Economy Hand Book—NIFES, London.
3. Industrial Energy Conservation—A Handbook for Engineers and Managers—D.A. Reay, Pergamon Press Ltd.

**This booklet is one of a series on fuel oil conservation, others in the series are listed below:**

- 1) Combustion of fuel oils & Burners—operation and maintenance.
- 2) Efficient generation of steam.
- 3) Efficient utilisation of steam.
- 4) Fuel economy in furnaces and waste heat recovery.
- 5) Refractories.
- 6) Thermal insulation.

**PCRA films available for industrial sector:**

- 1) "Tuning of Boilers and Furnaces".
- 2) "Handling of Fuel Oils".
- 3) "Efficient Utilisation of Steam in Industries"  
(under production).





Set up a few years ago in anticipation of the world-wide oil crisis that's affecting us all today, PCRA seeks to promote efficient utilisation of petroleum products—in homes, in industries, in farms, on roads. Because till alternative sources of energy are found, we have to make the best use of the world's diminishing oil reserves.






**PETROLEUM CONSERVATION  
RESEARCH ASSOCIATION**

Petroleum Conservation Research  
Association, 1008, New Delhi House,  
27, Barakhamba Road, New Delhi - 110 001.

**SAVE OIL.**  
**Because oil isn't going to last forever.**

6

Refractones





# Introduction

Manufacturing processes involving high temperatures whether melting, refining, sintering, heating, and soaking or heat treatment, need refractories to withstand service conditions at the desired operating temperatures. Use of the right type of refractories in furnaces and kilns, increase their efficiency and result in substantial fuel savings.

This booklet covers the types of refractories, their properties and applications, and how they may be applied to give better fuel efficiency and service life.

# What is a refractory?

Any material can be described as 'refractory,' if it can withstand the action of abrasive or corrosive solids, liquids or gases at high temperatures.

The various combinations of conditions in which refractories are used, make it necessary to manufacture a range of refractory materials with different properties. Refractory materials are made in varying combinations and shapes and for different applications.

## Requirements of refractories

The general requirements of a refractory material can be summed up as:

- \* Its ability to withstand high temperatures.
- \* Its ability to withstand sudden changes of temperatures.
- \* Its ability to withstand action of molten metal slag, glass, hot gases, etc.
- \* Its ability to withstand load at service conditions.
- \* Its ability to withstand load and abrasive forces.
- \* Low coefficient of thermal expansion.
- \* Should be able to conserve heat.
- \* Should not contaminate the material with which it comes into contact.

## Properties of refractories

Some of the important properties of refractories are:

**Melting point:** Pure substances melt sharply at a definite temperature. Most refractory materials consist of high melting particles bonded together. At high temperature, glass fuses and as the temperature rises, the resulting slag increases in quantity by partial solution of the refractory particles. The temperature at which this action results in failure of a test pyramid (cone) to support its own weight is called, for convenience, the melting point of the refractory. Table 1 shows the melting point of some pure compounds used as refractories.

**Table-I**  
**Melting points of pure compounds**

Pure compound	Formula	Melting temperature °C
Alumina	$\text{Al}_2\text{O}_3$	2050
Lime	$\text{CaO}$	2570
Chromite	$\text{FeOCr}_2\text{O}_3$	2180
Chromium Oxide	$\text{Cr}_2\text{O}_3$	2275
Magnesia	$\text{MgO}$	2800
Silica	$\text{SiO}_2$	1715
Titania	$\text{TiO}_2$	1850

**Size:** The size and shape of the refractories is a part of the design feature. It is an important feature in design since it affects the stability of any structure. Accuracy and size is extremely important to enable proper fitting of the refractory shape and to minimise the thickness and joints in construction.


**Bulk density:** A useful property for refractories is bulk density, which defines the material present in a given volume. An increase in bulk density of a given refractory increases its volume stability, its heat capacity, as well as resistance to slag penetration.

**Porosity:** The apparent porosity is a measure of the volume of the open pores, into which a liquid can penetrate, as a percentage of the total volume. This is an important property in cases where the refractory is in contact with molten charge and slags. A low apparent porosity is desirable since it would prevent easy penetration of the refractory size and continuity of pores will have important influences on refractory behaviour. A large number of small pores is generally preferable to an equivalent number of large pores. However, a measure of the true porosity which also takes into account the volume of closed pores, gives a reasonable idea of the texture of the material, as well as sintering characteristics. In fact, porosity, bulk density and apparent solid density have been termed rightly as "Vital statistics" of refractory shapes.

**Cold crushing strength:** The cold crushing strength, which is considered by some to be of doubtful relevance as a useful property, other than that it reveals little more than the ability to withstand the rigours of transport, can be used as a useful indicator to the adequacy of firing and abrasion

resistance in consonance with other properties such as bulk density and porosity.

**Pyrometric cone equivalent:** Temperature at which a refractory will deform under its own weight is known as its softening temperature which is indicated by PCE. Refractories, due to their chemical complexity, melt progressively over a range of temperature. Hence refractoriness or fusion point is ideally assessed by the cone fusion method. The equivalent standard cone which melts to the same extent as the test cone is known as the pyrometric cone equivalent. Thus in Fig. 1, refractoriness of Sample A is much higher than B and C.



(Fig.1)—PYROMETRIC CONES

The pyrometric cone equivalent indicates only the softening temperature. But, in service the refractory is subjected to load which would deform the refractory at a much lower temperature than that indicated by PCE. With change in the environmental conditions, such as reducing atmosphere, the P.C.E. value changes drastically.

**Refractoriness under load:** The refractoriness under load test (RUL test) gives an indication of the temperature at which the bricks will collapse, in service conditions with similar load.

However, under actual service where the bricks are heated only on one face, most of the load is carried by the relatively cooler rigid portion of the bricks. Hence the RUL test gives only an index of the refractory quality, rather than a figure which can be used in a refractory design. Under service conditions, where the refractory used is heated from all sides such as checkers, partition walls, etc. the RUL test data is quite significant.

**Creep at high temperature:** Creep is a time dependent property which determines the deformation in a given time and at a given temperature by a material under stress. The criterion of acceptance usually adopted is; that

compressive creep under the required conditions of load and temperature shall not exceed 0.3% in the first 50 hours of the test. This figure has been found to indicate that the creep rate falls by a negligible amount at the end of the stipulated period, and therefore the refractory can be considered safe to use for a much longer time.

**Volume stability, expansion, and shrinkage at high temperatures:** The contraction or expansion of the refractories can take place during service. Such permanent changes in dimensions may be due to:

- i) The changes in the allotropic forms which cause a change in specific gravity.
- ii) A chemical reaction which produces a new material of altered specific gravity.
- iii) The formation of liquid phase.
- iv) Sintering reactions.
- v) It may also happen on account of fluxing with dust and slag or by the action of alkalis on fireclay refractories, to form alkali-alumina silicates, causing expansion and disruption. This is an example which is generally observed in blast furnaces.

While it is desirable that all these changes are effected during manufacturing, it is not possible due to economic reasons, as the process is time dependent. Permanent Linear Change (PLC) on reheating and cooling of the bricks give an indication on the volume stability of the product as well as the adequacy of the processing parameters during manufacture. It is particularly significant as a measure of the degree of conversion achieved in the manufacture of silica bricks.

**Reversible thermal expansion:** Any material when heated, expands, and contracts on cooling. The reversible thermal expansion is a reflection on the phase transformations that occur during heating and cooling. The PLC and the reversible thermal expansion are followed in the design of refractory linings for provision of expansion joints. As a general rule, those with a lower thermal expansion co-efficient are less susceptible to thermal spalling.

**Thermal conductivity:** Thermal conductivity depends upon the chemical and mineralogical compositions as well as the glassy phase contained in the refractory and the application temperature. Although it is one of the least important properties as far as service performance is concerned, it evidently determines the thickness of brick work.

The conductivity usually changes with rise in temperature. In cases where heat transfer is required through the brick work, for example in recuperators, regenerators, muffles,

etc. the refractory should have high conductivity. Low thermal conductivity is desirable for conservation of heat by providing adequate insulation.

The provisions for back-up insulation, conserves heat but at the same time it increases the hot face temperature and hence the demand on the refractory quality increases. Accordingly, insulation on the roof in open hearth furnaces is normally not provided, otherwise it would cause failure due to severe dripping. Depending on the characteristic of the refractory used in the hot face, such as the high temperature load bearing capacity, it may be required that the quality of the brick be increased to the rise in temperature caused by over insulation.

Light weight refractories of low thermal conductivity find wider applications in the moderately low temperature heat treatment furnaces, where its primary function is usually conservation of energy. It is more so in case of batch type furnaces where the low heat capacity of the refractory structure would minimise the heat storage during the intermittent heating and cooling cycles.

# Classification of refractories

Refractories can be classified on the basis of chemical composition and use and methods of manufacture as shown below:

Examples	
<b>Classification based on Chemical composition</b>	
ACID—which readily combines with bases.	Silica, Semisilica, Alumino-silicate.
BASIC—which consists mainly of metallic oxides which resists the action of bases.	Magnesite, Chromemagnesite, Dolomite.
NEUTRAL—which doesn't combine; neither with acids nor bases.	Chrome, Pure, Alumina.
Special	Carbon, Silicon Carbide, Zirconia.
<b>Classification based on end use</b>	Blast Furnace Casting Pit

<b>Classification based on method of manufacture</b>	—Dry Press Process —Fused Cast —Hand Moulded —Formed (Normal, fired or chemically bonded.) —Unformed (Monolithics—plastics, Ramming Mass, Gunning, Castable, Spraying.)
--	---

Some of the typical refractories in industrial use are as under:

**Fireclay refractories**  
Fireclay refractories, such as firebricks, siliceous fireclays and aluminous clay refractories consist of aluminous silicates with various amounts of silica adding up SiO<sub>2</sub> content of less than 78% and containing less than 44% of Al<sub>2</sub>O<sub>3</sub>.

Table 2 shows that as the quantity of impurities increases and the amount of Al<sub>2</sub>O<sub>3</sub> decreases, the melting point of fireclay brick decreases. Owing to its relative cheapness and widespread location of the raw materials used to manufacture firebricks, this material finds uses in most furnaces, kilns, stoves, etc.

Table-II  
Properties of typical fireclay bricks

Brick	Percent SiO <sub>2</sub>	Percent Al <sub>2</sub> O <sub>3</sub>	Other Constituents	PCE °C
Super Duty	49-53	40-44	5-7	1745-1760
High Duty	50-80	35-40	5-9	1690-1745
Intermediate	60-70	26-36	5-9	1640-1680
High Duty (Siliceous)	65-80	18-30	3-8	1620-1680
Low Duty	60-70	23-33	6-10	1520-1595

Firebrick is the most common form of refractory material. It is used extensively in the iron and steel industry, non-ferrous metallurgy, glass industry, pottery kilns, cement industry, and by many others.



### High alumina refractories

Alumino silicate refractories containing more than 45% alumina are generally termed as high alumina materials. The alumina concentration ranges from 45 to 100%. The refractoriness of high alumina refractories increases with increase in alumina percentage. The applications of high alumina refractories includes the hearth and shaft of blast furnaces, ceramic kilns, cement kilns, glass tanks and crucibles for melting a wide range of metals.

### Silica brick

Silica brick (or Dinas) is a refractory material containing at least 93%  $\text{SiO}_2$ . The raw material is quality rocks. Various grades of silica brick have found extensive use in the iron and steel melting furnaces. In addition to high fusion point mulite type refractories, the other important properties are their high resistance to thermal shock (spalling) and their high refractoriness. It finds typical use in glass making and steel industry.

The outstanding property of silica brick is that it does not begin to soften under high loads until its fusion point is approached. This behaviour contrasts with that of many other refractories, for example alumino silicate materials, which begin to fuse and creep at temperatures considerably lower than their fusion points. Other advantages are flux and slag resistance, volume stability and high spalling resistance.

### Magnesite

Magnesite refractories are chemically basic materials, containing at least 85% magnesium oxide. They are made from naturally occurring magnesite ( $\text{MgCO}_3$ ).

The properties of magnesite refractories depend on the concentration of silicate bond at the operating temperatures. Good quality magnesite usually results from a  $\text{CaO-SiO}_2$  ratio of less than 2 with a minimum ferrite concentration, particularly if the furnaces lined with the refractory operate in oxidizing and reducing conditions. The slag resistance is very high particularly to lime and iron rich slags.

### Chromite refractories

Here, a distinction must be made between chrome-magnesite refractories and magnesite-chromite-refractories. Chrome-magnesite material usually contain 15-35%  $\text{Cr}_2\text{O}_3$  and 42-50%  $\text{MgO}$  whereas magnesite-chromite refractories contain at least 60%  $\text{MgO}$  and 8-18%  $\text{Cr}_2\text{O}_3$ .

Chrome-magnesite refractories are made in a wide range of qualities and are used for building the critical parts of high

temperature furnaces. These materials can withstand corrosive slags and gases and have high refractoriness. The magnesite-chromite products are suitable for service at the highest temperatures and in contact with the most basic slags used in steel melting. Magnesite-chromite usually has a better spalling resistance than chrome-magnesite.

### Zirconia refractories

Zirconium dioxide ( $\text{ZrO}_2$ ) is a polymorphic, material. There are certain difficulties in its usage and fabrication as a refractory material. It is essential to stabilise it before application as a refractory. This is achieved by incorporating small quantities of calcium, magnesium and cerium oxide, etc. Its properties depend mainly on the degree of stabilisation and quantity of stabiliser as well as the quality of the original raw material. Zirconia refractories have a very high strength at room temperature which is maintained upto temperatures as high as  $1500^\circ\text{C}$ . They are, therefore, useful as high temperature constructional materials for furnaces and kilns. The thermal conductivity of zirconium dioxide is found to be much lower than that of most other refractories and the material is therefore used as a high temperature insulating refractory.

Since Zirconia exhibits very low thermal losses and does not react readily with liquid metals, it is particularly useful for making refractory crucibles and other vessels for metallurgical purposes. Zirconia is a useful refractory material for glass furnaces primarily since it is not easily wetted by molten glasses and because of its low reaction with them.

### Oxide refractories (Alumina)

Alumina refractory materials which consist of aluminium oxide with little traces of impurities are often known as pure alumina.

Alumina is one of the most chemically stable oxides known. It is mechanically very strong, insoluble in water and super heated steam, and in most inorganic acids and alkalis. Its properties make it suitable for the shaping of crucibles for fusing sodium carbonate, sodium hydroxide and sodium peroxide. It has a high resistance in oxidising and reducing atmosphere. Alumina is extensively used in heat processing industries. Highly porous alumina is used for lining furnaces operating up to  $1850^\circ\text{C}$ .

## Monolithics

Monolithic refractories are replacing the conventional type fired refractories at a much faster rate in many applications



including those of industrial furnaces. The main advantages being:

- i) It eliminates joints which is an inherent weakness.
- ii) Method of application is faster and skilled measures in large number are not required.
- iii) Transportation and handling are simple.
- iv) Offers better scope to reduce downtime for repairs.
- v) Offers considerable scope to reduce inventory and eliminate special shapes.
- vi) It is a heat saver.
- vii) Has better spalling resistance.
- viii) Has greater volume stability.

Various means are employed in the placement of monolithics like ramming casting, gunniting, spraying, sand slinging, etc. Ramming masses are used mostly in cold applications where proper consolidation of the material is important. The same practice can be adopted with both air setting and heat setting materials. Proper ramming tools need to be selected.

Castables by name implies a material of hydraulic setting in nature. Calcium aluminate cement being the binder, it will have to be stored properly to prevent moisture absorption. Further its strength starts deteriorating after a period of 6 to 12 months.

## Insulating materials

Insulating materials greatly reduce the heat losses through walls. Insulation is effected by providing a layer of material having a low heat conductivity between the internal hot surface of a furnace and the external surface, thus causing the temperature of the external surface reduced.

Insulating materials owe their low conductivity to their pores while their heat capacity depends on the bulk density and specific heat. Structure of air insulating material consists of minute pores filled with air which have in themselves very low thermal conductivity, excessive heat affects all insulation material adversely, but the temperatures to which the various materials can be heated before this adverse effect occurs differ widely. Clearly, therefore, the choice of an insulating material must depend upon its effectiveness to resist heat conductivity and upon the temperature that it will withstand.

One of the most widely used insulating material is diatomite, also known as kiesel guhr which is made up from a mass of skeletons of minute aquatic plants deposited

thousands of years ago on the beds of seas and lakes. Chemically this consists of silica contaminated with clay and organic matter. A wide range of insulating refractories with wide combinations of properties are now available. The important physical properties of some insulating refractories are shown in the table below:


**Table-III**

Type	Thermal conductivity at 400 C mean Kcal/m/ C	Max. safe temperature C	Cold Crushing Strength Kg/cm <sup>2</sup>	Porosity %	Bulk density Kg/m <sup>3</sup>
Diatomite Solid Grade	.025	1000	270	52	1090
Diatomite Porous Grade	.014	800	110	77	540
Clay High	.030	1500	260	68	560
Alumina	.028	1500-1600	300	66	910
Silica	.040	1400	400	65	830

## Attaching insulation

The method of attaching insulation bricks is illustrated in Fig 2

### METHOD OF ATTACHING INSULATION TO AN EXISTING FLUE WALL



(Fig.2) — ELEVATION

In Fig. 2, a 115 mm brick wall is built outside the existing one, leaving a suitable gap of 76 mm between the old and new walls into which the insulating brick may be inserted as the wall is being built.

To keep the wall rigid, it is necessary to incorporate one or two buttresses and further strengthening is possible with a number of T bars about 600 mm apart.

## Ceramic Fibres

Ceramic fibres are yet another class of material of recent origin. Ceramic fibre which are manufactured by blowing either a high velocity gas or high velocity gases on to a molten stream of aluminosilicate material with a controlled composition that takes care of devitrification and shrinkage. The resulting fluffy, white cotton like fibre can be spun and fabricated into textiles, blankets, felts, boards, blocks, etc.

These products have low thermal conductivity, very low heat storage, extremely light weight, immunity to thermal shocks, and are chemically stable as well as neutral exceptionally resistance to wetting by non-ferrous metals like aluminium, zinc and their alloys. Ceramic fibres are composed of high purity silica in various percentages. A 52-48 combination can be applied as a hot face insulation material up to 1420°C. Whereas a 62-38 combination imparts greater refractoriness to the fibre, 42%  $\text{Al}_2\text{O}_3$ , 52%  $\text{SiO}_2$  and 6%  $\text{ZrO}_2$  produces extra long staple fibre of 10 inches or so and are used for manufacturing ceramic fibre textiles and ropes.

The advantages of ceramic modules are:

- i) Better fuel economy (Savings as high as 60% are feasible in the case of certain intermittent furnaces)
- ii) Higher productive capacity of furnaces, due to reduced heat storage capacity.
- iii) Higher service life of the furnace and reduced maintenance costs due to longer refractory life.
- iv) Ease of installation.

## Selection of refractories

The selection of refractories for any particular application is made with a view to achieve the best performance of the equipment furnace, kiln or boiler and depends on certain properties of the refractories. Further, the choice of a refractory material for a given application will be

determined by the type of furnace or heating unit and the prevailing conditions e.g. the gaseous atmosphere, the presence of slags, the type metal charge etc. It is, therefore, clear that temperature is by no means the only criterion for selection of refractories.

Any furnace designer or industry should have a clear idea about the service conditions which the refractory is required to face. The furnace manufacturers or users have to consider the following points, before selecting a refractory.

- i) Area of application.
- ii) Working temperatures.
- iii) Extent of abrasion and impact.
- iv) Structural load of the furnace.
- v) Stress due to temperature gradient in the structures and temperature fluctuations.
- vi) Chemical compatibility to the furnace environment.
- vii) Heat transfer and fuel conservation.
- viii) Cost considerations.

It is therefore, essential to have an objective evaluation of the above conditions. The proper assessment of the desired properties would provide guidelines for selection of the proper refractory materials.

It would be important to mention here that the furnace manufacturer or a user is also concerned with the conservation of energy. Fuel can be saved in two ways: either by insulation or by faster working. Both these methods give low energy cost per tonne of product.


## Heat losses from furnace walls

In furnaces and kilns, heat losses from furnace walls, affect the fuel economy substantially. The extent of wall losses depends on:


- i) emissivity of walls;
- ii) conductivity of refractories;
- iii) wall thickness;
- iv) whether furnace or kiln is operated continuously or intermittently.

Different materials have different radiation power (emissivity). Thus emissivity of walls coated with aluminium paint is lower than that of bricks. Fig. 3 shows the coefficient of heat dissipation for the following conditions:

- a) rough vertical plane surface.
- b) vertical aluminium painted walls.



(Fig.3)— COEFFICIENT OF HEAT TRANSFER FOR DIFFERENT CONDITIONS IN STILL AIR AT 40°C.




(Fig 4) - AVERAGE CONDUCTIVITY OF REFRACTORY MATERIAL


The variations of thermal conductivity for typical refractory materials (silica brick, fireclay brick and insulation brick) with temperature is depicted in Fig.5. Thus at a mean temperature of 600°C, conductivity of the insulation brick is only 20 per cent of that for fireclay brick.

Heat losses can be reduced by increasing the wall thickness, or through the application of insulating bricks. Outside wall temperature and heat losses for a composite wall of a certain thickness of fire brick and insulation brick are much lower due to lesser conductivity of insulating brick as compared to a refractory brick. This is depicted by the curves in Figs.5 and 6. Thus heat losses from a furnace wall 115 mm thick at 650°C amounting to 2650 Kcal/m²/hr. can be cut down to 850 Kcal/m²/hr. by using 65 mm insulation on a 115 mm. wall.

The heat losses discussed in the preceding section are those incurred during steady, uninterrupted operation. In actual practice, operating periods ("on") alternate with idle



(Fig.5)— TEMPERATURE RELATION OF FACES FURNACE WALL.



(Fig.6)—HEAT LOSSES THROUGH FURNACE WALLS

periods ("off"). During the off period, the heat stored in the refractories in the on-period is gradually dissipated, mainly through radiation and convection from the cold face. In addition, some heat is abstracted by air flowing through the furnace. Dissipation of stored heat is a loss, because the lost heat is at least in part again imparted to the refractories during the next "on" period, thus expending fuel to generate the heat. If a furnace is operated 24 hr. every third day, practically all of the heat stored in the refractories is lost. But if the furnace is operated 8 hrs. per day, not all the heat stored in the refractories is dissipated. For a furnace with firebrick wall (350 mm) it is estimated that 55 per cent of the heat stored in the refractories is dissipated from the cold surface during 16 hours idle period. Furnace walls built of insulating refractories and encased in a shell reduce flow of heat to the surroundings. The loss can further be reduced by inserting a fibre block between the insulating refractory and

the steel casing. The general question one asks is how much heat loss can be reduced by application of insulation. The answer is that it depends on the thickness of firebricks and of the insulation and on continuity of furnace operation. The heat saving pattern with three of these variables are indicated in the table below:

**Table-IV**  
**Reduction of wall losses by insulation percent**

Thickness of Fire-brick wall mm	Continuous Operation Insulation 65 mm	Insulation 120 mm	1 Week Cycle Insulation 65 mm	1 Day Cycle 6 Days per week Insulation 65 mm
115	62	76	58	25
230	46	65	36	18
350	38	65	20	14
460	35	53	15	12

In the table, one week cycle means continuous operation for 6 days of 24 hrs. For 5 days operation, the savings reduced, approximately 10%, to one day cycle means 8 to 10 hr. per day. The tabular values must be reduced somewhat, if the wall is thick in comparison with the interior dimensions of the furnace. The tabular values apply only to those furnaces which are covered entirely with insulation, even under the binding.

To sum up, the heat losses from the walls depend on

- 1) Inside temperature.
- 2) Outside air temperature.
- 3) Outside air velocity.
- 4) Configuration of walls.
- 5) Emissivity of walls.
- 6) Thickness of walls.
- 7) Conductivity of walls.

The last two can be easily controlled by the furnace fabricator. The following conclusions can be drawn:

- i) As the wall thickness increases, the heat losses reduce.
- ii) As thickness of insulation is increased, heat losses reduce.
- iii) The effect of insulation in reducing heat losses is more pronounced than the increase of wall thickness. Roughly 1 cm. of insulation brick is equivalent to 5 to 8 cm of refractory (firebrick).
- iv) In intermittent furnaces, thin walls of insulating refractories are preferable to thick walls of a normal

# Design and constructional aspects

The life of an installation may be shortened due to faulty design or improper construction in spite of the selection of the right type of refractory. Some of the important aspects of refractory construction are:

**Bond:** Bond in brick work is an arrangement by which the joints between the bricks are staggered in all directions in a pre-determined manner. This ensures stability in construction as well as air tightness. An all header construction is recommended in the hot face of a furnace where heavy refractory wear is anticipated either due to action of molten metal slag or dust laden gas moving at high velocities. Where intermittent repairs to the walls are expected, the working layer is built separately from the main wall.

**Wall thickness:** Structural stability should be taken into consideration while deciding the wall thickness. Walls of 115 mm thickness are not constructed beyond a height of one metre without proper anchorage. From the stability point of view minimum thickness should be around 230 mm which may be suitably increased as the height goes up. Use of metallic sheets with anchoring arrangements, improves the stability of the wall where basic refractories are used. Such anchoring of walls with the furnace structurals should have sliding arrangement to take care of the movement of refractories during heating up and cooling down.

**Mortar joints:** Mortar joints will improve the stability of construction. It also takes care of slight variation in sizes as well as warpages by offering a uniform bedding surface. The mortar joints should be as thin as possible especially where they are in contact with molten metal slag, etc. as in the case of ladles handling molten metals. This can be achieved where the construction is limited to standard bricks. But where special bulky shapes are involved a thicker joint has to be provided as a design allowance. Chemical and

physical properties of mortar should be identical to that of the bricks which they are joining. Workability of the mortar is important, in the absence of which, good construction is not possible. The excess mortar applied to the brick surface should come out from the edges when one brick is tapped against the other, to ensure that the joint is full and that there is no open gap.

**Expansion joints:** As explained earlier, refractories expand on heating up. Suitable provision should be made at the time of construction for this expansion to take place without creating undue stresses which may result in failure of the refractories. Usually, expansion joints are built in as the construction proceeds. The necessary provision is made depending on the expansion characteristics of the particular refractory at the operating temperature. Care should be taken to see that the expansion allowance provided is just sufficient as any excess provision will have open joints, after heating up of the furnace which will have detrimental effects. In practice, it has been found that if one could provide for just one half of the theoretical expansion it would suffice. The remaining one half will be absorbed by the mortar joints, or even dry joints between the bricks. In some cases, expansion joints are not built in, either they are provided for at the ends or alternatively the movement of the refractories due to expansion is controlled by allowing the structural to move under controlled loads. Expansion joints must be kept free from foreign matter like clay or brick dust. It is preferable to fill it with some combustible material like saw dust, corrugated paper, cardboard, wooden shavings, etc.

**Structural support:** Refractories are normally held in position with a steel shell or a structural framework comprising buck-stays and tie rods. As failure of structurals by other reason will cause partial failure or even total collapse of refractories. Their alignment, shape etc. should be of equal concern. Periodical checks on the structure should be done as these are likely to lose strength by fatigue. Also important is that the structurals should not get overheated, and therefore, it should be adequately insulated wherever required.

## REFERENCE:

1. Refractories—F.H. Norton, John Wiler Publication.
2. Refractories And Their Uses—Kenneth Shaw, Applied Science Publishers Ltd., London.
3. Refractory Materials—G.B. Rothenberg, Noyes Data Corp., NJ, USA.

**This booklet is one of a series on fuel oil conservation, others in the series are listed below:**

- 1) Storage, handling and preparation of fuel oil.
- 2) Combustion of fuel oils & Burners—operation and maintenance.
- 3) Efficient generation of steam.
- 4) Efficient utilisation of steam.
- 5) Refractories.
- 6) Thermal insulation.

**PCRA films available for industrial sector:**

- 1) "Tuning of Boilers and Furnaces".
- 2) "Handling of Fuel Oils".
- 3) "Efficient Utilisation of Steam in Industries"  
(under production).


Set up a few years ago in anticipation of the world-wide oil crisis that's affecting us all today, PCRA seeks to promote efficient utilisation of petroleum products—in homes, in industries, in farms, on roads. Because till alternative sources of energy are found, we have to make the best use of the world's diminishing oil reserves.



**PETROLEUM CONSERVATION  
RESEARCH ASSOCIATION**

Petroleum Conservation Research  
Association, 1008, New Delhi House,  
27, Barakhamba Road, New Delhi - 110 001.

**SAVE OIL.**  
**Because oil isn't going to last forever.**







# Introduction

The need for efficient thermal insulation has become more important with higher operating temperatures and increasing energy costs. Prevention of heat leakage by judicious application of thermal insulation is the simplest method of achieving substantial economy in energy consumption. With the advent of technology in insulating materials, many upgraded alternatives are available to engineers for application in industry. Though thermal insulation is equally relevant for cryogenic applications, this booklet is limited to medium temperature ranges (50 to 600°C). Insulation for high temperature of 600°C, which are normally encountered in industrial furnaces, is covered in the booklet on 'Refractories' in this series.

# Functions of insulation

Thermal insulation serves several functions such as:

- i) Saving of energy
- ii) Fire protection
- iii) Conservation of products
- iv) Control of temperature
- v) Increased production
- vi) Better working conditions.

## Principle of insulating materials

Insulators are poor conductors of heat and have low conductivity. Insulating material are porous containing a large number of air cells. The resistance to heat transfer by the insulating material would depend on the number of dormant or near dormant air cells packed in the mass. The air cell would be dormant if its diameter is no larger than the mean free path which, for all practical purposes, could be taken as 0.09 microns. This would be possible if insulating materials could be produced with very low fibre diameters and, space between the fibres be so compressed as to be equal or less than the mean free path. Larger air cells are not dormant, and thus convection currents are set up, due to which air temperature rises, this in turn increases the air pressure and consequently the rate of heat flow. This means that for higher temperatures, high density materials should be used.

## Mechanism of heat transfer

Heat is transferred through insulation by any one, or more, of the following modes:

- 1) Solid conduction through matrix or fibres
- 2) Gaseous conduction
- 3) Radiation across gas or air space
- 4) Convection across gas or air space
- 5) Overall convection of the hot face to the cold face.

Materials vary widely in heat conducting properties. This is expressed by the term thermal conductivity. Thermal conductivity is the amount of heat transferred in unit time through an unit area of unit thickness with unit temperature difference across the face. Thermal conductivity of a given material usually increases with rise in temperature. Thermal conductivity values for typical heat insulating material, resistant films and heating surfaces are shown in Table.1.

**Table-1**

### Thermal conductivity of different material

Material	Density (kg/m <sup>3</sup> )	Approximate conductivity values (kcal/m/hr/°C)
<b>A) Insulating material</b>		
i) Magnesia	177-225	0.051 to 0.068
ii) Mineral wool	50-250	0.035 to 0.087
iii) Calcium silicate	160-320	0.049 to 0.079
iv) Aluminosilicates	96	0.028 to 0.071
v) Glass fibres	96	0.028 to 0.061
<b>B) Resistant films</b>		
Water at 0°C		0.510
Water at 95°C		0.585
Air		0.0214
Scale		0.99-2.97
<b>C) Heating surfaces (Values at 100°C)</b>		
Copper		338.0
Aluminium		206.0
Cast Iron		27.8
Steel (0.5°C)		44.7
Brass		89.3

Conductivity of an insulating material varies with its density, porosity, pore size, (in the case of fibrous materials) fibre diameter and shot content (i.e. non-fiberized particles of rock or glass wool). It is advisable to compute heat losses, on the basis of test values given by the manufacturers of insulating materials. However, K values acceptable for typical insulating materials (magnesia, calcium silicate and mineral wool) are as per British standards 3958 Parts 1-5, permitting inherent variations in product quality, dimensional tolerance and accuracy of fit on application. These are depicted in Fig. 1 below.

Table II

Variations in the values of surface coefficient finish or radiating surface and wind velocity

Insulation temperature (°C)	Wind speed (m/sec)	Surface coefficient (kcal/m <sup>2</sup> /hr/°C)		
		Ambient air at 30°C		
		Aluminium	Galvanized M.S.	Cloth, Cement/Fabric
50	0	4.70	6.41	7.84
50	1	7.59	9.30	10.73
50	5	13.41	15.12	16.55
50	10	17.98	19.69	21.12
60	0	5.36	7.15	8.65
60	1	8.79	10.58	12.08
60	5	15.71	17.51	19.00
60	10	21.15	22.95	24.44
60	0	5.82	7.71	9.28
60	1	9.62	11.51	13.08
60	5	17.28	19.17	20.74
60	10	23.30	25.19	26.76
70	0	6.21	8.19	9.84
70	1	10.79	12.27	13.92
70	5	18.53	20.51	22.16
70	10	25.00	26.97	28.62




Fig. 1

(Fig. 1)

Heat conducted through an insulating material is transferred to the surrounding air by radiation and convection. For simplicity the combined effect of radiation and convection heat transfers, from the insulation surface is referred to as surface coefficient and is affected by the velocity of air passing over the surface and by emissivity of the surface, which is the rate of heat transfer as compared to that from a black body. Table II shows the variations in the value of surface coefficient with finish of the radiating surface and wind velocity. Variation of surface coefficient effects a large difference in the insulation's surface temperature, but marginal difference to heat loss. Table I illustrates the effect of surface coefficient on heat losses and surface temperature for a 150 mm pipe for different temperature values.

**Table-III****Effect of surface coefficient on heat loss and surface temperature for a 150 mm pipe in ambient air at 30°C**

Temperature (°C)	Insulation	<u>Cloth</u>		<u>Galvanised mild steel</u>		<u>Aluminium</u>	
		q	t <sub>s</sub>	q	t <sub>s</sub>	q	t <sub>s</sub>
100	25 mm, K = .041	85.9	41	87.9	43	78.8	46
100	50 mm, K = .041	42.0	36	42.0	37	40.0	39
300	50 mm, K = .052	205.5	53	203.0	57	196.6	63
300	100 mm, K = .052	94.1	42	91.5	44	91.2	48
500	100 mm, K = .067	206.5	53	204.9	57	201.3	64
500	150 mm, K = .067	127.9	45	126.4	48	124.3	53

K = thermal conductivity (kcal/hr/m/°C)

t<sub>s</sub> = surface temperature (°C)

q = heat loss (kcal/hr/metre run)

$$q = \frac{(\theta_1 - \theta_2) K}{L} = (\theta_2 - \theta_a) f = \frac{(\theta_1 - \theta_a)}{\frac{L}{K} + \frac{1}{f}}$$

Where

θ<sub>1</sub> = the hot face temperature (°C)

θ<sub>2</sub> = the cold face temperature (°C)

θ<sub>a</sub> = the ambient temperature (°C)

L = the thickness of insulation (m)

K = the thermal conductivity of insulation (kcal/hr/m/°C)

f = the surface coefficient (kcal/hr/m<sup>2</sup>/°C)

The surface temperature may then be calculated from the equation

$$\theta_2 = \frac{q}{f} + \theta_a$$

For cylindrical surfaces, heat losses are given by

$$q = \frac{(\theta_1 - \theta_a)}{r_1 \left( \log_e \frac{r_2}{r_1} \right) \times \frac{1}{K} + \frac{r_2}{r_1} \times \frac{1}{f}}$$

q = heat loss (kcal/hr/m<sup>2</sup>)

r<sub>1</sub> = the inner radius of insulation (m)

r<sub>2</sub> = the outer radius of insulation (m)

The surface temperature can then be calculated from the equation

$$\theta_2 = \left( \frac{q}{f} \times \frac{r_1}{r_2} \right) + \theta_a$$

Increased air movement has a greater effect on heat loss from bare piping than from insulated piping. Table IV below shows the effects of wind velocity on heat loss from bare and insulated surfaces.

**Table -IV**

### Effect of wind velocity on heat loss

Wind velocity (m/sec)	Heat loss (kcal/m/hr)				
	Bare	25 mm Insulation	50 mm Insulation	75 mm Insulation	100 mm Insulation
0	3415	507	307	232	191
1	4197	537	319	238	198
5	7086	572	330	247	205
10	10490	576	336	248	206

Details: 150 mm pipe at 300°C  
Ambient temperature = 30°C  
Insulation K = 0.0515 kcal/m/hr/°C  
Finish: Galvanized Mild Steel.

## Choice and properties of lagging material

### Cork, Felt and Straw

These are natural and the cheapest lagging material available. Cork is probably the best of all materials due to its intricate natural structure. These materials are useful for temporary lagging as they can be conveniently wrapped around pipes with single strands of wire and string. They should not be used for surfaces hotter than 200°C as they are inflammable and get charred and brittle at moderate temperatures.

### 85% Magnesite

This is light calcined magnesium carbonate with 15% amosite asbestos, moulded into standard pipe sections and other shapes. It is excellent, robust and economical in operation, but requires protection from the weather. It should not be used on surfaces whose temperature is over 300°C. This disadvantage can be overcome by interposing a thin layer of special cement between magnesite and the hot surface. Use of Magnesite as insulation has become obsolete these days.

### Asbestos

Asbestos is a natural mineral consisting of a variety of complicated silicate compounds generally containing

calcium or iron or both. There are many different types of asbestos used for lagging purposes — e.g. asbestos fibres and textiles produced by textile machinery in the form of opened fibre, yarn, sheet and mattresses which can be used upto temperatures of 250°C.

Asbestos or plastic sections and coatings which consist of short amosite or crocidolite fibres with a blending agent sprayed or moulded, can withstand temperatures upto 600°C.

Asbestos fibres are in general fire proof material of very low thermal conductivity. However, its use is being discontinued in some European countries due to health restrictions.

### Glass wool

This is supplied as a staple fibre, continuous filaments, or in the form of mattresses, or in the form of semi rigid bonded slabs.

Glass wool is relatively expensive, it irritates sensitive skin and can only be used on surfaces with a maximum temperature of 550°C, when loose and upto 250°C when bonded.

### Slag wool and rock wool

These are made by centrifugal spinning process from molten slag or mineral rocks.

They are good heat insulators and are comparatively less costlier. They can be applied to hot surfaces with temperatures upto 850°C and are available in the form of mattresses, blankets, moulded sections and insulating boards.

### Ceramic Fibres

Ceramic fibres are pressed into a blanket for use up to 1700°C.

## Types and forms of thermal insulation

Thermal insulation materials can be divided into four types:

- Granular
- Fibrous
- Cellular
- Reflective.

Granular, fibrous and cellular types rely on enclosed air or gas and minimum solid conduction paths for their thermal properties. Granular materials such as calcium silicate and diatomaceous earth (kiesel guhr), i.e. siliceous particles

composed of skeletons of diatoms, containing air entrained in the matrix. Fibrous materials like mineral wool and refractory fibres contain air between the fibres and cellular materials such as cellular glass and foamed plastics contain small air or gas cells, sealed or partly sealed from each other. Reflective insulation consists of numerous

layers or random packing of low emissivity foils such as aluminium. It is possible to have a combination of the above. The four types of insulation have varied physical characteristics and as insulation is required for a wide range of services, they are produced in many forms as shown in Table V.

**Table-V**

### **Forms of thermal insulation**

<b>Form</b>	<b>Description</b>	<b>Examples</b>
Preformed	Fabricated in such a manner that at least one surface conforms to the shape of the surface being insulated, this shape being permanently maintained.	Rigid slabs & pipe sections of calcium silicate, mineral wool, cork.
Plastic composition	Insulation in a loose dry form which is prepared by mixing with water.	Magnesia, calcium silicate, diatomaceous earth.
Loose Fill	Insulation in the form of powdered granules, loose, or pelleted fibres.	Vermiculite, Mineral Wool
Flexible	Insulation materials which, lacking rigidity, tend to conform to the shape of the surface against which it is laid.	Low density mineral wool
Textile	Insulation in the form of rope, cloth, etc.	Asbestos, ceramic fibre ropes and fabrics.
Mattress	Flexible insulation faced or totally enclosed with fabric, wire netting, expanded metals, etc.	Wire netted mineral wool mattress, asbestos and glass wool mattresses
Reflective	Insulation comprising numerous layers or random packing of low emissivity foils.	Aluminium foil, stainless steel foil.
Spray applied	Insulation applied by machine in the form of spray. Insulation may be fibrous or granular material mixed with water or other suitable binder.	Sprayed mineral fibre/ceramic fibre.

Typical thermal insulating materials for use in the temperature range of 50 to 1000°C are listed in Table VI below.

Table VI

Insulation	Type	Availability in form	Density kg/m <sup>3</sup>	Thermal Conductivity (kcal/m/hr/°C)	Approximate limiting temp. (°C)
1) Cellular glass	Cellular	Slabs, sections	120-152	.047 at 50°C	430
2) Asbestos	Fibrous	Mattress, textile, loose fill	80-250	.042 at 40°C	600
3) Glass fibre	Fibrous	Slab, loose fill, mattress	12-80	.032 at 40°C .051 at 150°C	400
4) Rock wool and slag wool	Fibrous	Slab, preformed sections, mattresses, loose fill, sprayed	40-250	.032 at 40°C .036 to .045 at 110°C .005 at 250°C	800
5) Calcium silicate	Granular	Slab, section, plastic, brick	240	.051 at 40°C	850
6) Magnesia	Granular	Slab, section, plastic loose fill	200	.05 at 40°C .065 at 200°C	300
7) Silica	Fibrous	Loose fill, brick	50-150	.033 at 40°C .07 at 250°C .081 at 250°C	1000
8) Aluminosilicate	Fibrous	Loose fill, mattress	50-250	.028 to .071	1200
9) Aluminosilicate	Granular	Textile, sprayable Brid	500-800	—	1200
10) Aluminium	Reflective	Reflective	10-30	.026 to .036 at 20°C .074 at 250°C	500
11) Stainless Steel	Reflective	Reflective	300-600	—	800
12) Vermiculate	Granular	Plastic, wax fill	50-500	.073 at 40°C .093 at 250°C	1100



# Selection of lagging material

The ultimate choice of a thermal insulating material is an engineering decision involving a number of factors, important among such are:

1. The operating temperature of the system
2. Thermal conductivity of the insulation
3. Capability of the insulation in application to hot surfaces readily and cheaply
4. Resistance to heat, weather and adverse atmospheric conditions
5. Ability to withstand vibration, noise, and accidental mechanical damage
6. Resistance to chemicals
7. Resistance to fire
8. No shrinkage or cracking during use
9. Jacketing the insulation
10. Total cost including maintenance costs.

## Method of application of insulation

Since most of the insulation materials are fibrous and light, they have to be applied at the correct density without leaving void, and should be properly supported. Therefore, the correct method for application of insulation is equally relevant in order to minimise heat losses.

The Indian Standards Institution gives guidelines on the method of application of insulation, (Ref. IS: 7413-1981; Code of Practice for the Application and Finishing of Thermal Insulation Materials at Temperatures between 40°C and 700°C) abstracts from which are given below:

### a) Methods of application

All insulation materials, however fixed, should be applied so as to be in intimate contact with the surface to which they are applied; and the edges, or ends of sections, shall butt up close to one another over their whole surface except in special applications.

While applying multi-layer insulation, all joints shall be staggered; and each layer shall be separately secured to the surface.

In consideration of possible pipeline movement with change in fluid temperatures, different pipes should be separately insulated.

The insulation shall be supported when applied to the sides of, or underneath large vessels or ducts or to long runs of vertical piping. Supports are welded either to the hot surface or to bands which are then strapped round the

surface. These supports serve to hold the insulation in place, prevent its slipping, or support it above expansion joints. In addition, they provide necessary anchorage for lacing wire or wire-netting which may be required to hold the insulation in place and/or to provide reinforcement for the insulation or a finishing material.

### Surface preparation

Before application of the insulation, the surface is wire-brushed to remove dirt, rust, scale, oil, etc. and dried.

All surfaces are then brush-coated with a suitable anti-corrosive primer before insulating.

### Application of insulation

The following methods are available for application of flexible insulation, rigid insulation etc.

#### i) Flexible insulation

Flexible materials, namely, mats or blankets faced on one or both sides with a suitable facing material are applied by means of tie wire or metal bands or wire netting on the outer side, and are suitably laced.

#### ii) Rigid insulation

Rigid insulation material, namely blocks or boards, may be applied by means of suitable metal bands, or wire netting on the outer surface.

#### iii) Thermal insulating cement

Thermal insulating cements are supplied in the form of a dry powder, which is mixed with water to form a soft mortar of even consistency suitable for application by hand or with a trowel.

Thermal insulating cements require heat for drying to ensure initial adhesion to the surface. All surfaces insulated with thermal insulating cements may, therefore, be kept warm throughout the application of the insulation as per specifications by the manufacturer of the cement.

#### iv) Loose-fill insulation

This may be adopted by agreement between the purchaser and the applicator. Loose-fill insulation is recommended for the following cases.

- a) Expansion/contraction joints in an application when rigid insulation has been used, or
- b) Specific areas of the equipment where conventional methods of application may not be possible and where packing a loose fill is the only possible method of providing insulation.

### Specific applications

Insulation of pipes, ducts, vessels, etc., may be suitably carried out by any one of the methods already mentioned. However, specific considerations pertaining to insulation of pipes, ducts, vessels, etc. are detailed below.

**Pipes:** On continuous runs of 6 metres or more of vertical pipe, support rings are provided at not more than 3-metre intervals. Such rings encircle the pipe and the radial lugs thereon and with specified length equal to 75 per cent of the total insulation thickness.

**Ducts:** When insulation is applied around the corners of the duct, care should be taken to counteract tendency for the material to thin down at these locations.

**Vessels:** All large vertical vessels with a height of 6 metres or more are provided with support rings, at not more than 3-metre intervals. Such rings encompass the vessel, and the radial lugs thereon have a length equal to 75 per cent of the total insulation thickness. Extra insulation is provided over the support rings. This extends for 25 cm on each side of the ring and is extended to 45 cm for watershed on the upper side.

## Finishing

Protective coverings or finishes are required over the insulation for one or more of the following reasons:

- a) Protection against mechanical damage
- b) Protection against weather or chemical attack
- c) Retardation of flame spread
- d) Appearance
- e) Providing the insulation with an easily cleaned surface
- f) Identification of pipe or vessel.

## Protective finishes

The following are the commonly applied protective finishes:

### Finishing cement

Mixtures of cement-sand or cement asbestos or asbestos-plaster of paris, with a minimum thickness of 10 mm or as specified and reinforced with wire netting of minimum 20 mm mesh and 0.56 mm diameter or equivalent metal sheet.

### Bituminous plastics

Minimum of 3 mm thickness with suitable reinforcement such as fabric or wire netting where necessary.

### Sheet metal

Aluminium, galvanized iron or mild steel sheet of suitable thickness with provision of anti-corrosive paint on the inner surface. Galvanized iron or mild steel sheets. Sheets metal, whether applied to pipes or to vessels, may preferably be secured by metal bands.

All joints between adjacent sheets should be either rooved or overlapped, 50 mm minimum against the weather, to prevent the ingress of rain water.

### Asbestos cloth

wool felt, jute canvas, scrim cloth are also used.

## Fittings

The word 'fittings' includes flanges, valves expansion/contraction joints and other pipe fittings.

Before insulation on fittings is undertaken, insulation of the pipe, with its protective finish, must be completed. The insulation is stopped short of the fitting on both sides of the fittings so as to allow withdrawal of belts, without disturbing the insulation. The fitting is then insulated.

## Tracer lines

While erecting tracer pipelines, it is necessary to maintain the closest possible contact between the main pipe and the tracer.

Care may be taken to prevent the insulation from filling any space between the main pipe and the tracer.

Whatever insulation is applied, the pipe and tracer is encased in aluminium foil (0.1 mm thick) drawn up tight and laced with galvanized iron wire. The wrapped pipe and tracer may then be insulated with flexible insulation of thermal insulating cement in the same way as an ordinary pipe.

## Expansion joints in insulation

Depending on the type of insulation used, the operating temperature and the nature of the plant, it may be necessary to provide expansion joints or vessels or pipes to prevent the insulation from rupturing or buckling when the hot surface expands or contracts.

In all cases where support rings are provided on vessels or vertical pipes for rigid insulation materials, the insulation shall be stopped short about 5 mm from each ring and the space between the insulation and the ring filled with a flexible insulation material.

On horizontal pipes and vessels, insulated with rigid insulation materials or thermal insulation cements, expansion joints filled with flexible insulation material should be provided at suitable intervals.


Flexible thermal insulation, for this purpose, mineral wool rigid sections, used at temperatures not exceeding 230°C, do not normally need expansion joints.

Where sheet metal is used as the finish, the joints in the sheets over the expansion joints should not be secured with screws.

All other finishing materials may be carried over expansion joints in the insulation without a joint.

## Use of moulded sections

Lagging materials can be obtained in bulk, in the form of moulded sections; semi-cylindrical for pipes, slabs for vessels, etc. The main advantage of the moulded sections is the ease of application and replacement when undertaking repairs for damaged lagging. It is easier to replace a moulded section. Most of the damaged lagging can be cut up into wedge sections for covering bends and awkward shapes. While a pipe is being taken down, most of the plasticid lagging is generally lost whereas sections may be recovered intact, with a little care.



SECTIONAL MOULDED LAGGING

Figure 2

Fig. 2 shows the method of fastening the sections to the pipe by a spiral binding of soft wire. For a really neat job, the sheeting should be secured by means of a sheet metal screw. A quick rougher method can be utilised with soft wire binding. The wire should be twisted up fairly tight and when all the wires are in position on one section, the wire may be given a quarter kink with a pair of pliers to do the final tightening without the risk of snapping the wire at twist.

## Lagging flanges

Some engineers generally commit the error of leaving the flanges and valves unlagged while insulating the piping systems. In fact, some insulating contractors recommend that flanges should not be lagged if operating temperatures are less than 200°C. Such recommendations show a complete lack of knowledge on the economy of insulation. Often, flanges are left bare, due to the fear that leaks may go undetected and that leakages may corrode the flange bolts.

There are several reasons to dispel this practice. First of all, if the moulded box lagging is used for flanges, a 75 mm length of a 6 mm pipe may be inserted into the bottom of the box to give an early warning of any leak.

Secondly, a really bad leak will soon make itself known. Third, lagging the flanges is one of the best ways of stopping leaks.

Bare flanges on hot lagged pipes introduce temperature stresses at the flanges which may be the cause of leaks. Fig. 3 gives a sectional view of moulded lagging on pipe flange protected by sheet metal. The heat loss from uninsulated flanges and valves is equal to approximately that from a 0.5 metre and a 1 metre bare piping respectively. The heat loss from an uninsulated flange may equal that from several metres of insulated piping, and a piping system with bare loss compared to that of a fully insulated system. The effect of retaining uninsulated piping, flanges and valves can be seen from Table VII below:


Table VII

Equivalent fuel loss from uninsulated surface

Tempera- ture (°C)	Litres of furnace oil/ annum/metre length				
	Pipe dia (25mm)	Pipe dia (50mm)	Pipe dia (75mm)	Pipe dia (100mm)	Pipe dia (150mm)
50	15	28	40	50	68
100	74	133	190	250	360
150	160	288	410	472	680
200	248	426	620	786	1136
250	340	628	916	1182	1713
300	482	895	1290	1628	2428

### Assumptions

- a) Ambient Temperature 30°C for still air
- b) Hr of operation 8100
- c) Pipe external surface Mild Steel



SECTIONAL MOULDED LAGGING ON PIPE FLANGE  
PROTECTED BY SHEET STEEL

Fig.3

Table VIII below shows the equivalent wastage of bare surfaces.

Table-VIII

Temperature (°C)	Surface covered with aluminium sheet (Litres/annum)	Surface covered with galvanized mild steel (Litres/annum)
50	80	113
100	366	520
150	708	1050
200	1118	1757
250	1588	2660
300	2116	4194

Calculations based on

3000 hours/year

Average ambient: 30°C

Still air condition

Boiler efficiency: 81.8%

Gross Calorific Value: 10,300 kcal/kg

Sp. gravity of oil: 0.95

## Insulation of boilers

Boilers for power plants and industrial applications have membrane walls or skin casings on which thermal insulation is applied directly to the walls, without the need for any refractory protective materials. Maximum temperatures to which the boiler wall insulation is subjected are saturated steam conditions, which would not

normally exceed 350°C. Insulation of large boiler walls is usually achieved by the application of mineral fibre slabs, applied in two layers, secured to studs and finished with either galvanized mild steel or aluminium. The insulation chosen should be sufficiently resilient to accommodate relative thermal expansion between boiler wall and outer metal finish.

## Insulation of gas flues

Gas flues are insulated to maintain the required gas temperature in the chimney and to prevent corrosion by maintaining the temperature of flue walls above the dew point of gases. The vertical sides and bottom of the flue may be insulated with low density insulation, supported on studs and reinforcing mesh, but the top of the flue which is liable to foot traffic should be insulated with material of sufficient resistance to compression, in order to withstand imposed loads. The tops are normally insulated with calcium silicate or high density mineral wool. Expansion joints in gas flues should be insulated to prevent acid deposition.

## Open top tanks

Open top tanks containing hot liquids lose energy through evaporation. Heat losses can be appreciably reduced by floating a layer of polypropylene (plastic) spheres on the surface of the liquid. Manufacturers claim a reduction of 70% heat losses by floating a layer of 45 mm diameter balls on the surface of liquids at 90°C.

## Insulating stainless steel surfaces


Insulated austenitic stainless steel surfaces operating at temperatures above 70°C are liable to external stress corrosion, and cracking in the presence of chlorides. As most thermal insulating materials contain chlorides when manufactured, and may also pick up chlorides from the atmosphere, it is necessary to take precautions when insulation is applied to stainless steel piping and equipment. It is recommended that a barrier be placed between the insulation and the stainless steel to prevent chlorides that may be leached out from being deposited on the stainless steel. The usual practice is to apply and fit aluminium foil no thinner than 0.06 mm before the insulation is applied.

Painting treatments may also be applied to stainless steels before insulation is applied. Furthermore, stainless steel surfaces should be adequately water-proofed to prevent ingress of water.

# Optimum economic thickness

Insulation of any thermal system means capital expenditure. Hence, the most important factor in any insulation system is to analyse the thermal insulation with respect to cost.

The effectiveness of insulation follows the law of diminishing returns. Hence, there is a definite economic limit to the amount of insulation which is justified, i.e. there is a thickness below which the insulation is insufficient and loss of heat is more. An increased thickness is wasteful in terms of cost, and cannot be recovered through small heat savings. This limiting value, termed as economic thickness of insulation (ETI) is that thickness of insulation at which the costs of heat loss, plus the installed cost of insulation is at a minimum, over a given period of time. Fig. 4 below demonstrates this principle.



DETERMINATION OF THE ECONOMIC THICKNESS OF INSULATION MATERIAL.

I: COST OF INSULATION    H: COST OF HEAT LOSS  
I+H: TOTAL COST    M: ECONOMIC THICKNESS

(Fig. 4)

The determination of economic thickness requires the attention to the following factors:

- Value of fuel (fuel cost plus cost of labour, maintenance, etc.)
- Annual hours of operation
- Heat content of fuel
- Efficiency of combustion of fuel
- Average exposure ambient still air temperature
- Operating temperature of surface
- Pipe diameter/thickness of surface
- Estimated cost of insulation installed
- Amortization period
- Heat loss per linear metre (or square metre, if a flat surface is used).

After compiling the above data, the economic thickness is determined by first computing the heat loss per year on 100 metres of the surface. Then the installed insulation cost per year is calculated. The latter figure is equal to the cost of 100 linear metres of insulation divided by the amortization period. Finally, the cost of heat is added to the insulation cost. After this summation is plotted for various values of insulation thickness, the lowest point on the curve indicates economic thickness; thus economic thickness pays for itself besides earning a return over its original cost. From this definition, any changes occurring in the prices of fuel or in the insulation cost will tend to shift the economic thickness to another value. Hence the insulation levels which were uneconomical in the 70's may be quite lucrative now due to the drastic increase in fuel prices in the recent years. Based on the prevailing cost structure one has to review the entire insulation system and assess if any additional insulation is necessary to achieve optimum economy. Mathematical analysis for determining optimum economic thickness is as under:

## Cost of heat loss per year

$$= \frac{q \times N}{n \times H} \times P \text{ in Rs/year}$$

where N = No. of hours of operation of plant per year

P = Price of fuel in Rs/kg

n = Efficiency of steam generation plant

H = Gross calorific value of fuel in kcal/kg

q = Heat in kcal/hr.

## Annual cost of insulation

$$= c/a$$

where c = cost of insulation including outer protection covering.

$$\text{Amortization period} = a = \frac{1}{\frac{r}{100} + \frac{1}{z}} \text{ Year}$$

Where r is the percentage return on capital and z is plant life in years.

The cost of heat losses per year is computed for a range of insulation thickness at 10 mm intervals and tabulated.

These costs are added to each thickness and from that the minimum cost becomes apparent.

The following case illustrates the computation of economic thickness.

#### Example

A process industry has a package boiler using furnace oil as fuel. Efficiency of the package boiler is 80%. The plant operates for 6000 hours each year. It is now required to calculate the economic thickness of insulation for

- (a) a flat surface whose hot face temperature is 100°C
- (b) a cylindrical surface (steam pipe) where the hot surface temperature is 150°C.

Insulation material being used in both the cases is mineral wool with a density of 120 kg/m<sup>3</sup>. The outer surface of the

insulation is covered with thin aluminium sheet of 0.56 mm thickness.

Cost of fuel (furnace oil)	= Rs 2.80/kg
Calorific value of fuel	= 10300 kcal/kg
Boiler efficiency	= 80%
Plant operational hours/year	= 6000
Rate on Capital required	= 20% = 0.20
Assume Plant Life	= 5 years
Average ambient temperature	= 30°C
Cost of useful heat	= $\frac{2.80}{0.8 \times 10300}$
	= Rs 0.00033/kcal

$$\text{Years of repayment (amortization period)} = \frac{1}{0.20 + \frac{1}{5}} = 2.5 \text{ years}$$

#### a) Tabulation of heat losses and cost of insulation for flat surface at 100°C

Insulation thickness (mm)	Heat loss/year kcal/m <sup>2</sup>	Annual cost (Rs/m <sup>2</sup> ) of		Total cost (Rs/m <sup>2</sup> )
		Heat loss (kcal)	Insulation *	
		(a)	(b)	(a) + (b)
25	69.0	138	48	186.0
50	45.6	91.2	57	148.2
75	31.84	63.68	65	128.68
90	27.53	55.06	75	130.06
100	24.77	49.54	81	130.54
150	21.57	43.08	87.5	130.58

Obviously, optimum thickness = 75 mm.

$$\text{Annual cost of insulation} = \frac{\text{Total cost of insulation}}{\text{Amortization period}}$$

## b) Tabulation of heat losses and insulation cost for cylindrical surface at 150°C

Insulation thickness (mm)	Heat loss/year		Annual Cost (Rs/100m) of		
	kcal/m <sup>2</sup>	kcal/100 m	Heat loss (kcal) (a)	Insulation * (b)	Total cost (Rs/100m) (a) + (b)
25	152.68	3817	7642	1660	9302
40	128.16	3204	6408	2140	8548
50	116.38	2909.5	5819	2480	8299
65	103.76	2594	5188	3027	8215
75	98.08	2452	4904	3320	8224
90	90.60	2265	4530	4220	8750
100	88.80	2220	4440	4540	8980

Therefore, optimum thickness = 65 mm.

However for quicker evaluation of insulation levels required, the following approach may be adopted:

$$\text{* Annual cost of insulation} = \frac{\text{Total cost of insulation}}{\text{Amortization period}}$$

i) Table IX below depicts the insulation level required for insulating hot surfaces (pipes and flat) as a rough guideline for small and medium industries

**Table-IX**

### Recommended insulation thickness for cylindrical and flat surfaces

Temperature (°C)	Pipe				Flat (mm)
	25 mm dia	50 mm dia	75 mm dia	100 mm dia	
Upto 100	25	40	50	65	75
100-150	40	50	65	75	100
150-200	50	65	75	100	125
200-250	50	75	100	125	150
250-300	65	90	115	150	175

- The above insulation thickness is for mineral wool backed by a bright metallic surface
- It is assumed that furnace oil is the source of thermal energy. Prevailing price of furnace oil is taken as Rs 2,800/tonne
- Average utilisation of equipment is assumed to be 6000 hrs/annum

- Though surface temperature of the insulation cannot indicate absolutely its effectiveness, yet the following norms may be adopted to evaluate the use of improving insulation levels.

For a wall insulated surface,  $\Delta T$  (temperature difference) between the surface temperature of insulation and ambient air should be less than the values indicated in the following table:

**Table-X****Desirable temperature differential between surface and ambient temperature**

Finish	Pipe dia less than 10 mm		Pipe dia greater than 100 mm flats	
	operating temp. less than 250°C	Operating temp. greater 250°C	Operating temp. less than 250°C	Operating temp. greater than 250°C
Bright Aluminium Galvanised Sheet	< 15	< 15	< 15	< 20
Dull Finish (cloth) cement, rough sheet	< 10	< 10	< 15	< 15

**REFERENCE:**

1. Efficient Use of Steam — Oliver Lyle
2. The Efficient Use of Fuel — HMSO, London
3. Refractories And Their Uses — Kenneth Shaw; Applied Science Publishers Ltd., London

**Courtesy—**

1. M/s Econtherm Systems Pvt. Ltd., New Delhi
2. M/s Lloyd Insulation (Pvt.) Ltd., New Delhi.

This booklet is one of a series on fuel oil conservation, others in the series are:

- 1) Storage, handling and preparation of fuel oil
- 2) Combustion of fuel oils & burners — operation and maintenance
- 3) Efficient generation of steam
- 4) Efficient utilisation of steam
- 5) Fuel economy in furnaces and waste heat recovery
- 6) Refractory.

**Other books available with us are:**

- 1) Energy Audit
- 2) Efficient operation of boilers and furnaces — an operators guide (available in 10 languages).

**PCRA films available for industrial sector:**

- 1) Tuning of Boilers and Furnaces
- 2) Handling of Fuel Oils
- 3) Efficient Utilisation of Steam in Industries (under production).



# Notes

.



**This booklet is one of a series on fuel oil conservation, others in the series are listed below:**

- 1) Storage, handling and preparation of fuel oil.
- 2) Combustion of fuel oils & Burners—operation and maintenance.
- 3) Efficient generation of steam.
- 4) Efficient utilisation of steam.
- 5) Refractories.
- 6) Thermal insulation.

**PCRA films available for industrial sector:**

- 1) "Tuning of Boilers and Furnaces".
- 2) "Handling of Fuel Oils".
- 3) "Efficient Utilisation of Steam in Industries"  
(under production).

Set up a few years ago in anticipation of the world-wide oil crisis that's affecting us all today, PCRA seeks to promote efficient utilisation of petroleum products—in homes, in industries, in farms, on roads. Because till alternative sources of energy are found, we have to make the best use of the world's diminishing oil reserves.




**PETROLEUM CONSERVATION  
RESEARCH ASSOCIATION**

Petroleum Conservation Research  
Association, 1008, New Delhi House,  
27, Barakhamba Road, New Delhi - 110 001.

**SAVE OIL.**

**Because oil isn't going to last forever.**

# AN APPROACH TO ENERGY AUDIT





## INTRO

This booklet  
it describes  
and how  
carried out

The approach  
nature of  
organisations  
energy

As Energy  
ma  
En

# ENERGY AUDIT

A lot of publicity has already been given to encourage energy conservation but not much is known about the specific ways and means to achieve the same. Energy Audit deals with this aspect at length.

Energy Audit is the key to a systematic approach for decision-making in the area of energy management. It attempts to balance the total energy inputs with its use and serves to identify all the energy streams in a facility. It quantifies energy usage according to its discrete functions.

Industrial Energy Audit is an effective tool in defining and pursuing comprehensive energy management programmes. In this field also, the basic functions of management like planning, decision-making, organising and controlling, apply equally as in any other management subject. These functions can be effectively performed, based on reliable information which can be made available to the top management by applying Energy Audit techniques.

## THE NEED

With the advent of energy crisis and exponential hikes in the cost of different forms of energy, Energy Audit is manifesting its due importance in various sectors. Energy Audit will help to understand more about the ways energy and fuel are used in any industry, and help in identifying the areas where waste can occur and where scope for improvement exists.

The Energy Audit would give a positive orientation to the energy cost reduction, preventive maintenance and quality control programmes which are vital for production and utility activities. Such an audit programme will help to keep alive variations which occur in the energy costs, availability and reliability of supply of energy, decide on appropriate energy mix, identify energy conservation technologies, retrofits for energy conservation equipment and the like.

In general, Energy Audit is the translation of conservation ideas into realities, by blending technically feasible solutions with economic and other organisational considerations within a specified time frame. This technique will be more beneficial than piece-meal injection of short-term measures, without adopting a scientifically evolved strategy including gearing up of organisational structure and other infrastructural requirements.

## TYPE

Energy Audit attempts to balance total input of energy with its use. The type of Energy Audit to be performed depends on:

- the function and type of industry,
- the depth to which final audit is needed, and
- the potential and magnitude of cost reduction desired.

The primary objective of Energy Audit is to determine ways to reduce energy consumption per unit of product output or to lower operating costs. The extent and type of Energy Audit should result in gains commensurate with the efforts.

There can be two types of Energy Audit—

- i) Preliminary Audit
- ii) Detailed Audit

Preliminary Audit is performed in a limited span of time. It focuses on major energy supplies and demands, accounting for at least 70 per cent of total energy requirements. The Detailed Audit goes beyond quantitative estimates to costs and savings. It includes engineering recommendations and well defined projects with priorities. It accounts for approximately 95 per cent of energy utilised in the plant. A long range energy plan can be drawn up on the basis of data generated and analysed.

The Preliminary Audit can be an effective follow up for measuring the progress of the Plant Energy Management Programme (if any) that has been drawn up earlier. It may also form the basis for deciding the modalities of Detailed Audit.

The two types of audit are compared & shown in Table - 1

**TABLE-1**

Preliminary Audit		
Objective	Set priorities for optimising energy consumption	Identify areas for energy conservation and develop a plan of action
Scope	Highlight energy costs and wastages in major equipment/processes	For the plant as a whole or for a particular unit/department
Duration	2 to 10 days	1 week to 1 month
Audit frequency	Difficult to decide	May be 3 to 5 years once
Preparation	a) No pre-audit visit required b) Detailed questionnaire to be completed before the audit	One or two pre-audit visits may be required in addition to the main audit. The following may be required: 1. Advance notice of visit to plant 2. Arrangements for access to plant 3. Advance notice of visit to management 4. Advance notice of visit to safety 5. Advance notice of visit to security
Due date	Within two weeks of completion of field work	Within 3 months of completion of field work

However, for energy intensive industries it may be on an annual basis

## METHODOLOGY

There is no set methodology which can be readily tailor-adapted for conducting Energy Audit in all plants. What works in one plant may fail in another. It depends on the management philosophy, history and culture of organisation, type of plant and machinery, financial conditions of the company and technological and process intricacies. In essence, Energy Audit

'directs and controls the energy management programme. A general questionnaire is, however, given in Appendix-I which will help in identifying areas while carrying out an Energy Audit study. An energy management programme which can be steered through a well conceived Energy Audit system is highlighted hereafter.



# PRE-REQUISITES

Before starting any energy management programme, the top management should assign the responsibilities of energy accounting, auditing and analysis to an internal and/or an external group. The executives from various departments like production, utilities, maintenance and finance should be brought together in order to review the findings at periodic intervals.

Necessary financial, organisational and infrastructural support for implementing and reviewing energy conservation measures should be provided to this group.

The involvement of the representatives from different departments/labour unions is necessary to make the energy conservation measures effective.

## SCOPE

The needs and objectives of the Energy Audit are to be identified. The functional areas to be studied are selected, based on overall energy consumption figures of the organisation.

The scope of an Energy Audit varies according to the facilities being audited. At one extreme is a light manufacturing operation where lighting, ventilation and air-conditioning are the major energy uses. While at the other end, there are integrated process units like refineries and petrochemical plants, where cascading of energy and complex energy balances are involved. The different scopes of Energy Audit are listed in Table 2.

## TABLE-2

### SCOPE OF ENERGY AUDIT

- Analyse present consumption and past trends in detail.
- Review lighting requirements.
- Consider submetering.
- Compare standard consumption to actual.
- Produce an energy balance diagram for the firm.
- Review existing energy recording systems.
- Compare consumption with other locations, other firms, previous period and budget.
- Check records against invoices.
- Compare meter reading against records.
- Review records of maintenance engineer.
- Check capacities and efficiencies of equipments.
- Check working of controls.
- Examine need for automatic controls.
- Determine adequacy of maintenance.
- Review fuel storage and handling.
- Examine need for improved instrumentation.
- Consider training energy management staff.
- Review new projects with respect to energy use.
- Introduce life cycle costing.
- Consider changing the management information system to include energy parameters.
- Develop energy use indices to compare performance/productivity.
- Introduce energy use monitoring procedures.
- Check frequency of energy reporting systems.
- Examine and monitor new energy saving techniques.
- Examine need for energy saving incentives.
- Consider publicity campaigns and incentives.

# DATA COLLECTION

Basic data concerning the overall energy consumption, its cost and production figures for a period of the preceding five years have to be collected. These figures, when compared, give a trend of energy consumption and its cost per unit production over the years. The data can be compiled in different formats given in Tables 3,4,5. Energy

consumption in different forms should be expressed in a common unit (Kcal/Kwh/GJ) to facilitate easy comparison. Appendix-II may be referred to for various energy conversion factors. As energy consumption is also related to production figures, it should be expressed in a common term viz. specific energy consumption — Kcal/unit of production.


## TABLE-3 ENERGY CONSUMPTION FIGURES

Year	TYPE OF ENERGY													
	FUEL										ELECTRICITY			
	FURNACE OIL					COAL					KWH		Tons	
	MT	Rs./MT	Rs./Kcal	% of Total Kcal	% of Total Cost	MT	Rs./MT	Rs./Kcal	% of Total Kcal	% of Total Cost	(1)	Rs./Kwh	(2)	Rs./Ton
	(1)	(2)	(3)	(4)	(5)	(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
1978														
1979														
1980														
1981														
1982														
1983														

## TABLE-4 PRODUCTION FIGURES

Year	Production, Tonnes	Total Energy consumed, Kcal
1978		
1979		
1980		
1981		
1982		
1983		

## TABLE-5



The collection of data as indicated in the previous tables, needs metering facilities for energy used in different sections/departments. A fair approximation of energy consumption in different processes/equipment can be made with the help of different standard data given in appendices-III to VI.

Pie diagram of energy consumption




Fig.1

## DATA ANALYSIS

When sufficient data has been built up, the existing records of consumption should be reviewed. The energy consumption and production figures available can be refined to an appropriate form.

A pictorial representation e.g. pie diagram, can be made to indicate the share of different forms of




Fig.2

energy in the total energy consumption of the unit (Fig.1).

A graphical representation of energy input per unit of product (specific energy consumption) over the years, as shown in Fig.2, will give an immediate insight into the trend of energy consumption. An increasing trend would call for a serious involvement in holding the line.

A sankey diagram, as illustrated in Fig.3, can be drawn for accounting energy use and losses in the plant. This can be accompanied by actions required for curtailing the consumption.

Sankey diagram of energy input and end uses: all units are in kw. i.e. 3412 Btu/h or 3.600 MJ/h




Fig.3

By making a graph of specific energy consumption against product output from a large number of readings or as a result of trials, (Fig.4), it may be possible to pick out the best set of figures which can be used as a target for future output or to optimize the process for energy use. The comparison of

specific energy consumption with similar units and/or a theoretical exercise for the same will also help in fixing targets.

### Specific Energy Consumption


kcal/unit of production

Product output

Fig.4

A process flow diagram with energy consumption in each step/operation could be made which will indicate the order of energy consumption in different operations.

This is illustrated in Fig.5. Refining the data in various forms would thus help in locating the areas of high energy consumption, high costs and savings potential.



MELTER

648 X


BURNER

660348

WATER

WASTE  
HEAT  
BOILER

22817



# ENERGY CONSERVATION PROPOSALS

Energy Audit results in energy conservation proposals or projects. Initially, proposals with minimum investments are identified such as:

- \* Improvements in the standard maintenance of thermal insulation, instrumentation, combustion equipment, etc.
- \* Carrying out of plant efficiency trials
- \* Excess air control
- \* Stopping leakages
- \* Re-allocation of electric motors.

The criteria used for ranking the proposals are the savings achievable from a project compared to the investments needed for effecting these savings. The savings to investment ratio (SIR) is calculated and the project with the highest SIR is selected first then the next highest and so on. Proposed projects, however, should provide an adequate financial return on the capital required to complete them. A discounted Cash Flow and/or Life Cycle Cost Analysis of the project should be carried out to get a complete economic analysis of the proposal. The following guidelines are recommended for approval of smaller size, working budget type, energy conservation projects.

Anticipated Real Project Life	Payback
5 years	2 years
10 years	3 years
15 years	4 years

An effective campaign on educating the employees in the unit by way of posters, house magazines, suggestion box, involvement of unions, training programmes and incentive schemes should be given due attention to help imbibe the energy conservation attitude.

## CONTROL

A reporting system of energy consumption should be devised and incorporated in the Management Information Systems. This will help in evaluating and reviewing the different energy conservation programmes implemented.

This necessarily calls for proper metering system at key points. The reliability of the data is most important. It, otherwise, would jeopardise the whole exercise. The data thus generated will give a clear

picture of the status of different energy conservation proposals/projects against the targeted value. It leaves enough room to re-organise the programmes accordingly, if the results are found far short of the target.

## PERIODICITY OF THE AUDIT

It is too much to expect a common answer to the question of periodicity of Energy Audit. It depends on the type of audit undertaken previously, pace of implementation of energy conservation programme in the recent past, overall potential for energy conservation and several other factors. It can be better decided by professionals involved in the latest Energy Audit exercise undertaken in the plant or on the basis of a preliminary audit, specially being undertaken for the above purpose. However, for a beginning the periodicity suggested in Table-I would be adequate.

## CONCLUSION

Energy Audit is an effective tool in defining and pursuing a comprehensive energy management programme. A careful audit of any type will give the unit a plan with which it can effectively manage the plant energy system at minimum energy costs. This approach would be useful for industries in combating escalating energy costs and also reap several other benefits like improved production, better quality, higher profits, lower emission, etc. The approach would broadly be the same in any type of industry and service. The basic formats may have to be suitably modified for different types of industries.



# GENERAL QUESTIONNAIRE

## I Internal Control Questionnaire

Name of company: .....

Location: .....

Official(s) interviewed: .....

### A Control of Energy

1. Who is responsible for energy management?

Name:

Position in organisation:

Full time or part time:

Qualifications, relevant experience:

Staff:

2. How is energy consumption reviewed?

From head office or on location:

Continuously or periodically:

According to a plan or irregularly:

3. If periodically, when was the last review?

4. How is energy consumption analysed?

By department;

By product;

By source;

By month;

By cost.

Between lighting, hot water, space heating, power, etc.

Between office, factory, warehouse, transport, etc.

5. Does analysis identify the relationship between consumption of energy and level of activity?

6. What units of measurement are used? (It may be useful to convert consumption of different sorts of energy into one unit — other than money.)

7. What are the metering control arrangements?

(N.B. This question includes:

How frequently are readings taken?

To what extent is there submetering?

What records are kept?)

Coal or other solid fuels;

Steam;

Gas;

Electricity;

Liquid fuels;

Water;

Others;

8. Is there an energy consumption forecast/budget?

9. Have standards been set — i.e. standard energy consumption for each process or building?

10. Is consumption compared with:

— previous periods?

— other locations?

— other companies?

— other industries?

11. Has the management set targets:

— for absolute levels of consumption?

— for levels of consumption based on activity?

— for levels of idle time?

— for % cuts in consumption?

12. (a) Does management consider information on energy consumption an essential part of the management information system?

(b) If not, why?

13. What steps have been taken by way of education of employees, to promote energy conservation?

14. What steps are being/have been taken in re-cycling energy —

e.g. sale of by-products or scrap (having intrinsic energy content)?

— reclamation of energy as heat from air, water, hot products etc?

— recovery of heat from incineration of waste?

15. To what extent is planned maintenance in operation?

16. How often are different classes of plant inspected or tested —

e.g. for corrosion, cracking, fouling, leaks, malfunctioning steam traps, inaccurate or inoperative control devices?

17. Who controls capital spending budget?

18. (a) Is there a list of energy saving investments under review, ranked in order of priority, with detailed costing and pay-back calculation?

(b) If not, why?

19. Has a Sankey diagram been prepared? (Fig. 3)

### B. Sources of Energy

1. What are the sources of energy used?

Coal or other solid fuels;

Gas;

Electricity;

Liquid fuels;

Others:

2. (a) What tariffs are used?

(b) Why?

(c) When were they last reviewed?

## C. Uses of Energy

1. Storage:
  - (a) How are storage tanks heated?
  - (b) Are they kept at most economic temperature?
  - (c) Are they adequately insulated?
2. What are areas of high energy consumption?
3. Is there any risk/evidence of unauthorised use or leakage?
4. What further steps are being considered to optimise savings and profits?
5. Processes:
  - (a) Are pipes and tanks adequately lagged?
  - (b) Is condensate recovered?
  - (c) Is boiler and furnace efficiency tested?
  - (d) Are process temperatures at lowest essential level?

## II. General Audit Programme

### A. Records of consumption

1. Produce detailed analysis of energy consumed over the most recent year. Show the amount, and cost per unit, of each fuel. (This will be used for the purpose of the current audit and for providing a baseline for comparison with later years).
2. Review existing records of consumption and determine if adequate information is available to management.
3. Draw Sankey Diagram (See Fig. 3).
4. Compare consumption with:
  - (a) Other locations
  - (b) Previous periods
  - (c) Budget
5. Compare standard consumption to actual for each process, and identify losses.
6. Test meter readings against records.
7. Test records against invoices.

### B. Housekeeping

1. Check that all control mechanisms are effective and frequently tested.
2. Consider whether further instruments would be useful in measuring or controlling particular parameters (e.g. temperature, pressure, humidity, flow rate).
3. Determine whether maintenance is adequate (e.g. annual cleaning of boilers is unlikely to be sufficient to avoid fouling and corrosion of tubes).
4. Consider how maintenance could be improved:
  - more skilled manpower,
  - design change (e.g. fitting of by-pass facilities, pipe line strainers, sight glasses of steam traps etc.)

5. Review fuel storage and handling.
  - consider whether temperatures are adequate or excessive.
  - consider whether vapourisation could be reduced (e.g. by reducing the vapour space above volatile liquids).
6. Review space heating/cooling:
  - check that the installation has fast response to control.
  - check that control devices are protected from unauthorised interference.
  - check that temperature, air movement and ventilation are not excessive.
  - ensure windows are not used for temperature control in heated buildings.
  - check insulation throughout:
    - plant, including tanks and pipe runs,
    - roofs,
    - walls,
    - doors, windows,
    - floors, etc
  - check that systems are properly integrated (i.e. boiler and refrigerator plants do not conflict).
  - review heating installation.

(NB: The purpose of this audit step, in conjunction with (A) above, is to determine when and how much heat is lost, with a view to recommending remedial action, if appropriate.)
7. Review lighting:
  - consider if the most efficient form of lighting is used for each purpose.
  - check lighting levels maintain proper illumination.
8. Review tariffs or contracts for supply of energy:
  - ensure the most appropriate tariffs are used, discuss with suppliers, if appropriate.
9. Check all reasonable steps are taken to minimise peak demands for electricity e.g.:
  - re-schedule tasks to off-peak periods.
  - use an emergency type diesel generator as booster/ alternative to electricity, preferably including waste heat recovery.
  - monitor consumption precisely.
  - use maximum demand meter.
10. Consider the feasibility of using night rate electricity.
11. Consider sub-metering, so that consumption can be broken down into controllable units, i.e. cost centres, thereby making some individual personally responsible.

## C. Personnel

1. Consider if specialist workers are adequately trained and motivated, e.g.:

- energy manager,
- maintenance engineer,
- instrument engineer.
- furnace operator,

2. Review energy conservation propaganda or education, e.g.:

- posters,
- house magazines,
- circulars,
- requests for suggestions from employees,
- talks and short courses,
- involvement of unions.

## D. Capital Investment

1. Review energy related capital projects under consideration:

- check calculation of return/pay-back,
- review arguments for and against making the investment,
- check that tax implications are correctly taken into account.

2. Review efficiency of furnaces, boilers and process equipment.

(NB: About 86 per cent of all energy used by industry is converted in boilers or furnaces)

- Consider whether they should be replaced (advantage of PCRA boiler replacement scheme could be taken).
- Consider whether they should be modified:
  - by pre-heating air,
  - by adding metering facilities,
  - by recovering waste heat,
  - by improved insulation,
  - by replacing burners (Modern burners have improved turndown capability which can be useful if there is a fluctuating load/demand and can show a 30 per cent return on capital),
  - by adding economisers,
  - by returning condensate to boilers,
- consider the size of equipment vis-a-vis demand.
- determine whether use of cooling water is restricted to an economic level.

## CONVERSION FACTORS AND ENERGY UNITS

1 Btu	= 1.055 K. Joules
1 Btu/lb	= 0.002326 MJ/Kg.
1 MJ/Kg.	= 429.9 Btu/lb.
1 therm.	= 100,000 Btu = 29.3 KWH = 105.5 MJ
1 megajoule	= 947.8 Btu = 0.2778 KWH
	= 0.009478 therm.
1 cu.ft.	= 0.02832 cu.m.
1 cu. metre	= 35.315 c.ft.
1 MJ/cu.m.	= 26.84 Btu/cu.ft.
1 Kwh	= 3.6 Mje = 860 K.cal.

## ABBREVIATIONS

K (Kilo)	— $10^3$ (thousand)
M (Mega)	— $10^6$ (million)
G (Giga)	— $10^9$ (billion)
T (Tera)	— $10^{12}$ (trillion)
P (Peta)	— $10^{15}$
E (Exa)	— $10^{18}$

## ENERGY FORM AND CONVERSION TO GJ:

a. Electricity (KWH)	= 0.0036 GJ
b. Fuel oil (tonnes)	= 43.73 GJ
c. Industrial diesel oil (tonnes)	= 45.5 GJ
d. Automotive distillate (litres)	= 0.0383 GJ
e. Kerosene (litres)	= 0.0375 GJ
f. LPG (tonnes)	= 50.3 GJ
(litres)	= 0.0266 GJ
g. Coal (Black) tonne	= 30.7 GJ
(Brown) tonne	= 9.7 GJ






Fig.10


Flash steam is formed when there is a drop in condensate pressure — which, normally, is immediately after the steam trap orifice. Flash steam can be used locally which results in substantial savings. The amount of condensate re-evaporation to steam depends on the difference in pressure. The higher the initial pressure and the lower the flash recovery pressure, the greater will be the flash steam formed. The figure shown above gives the amount of flash steam available at different pressure levels.

# CAPACITY OF PIPELINES

Table 2

Pipeline Capacities at Specific Velocities—Metric Units

Pressure bar	Velocity m/s	kg/h										
		15 mm	20 mm	25 mm	32 mm	40 mm	50 mm	65 mm	80 mm	100mm	125mm	150mm
0.4	15	7	14	24	37	52	99	145	213	394	648	917
	25	10	25	40	62	92	162	265	384	675	972	1457
	40	17	35	64	102	142	265	403	576	1037	1670	2303
0.7	15	7	16	25	40	59	109	166	250	431	680	1006
	25	12	25	45	72	100	182	287	430	716	1145	1575
	40	18	37	68	106	167	298	428	630	1108	1712	2417
1.0	15	8	17	29	43	65	112	182	260	470	694	1020
	25	12	26	48	72	100	193	300	445	730	1160	1660
	40	19	39	71	112	172	311	465	640	1150	1800	2500
2.0	15	12	25	45	70	100	182	280	410	715	1125	1580
	25	19	43	70	112	162	295	428	656	1215	1755	2520
	40	30	64	115	178	275	475	745	1010	1895	2925	4175
3.0	15	16	37	60	93	127	245	385	535	925	1505	2040
	25	26	56	100	152	225	425	632	910	1580	2480	3440
	40	41	87	157	250	357	595	1025	1460	2540	4050	5940
4.0	15	19	42	70	108	156	281	432	635	1166	1685	2460
	25	30	63	115	180	270	450	742	1080	1980	2925	4225
	40	49	116	197	295	456	796	1247	1825	3120	4940	7050
5.0	15	22	49	87	128	187	352	526	770	1295	2105	2835
	25	36	81	135	211	308	548	885	1265	2110	3540	5150
	40	59	131	225	338	495	855	1350	1890	3510	5400	7870
6.0	15	26	59	105	153	225	425	632	925	1555	2525	3400
	25	43	97	162	253	370	658	1065	1520	2530	4250	6175
	40	71	157	270	405	595	1025	1620	2270	4210	6475	9445
7.0	15	29	63	110	165	260	445	705	952	1815	2765	3990
	25	49	114	190	288	450	785	1205	1750	3025	4815	6900
	40	76	177	303	455	690	1210	1865	2520	4585	7560	10880
8.0	15	32	70	126	190	285	475	800	1125	1990	3025	4540
	25	54	122	205	320	465	810	1260	1870	3240	5220	7120
	40	84	192	327	510	730	1370	2065	3120	5135	8395	12470
10.0	15	41	95	155	250	372	626	1012	1465	2495	3995	5860
	25	66	145	257	405	562	990	1530	2205	3825	6295	8995
	40	104	216	408	615	910	1635	2545	3600	6230	9880	14390
14.0	15	50	121	205	310	465	810	1270	1870	3220	5215	7390
	25	85	195	331	520	740	1375	2080	3120	5200	8500	12560
	40	126	305	555	825	1210	2195	3425	4735	8510	13050	18630




This nomograph is made in two parts. Left hand side provides the maximum possible mass flow rates and the right hand side gives the maximum possible volume flow rates of liquids, the volume being measured at the specific flow conditions.

**Problem:**

Find the maximum flow rate possible when a liquid with a specific gravity of 0.8 is flowing through a pipe having an internal diameter of 6 inches.

**Solution:**

Use a straightedge to connect 6 on scale with 0.8 on primary scale SG and extend the line to intersect scale W, reading the maximum flow rate as 32,000 lb/hr. Connect 32,000 on scale W with 0.8 on secondary scale SG and where scale Q is crossed, read the maximum possible volume flow rate as 6400 cu.ft/hr.



Each motor has a unique efficiency curve, but motor efficiency curves in general adhere to the shape shown here. Manufacturers generally design their motors for maximum efficiency at or about 100 per cent of full load. If efficiency of one motor is being compared to that of another, and specific efficiency curves are not available for both, it can be reasonably presumed that the general shape of the curves for both motors will conform to the shape shown here, although magnitudes might differ.

## REFERENCE :

- |   |   |                                     |  |
|---|---|-------------------------------------|--|
| 1. Energy Auditing                              | — Published by the<br>Fairmont Press Inc.<br>P.O. Box 14227<br>Atlanta, Georgia - 30324 | 3. Energy Audit Series              | — Department of Energy,<br>London.         |
| 2. Energy Analysis: A New<br>Public Policy Tool | — Edited by Martha<br>W. Gilland  | 4. Spirax Sarco Information<br>Book | — Spirax Sarco Ltd,<br>Cheltenham, London. |



The following PCRA booklets on Efficient Utilisation of Fuel Oils in Industry, are available :

1. Storage, handling and preparation of fuel oil.
2. Combustion of fuel oils & Burners — operation and maintenance.
3. Efficient generation of steam.
4. Efficient utilisation of steam.
5. Fuel economy in furnaces and waste heat recovery.
6. Refractories.
7. Thermal insulation.

PCRA films available for Industrial sector :

1. "Tuning of Boilers and Furnaces"
2. "Handling of Fuel Oils"
3. "Efficient Utilisation of Steam in Industries" — (under production).



# **EFFICIENT OPERATION OF BOILERS AND FURNACES**

---



## **AN OPERATOR'S GUIDE**



## **roduction**

he efficiency of a boiler or furnace depends on how efficient the combustion system is and how best it is being operated. This involves knowing correct methods for efficient boiler and furnace operation.

This booklet provides guidelines for proper operation and maintenance of boilers and furnaces and for a proper understanding of steam generation, distribution and utilisation.






Figure 1. A  
connection to the  
part of the  
and the  
to the

TER



GR754

When you call the Service  
ask to go to the one on  
Ole Towne







## 2. Prevent oil leak

Stop oil leaks from flanges, valves, joints bends promptly. A leak one drop every second amounts to a loss of 4,000 litres of oil per year.



---

### **3. Drain water from storage tanks regularly**

A thick, dirty sludge would form if water is allowed to remain mixed in oil. So drain off water from the storage tank periodically.











**4. Clean oil filters  
periodically**





## 5. Maintain correct preheat temperature of oil

Use out-flow heater in the main storage tank only during winter. Take care to maintain the temperature between 30°-35°C for furnace oil.



Before supplying furnace oil to the burner, it should be heated to about 100°C.





## 6. Maintain correct pressure of oil and air at burner

### Burner type

LAP

MAP

Pressure jet

### Oil pressure

0.6-0.8 kg/cm<sup>2</sup>

6-7 kg/cm<sup>2</sup>

14-18 kg/cm<sup>2</sup>

### Air pressure

60 cm of water gauge

2-3 kg/cm<sup>2</sup>

—




## II. Combustion and Burners


### 7. Smoke indicates combustion condition

A lot of fuel is wasted when black smoke comes out from the chimney. This indicates poor combustion.





A very clean chimney on the contrary, shows that too much air is being used for combustion.



The best combustion is achieved when you get a light brown haze from the chimney which shows the desired level of excess air.










## 8. Reduce excess air

Theoretically, 1 kg. of oil requires 14.1 kg. of air for complete combustion. But in practice, about 20-25% excess air is required for complete combustion.

If the carbon-di-oxide is below 12.5% to 10% or if the oxygen is above 4% to 4.5%, it shows that there is more of excess air.

Excess air would make the burner use up more fuel. Analyse flue gases for carbon-di-oxide and oxygen content periodically.



### **9. Replace cracked burner blocks fast**

A cracked or damaged burner block will disturb the shape of the flame and result in poor combustion. This will also cause problems in restarting the furnace or boiler.




### **10. Clean burner nozzles regularly**

It is a good practice to clean burner nozzles at least once in a shift. First of all, soak the nozzles in kerosene and after a while, when deposits are well soaked, remove the carbon particles by rubbing them away. Use some soft wire like copper. Never use steel wire as this would damage the nozzles. Always keep some spare nozzles handy

---








11. Follow correct methods for oil boiler operation

### (1) Start-up

Before lighting the burner start the blower first and keep it running for some time to purge oil vapour gases away.




Take care to place the flame, either from a torch or any other source, only in front of the nozzle. Before lighting, ensure that only preheated oil reaches the burner.



## (ii) Operations

Check if the oil is preheated to the correct temperature (about 100°C) at the burner tip. Also check for the correct air pressure for your burner and make sure that no oil drips anywhere.

Align the burner, making sure that the flame does not strike on the refractory walls or charge. Flame impingement on the material does not help either in reducing the heating time or fuel consumption.



Adjust the length of the flame to suit the conditions, making sure that the flame does not leap out of the furnace.









### (iii) Load changes

Operate both air and oil valves at the same time.




Adjust burners and damper till you get a hazy, light brown smoke from the chimney, with at least 12.5% carbon-di-oxide or 3%-4% oxygen.





#### (iv) Shut down

Close oil line first.




Purge the oil vapour by keeping the blower on for sometime.





Do not keep the burner nozzle exposed to the radiant heat of the furnace. When you shut off the oil, take care to remove the burner/nozzle or place a thin refractory between the nozzle and the furnace.






### **III. Steam Generation**

#### **12. Keep water level between half and two third in the gauge glass**

If the water level is higher, it will be carried over along with steam. On the contrary, it is dangerous if the water level is low.



#### **13. Blow down the Boiler regularly**

Blowing down regularly reduces water-side scale formation on the sides. A scale formation of 1 mm thickness on the water side would increase your fuel consumption by 5-8%. On the other hand, excessive blow down also wastes fuel.

---








14.

Treat water properly to ensure good efficiency and a longer life span for the boiler.






### **15. Analyse flue gases regularly**

Flue gases need to be analysed frequently. Always maintain 12.5% to 13% carbon-di-oxide or 4-5% oxygen.

If the flue gas temperature rises about 40°C above the required normal (i.e. 180-200°C), then it should be reported immediately, for it is a sign of soot deposition. Even a soot of 3 mm thickness on the heat transfer surface can increase your fuel consumption by as much as 2 to 5%.



### **16. Check feed water temperature**

A sudden increase in feed water temperature is not normal and may result in damaging the feed water pump. Check feed water temperature frequently. Report wide variations promptly.





## IV. Steam Distribution

### 17. Is the steam distribution in order?

Check and report the following:

- a) Steam leak
- b) Sagged pipelines
- c) Damaged insulation of pipelines, flanges and joints.





## V. Efficient Steam Usage

### 18. Stop steam leakages

Attend to steam leak promptly.

A 3mm diameter leak on a pipeline carrying  $7\text{kg}/\text{cm}^2$  steam would amount to a waste of 32,000 litres of furnace oil per year.





### **19. Use right-quality steam**

Use dry steam at the required pressure and not at a higher pressure. Use steam at 0.5-1 kg/cm<sup>2</sup> for open steam injection.




### **20. Check steam traps**

Keep the sight glass clean. Do not keep the by-pass valves open. Report leaking traps immediately.









**21. Use flash steam whenever it is possible**

Use of flash steam reduces the load on the boiler and save fuel.



**22. Report damaged insulation of steam consuming equipment.**

Damaged/poor insulation of hot surface causes heat losses besides resulting in uncomfortable working conditions.

### **23. Prevent sudden boiler load fluctuation**

Inform start-up/shut down  
of steam consuming  
machines well in advance  
so that steam supply could  
be properly regulated from  
the boiler house in time.







## VI. Furnace o

### 24. Prevent flame impingement

Align burner(s) properly.  
Avoid flame from touching the materials. This will not only reduce hot spots on the material, but it would also eliminate soot deposits.




### **Adjust flame length**

leaping out of flues/  
openings means a  
loss of fuel.



### **26. Keep furnace doors closed:**

Keeping the furnace door  
unnecessarily open leads  
to wastage of fuel.












**27. Close all openings,  
including inspection  
holes**

Even small openings result  
in a lot of heat loss and  
thereby fuel wastage.



**28. Prevent air  
infiltration through  
furnace brick work**


Infiltrated air cools down the  
furnace and increases fuel  
consumption as well as  
scale losses.



---

**29. Operate the furnace  
at a slight positive  
pressure**

A slight positive pressure will prevent air infiltration. A simple way to check positive pressure is to hold a thread in front of the inspection hole or any other opening of the furnace. If the thread is sucked in, then the furnace is under negative pressure. If the thread is blown out, the furnace is under positive pressure.







### 30. Maintain correct furnace temperature

Correct temperature ensures good quality products.


A temperature that is higher than required would only use up more fuel.



---

### 31. Load the furnace its rated capacity

Overloading or underload  
uses up more fuel.









### 32. Recover waste heat

A recuperator regains the heat from waste gases. Keep the gas temperature within specified limits and check the temperature of preheated air.

Increase in flue gas temperature or decrease in air-preheat temperature after the recuperator indicates the need for cleaning of the recuperator tubes.

